

ROME MET, OR, USA

WMO: 726874

Lat: 42.900N

Lon: 117.650W

Elev: 3812

StdP: 12.78

Time Zone: -7.00 (NAM)

Period: 86-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	2.1	8.6	-7.4	4.3	10.1	1.2	6.7	13.5	23.3	47.0	20.2	40.1	4.7	100	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.6	97.4	60.9	95.1	60.0	92.1	59.1	62.1	92.9	61.0	91.4	59.8	89.2	7.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.0	66.4	66.0	49.4	60.1	64.2	47.3	55.6	63.9	29.5	92.0	28.7	92.1	27.9	89.2	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.7	17.9	15.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			-6.5	64.0	9.9	1.0	-13.6	64.7	-19.4	65.3	-25.0	65.8	-32.2	66.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.1	30.8	35.6	43.3	49.9	57.0	65.5	73.1	72.5	63.9	52.9	38.0	29.2
	DBStd	17.20	9.30	10.39	6.64	7.75	8.27	8.66	6.91	6.80	7.78	7.66	8.45	9.84
	HDD50	2422	597	403	224	98	25	2	0	0	4	56	368	645
	HDD65	5837	1062	823	674	456	273	100	18	21	112	378	810	1110
	CDD50	2811	0	0	15	94	243	467	716	699	422	147	8	0
	CDD65	751	0	0	0	3	26	115	269	255	79	4	0	0
	CDH74	12092	0	0	0	142	582	1884	3996	3743	1523	222	0	0
	CDH80	6051	0	0	0	23	209	888	2178	2017	678	58	0	0
Wind	WSAvg	6.0	5.1	5.0	6.1	6.9	7.3	7.2	6.4	6.1	5.7	5.5	5.2	4.8
Precipitation	PrecAvg	9.8	1.0	0.7	0.8	1.2	1.4	1.1	0.3	0.2	0.4	0.8	0.8	1.1
	PrecMax	15.8	3.1	1.7	1.8	2.4	4.5	3.3	1.3	0.6	2.4	2.5	1.5	2.5
	PrecMin	6.1	0.1	0.2	0.1	0.4	0.1	0.0	0.0	0.0	0.0	0.4	0.2	
	PrecStd	2.5	0.7	0.4	0.4	0.5	1.1	0.7	0.4	0.2	0.5	0.7	0.3	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	64.0	70.9	83.1	90.8	96.8	100.8	100.9	95.5	85.8	66.6	56.2
		MCWB	43.8	46.9	47.4	54.5	60.1	60.3	62.6	62.2	59.7	55.0	49.4	43.7
	2%	DB	50.5	57.6	65.7	78.7	86.0	93.7	97.9	97.5	91.4	80.4	60.1	51.5
		MCWB	40.8	44.1	46.7	52.7	56.4	59.5	61.2	60.9	58.1	52.9	45.8	41.7
	5%	DB	46.3	53.2	61.2	72.2	81.0	89.7	95.5	94.7	87.8	74.8	55.1	46.7
		MCWB	38.9	42.1	44.3	49.9	54.8	58.4	60.3	59.9	56.8	50.8	44.0	38.5
	10%	DB	43.1	49.0	56.8	66.5	75.2	85.3	92.0	91.4	83.9	69.2	51.1	42.5
		MCWB	36.3	40.4	42.9	48.0	52.9	56.7	59.1	58.7	55.1	48.7	42.1	36.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.9	48.2	49.6	56.1	62.6	62.4	63.3	63.4	60.6	56.0	50.1	44.9
		MCDB	52.3	61.2	65.4	78.5	88.6	88.5	97.8	93.7	90.4	83.3	60.6	54.1
	2%	WB	41.8	45.3	47.6	53.5	57.8	60.7	62.0	62.0	59.0	53.9	47.7	42.0
		MCDB	49.2	56.4	62.4	75.4	80.3	87.4	95.3	92.9	89.3	78.2	57.2	50.0
	5%	WB	39.1	43.1	45.9	51.0	55.8	59.4	60.9	60.7	57.3	51.5	45.3	39.3
		MCDB	45.7	51.4	59.5	69.4	77.6	86.2	92.7	91.2	86.0	72.3	53.9	46.1
	10%	WB	36.7	41.0	44.0	48.8	53.8	57.8	59.8	59.4	55.5	49.7	42.9	36.5
		MCDB	42.2	48.6	54.9	64.4	72.8	82.4	90.0	89.0	82.0	67.4	50.9	42.0
Mean Daily Temperature Range	5% DB	MDBR	17.6	21.1	22.9	25.2	26.2	29.0	31.6	32.6	32.6	30.2	20.0	17.6
		MCDBR	20.2	28.0	31.8	35.0	35.2	34.9	35.6	36.8	38.9	38.5	25.6	21.2
		MCWBR	12.5	16.1	16.2	16.1	14.1	13.0	14.1	15.2	17.5	19.0	15.1	13.5
	5% WB	MCDBR	18.2	25.4	27.0	32.1	33.0	33.0	33.8	34.5	36.7	35.2	23.9	18.4
		MCWBR	11.4	15.4	14.1	14.8	13.6	12.0	13.0	14.0	16.4	17.6	14.7	12.4
Clear-Sky Solar Irradiance	taub	0.254	0.263	0.274	0.296	0.317	0.316	0.325	0.322	0.302	0.276	0.259	0.253	
	taud	2.610	2.625	2.608	2.527	2.489	2.523	2.505	2.499	2.548	2.630	2.626	2.603	
	Ebn at Noon	291	305	312	309	303	302	298	296	297	295	287	281	
	Edh at Noon	20	23	27	31	34	33	33	32	28	23	19	18	
All-Sky Solar Radiation	RadAvg	532	845	1251	1720	2065	2397	2443	2128	1678	1125	669	435	
	RadStd	88	110	115	133	169	134	99	97	82	77	54	78	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (10 neighbors)	N/A	N/A	-2.41	N/A	N/A	N/A	N/A	N/A	+148	+70	

Nomenclature: See separate page