

ROME MET, OR, USA

WMO: 726874

Lat: 42.900N

Lon: 117.650W

Elev: 1162

StdP: 88.12

Time Zone: -7.00 (NAM)

Period: 86-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-16.6	-13.0	-21.9	0.6	-12.2	-17.1	1.0	-10.3	10.4	8.3	9.0	4.5	2.1	100	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	36.4	16.1	35.0	15.6	33.4	15.0	16.7	33.8	16.1	33.0	15.4	31.8	3.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.1	9.5	18.9	9.7	8.6	17.9	8.5	7.9	17.7	50.8	33.3	49.0	33.4	47.0	31.8	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.0	6.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-21.4	17.8	5.5	0.6	-25.3	18.2	-28.6	18.5	-31.7	18.8	-35.7	19.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	-0.7	2.0	6.3	9.9	13.9	18.6	22.8	22.5	17.7	11.6	3.3	-1.6		
	DBStd	9.56	5.17	5.77	3.69	4.31	4.60	4.81	3.84	3.78	4.32	4.26	4.69	5.46		
	HDD10.0	1346	332	224	124	54	14	1	0	0	2	31	204	358		
	HDD18.3	3243	590	457	374	253	152	56	10	12	62	210	450	617		
	CDD10.0	1562	0	0	8	52	135	259	398	388	234	82	4	0		
	CDD18.3	417	0	0	0	2	14	64	149	142	44	2	0	0		
	CDH23.3	6718	0	0	0	79	323	1047	2220	2079	846	123	0	0		
	CDH26.7	3362	0	0	0	13	116	493	1210	1121	377	32	0	0		
(14) Wind	WSAvg	2.7	2.3	2.3	2.7	3.1	3.3	3.2	2.9	2.7	2.6	2.4	2.3	2.2		
(15) Precipitation	PrecAvg	250	26	19	20	31	35	27	8	5	10	20	20	29		
	PrecMax	402	80	42	46	61	115	83	34	16	60	64	38	64		
	PrecMin	156	3	4	2	10	2	0	0	0	0	0	9	6		
	PrecStd	63	18	11	11	13	27	19	9	5	13	19	8	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	17.8	21.6	28.4	32.7	36.0	38.2	38.3	35.3	29.9	19.2	13.5		
		MCWB	6.5	8.3	8.6	12.5	15.6	15.7	17.0	16.8	15.4	12.8	9.7	6.5		
	2%	DB	10.3	14.2	18.7	25.9	30.0	34.3	36.6	36.4	33.0	26.9	15.6	10.8		
		MCWB	4.9	6.7	8.2	11.5	13.6	15.3	16.2	16.1	14.5	11.6	7.7	5.4		
	5%	DB	7.9	11.8	16.2	22.3	27.2	32.1	35.3	34.8	31.0	23.8	12.8	8.1		
		MCWB	3.8	5.6	6.8	9.9	12.7	14.7	15.7	15.5	13.8	10.5	6.6	3.6		
	10%	DB	6.2	9.4	13.8	19.2	24.0	29.6	33.3	33.0	28.8	20.7	10.6	5.8		
		MCWB	2.4	4.7	6.1	8.9	11.6	13.7	15.0	14.8	12.9	9.3	5.6	2.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	9.0	9.8	13.4	17.0	16.9	17.4	17.4	15.9	13.4	10.1	7.2		
		MCDB	11.3	16.2	18.5	25.8	31.4	31.4	36.6	34.3	32.5	28.5	15.9	12.3		
	2%	WB	5.5	7.4	8.7	12.0	14.3	16.0	16.7	16.7	15.0	12.2	8.7	5.6		
		MCDB	9.5	13.5	16.9	24.1	26.8	30.8	35.1	33.8	31.8	25.7	14.0	10.0		
	5%	WB	3.9	6.1	7.7	10.6	13.2	15.2	16.0	15.9	14.0	10.8	7.4	4.0		
		MCDB	7.6	10.8	15.3	20.8	25.3	30.1	33.7	32.9	30.0	22.4	12.2	7.8		
	10%	WB	2.6	5.0	6.7	9.4	12.1	14.3	15.4	15.2	13.1	9.8	6.1	2.5		
		MCDB	5.7	9.2	12.7	18.0	22.7	28.0	32.2	31.7	27.8	19.7	10.5	5.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	11.7	12.7	14.0	14.5	16.1	17.6	18.1	18.1	16.8	11.1	9.8		
		MCDBR	11.2	15.5	17.7	19.5	19.6	19.4	19.8	20.4	21.6	21.4	14.2	11.8		
	5% WB	MCWBR	6.9	9.0	9.0	8.9	7.9	7.2	7.8	8.5	9.7	10.6	8.4	7.5		
		MCWBR	10.1	14.1	15.0	17.8	18.3	18.8	19.2	20.4	19.6	13.3	10.2	6.9		
(40) Clear-Sky Solar Irradiance	taub		0.254	0.263	0.274	0.296	0.317	0.316	0.325	0.322	0.302	0.276	0.259	0.253		
	taud		2.610	2.625	2.608	2.527	2.489	2.523	2.505	2.499	2.548	2.630	2.626	2.603		
	Ebn at Noon		918	962	983	975	955	953	940	934	935	931	904	886		
	Edh at Noon		63	73	84	99	106	103	104	101	89	72	61	58		
(44) All-Sky Solar Radiation	RadAvg		1.68	2.67	3.94	5.42	6.51	7.56	7.70	6.71	5.29	3.55	2.11	1.37		
	RadStd		0.28	0.35	0.36	0.42	0.53	0.42	0.31	0.31	0.26	0.24	0.17	0.25		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	-1.34	N/A	N/A	N/A	N/A	N/A	+82	+39

Nomenclature: See separate page