

BAKER CITY, OR, USA

WMO: 726886

Lat: 44.843N

Lon: 117.809W

Elev: 3361

StdP: 13.00

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24130

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	0.9	7.7	-3.9	5.1	2.1	2.7	7.1	9.4	25.5	35.6	23.3	33.0	1.8	160	0.627

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.7	93.0	62.9	90.0	62.3	86.4	61.2	65.4	87.2	63.8	85.6	62.3	83.5	8.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.6	80.3	70.8	55.3	73.7	70.1	53.7	69.5	69.3	31.9	87.1	30.6	85.4	29.5	83.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.7	20.3	18.4	DB	-7.9	99.3	7.4	3.1	-13.2	101.5	-17.5	103.3	-21.7	105.0	-27.0	107.3	(4)
(5)			WB	-8.4	69.4	7.3	2.2	-13.7	71.0	-17.9	72.3	-22.0	73.6	-27.3	75.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.0	27.2	31.5	39.0	44.1	52.2	58.9	67.5	66.2	57.5	45.2	34.8	26.8	(6)	
	DBStd	15.68	8.89	7.63	6.38	6.48	7.27	6.52	5.35	5.62	6.97	7.07	8.13	8.96	(7)	
	HDD50	3210	706	518	345	198	62	8	0	0	14	182	457	720	(8)	
	HDD65	7174	1171	937	807	627	398	199	37	53	241	614	905	1185	(9)	
	CDD50	1751	0	0	3	21	131	277	542	503	239	33	2	0	(10)	
	CDD65	239	0	0	0	0	2	17	114	91	15	0	0	0	(11)	
	CDH74	6196	0	0	0	24	183	608	2441	2184	715	41	0	0	(12)	
	CDH80	2634	0	0	0	2	39	189	1133	1010	254	7	0	0	(13)	
(14) Wind	WSAvg	6.8	6.3	7.0	7.8	8.5	7.8	7.1	6.3	5.9	5.7	6.0	6.5	6.7	(14)	
(15) Precipitation	PrecAvg	10.5	0.9	0.6	0.8	0.8	1.4	1.2	0.6	0.8	0.7	0.6	0.9	1.0	(15)	
	PrecMax	15.7	2.6	1.7	1.8	3.6	4.2	5.0	2.3	3.5	2.7	1.7	2.2	2.8	(16)	
	PrecMin	5.6	0.2	0.1	0.1	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.0	(17)	
	PrecStd	2.2	0.5	0.4	0.4	0.6	0.9	0.9	0.6	0.9	0.7	0.4	0.6	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.0	56.3	66.7	77.4	84.4	90.5	97.3	97.2	91.3	79.5	62.6	50.0	(19)	
		MCWB	41.1	46.0	48.7	55.1	59.5	63.2	64.3	62.7	62.2	56.5	49.7	43.2	(20)	
	2%	DB	43.2	50.1	61.3	71.1	79.3	85.5	93.3	93.1	86.6	72.2	56.2	45.5	(21)	
		MCWB	38.1	41.9	46.3	52.3	58.1	61.6	63.6	62.1	59.6	52.6	45.9	40.8	(22)	
	5%	DB	40.7	46.1	56.9	65.0	74.5	81.2	90.4	90.0	82.3	66.5	51.9	42.0	(23)	
		MCWB	36.5	39.7	44.4	49.4	55.8	59.6	62.9	61.6	58.3	50.5	44.1	37.8	(24)	
	10%	DB	38.2	42.9	52.5	59.7	69.8	76.8	86.7	86.1	77.4	61.3	47.9	38.7	(25)	
		MCWB	34.7	37.4	42.5	46.5	53.6	57.9	62.0	60.7	56.5	47.9	41.5	35.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.9	46.8	50.2	56.7	62.3	66.9	68.3	66.2	64.7	57.8	50.9	44.4	(27)	
		MCDB	45.2	55.2	62.5	73.8	79.7	84.2	89.5	89.3	84.4	75.1	60.2	48.3	(28)	
	2%	WB	39.2	42.8	47.7	53.1	59.4	63.1	66.0	64.4	61.9	54.2	47.3	41.3	(29)	
		MCDB	42.4	48.9	59.2	68.6	75.4	81.3	87.8	88.0	82.1	69.2	54.2	44.8	(30)	
	5%	WB	36.9	40.3	45.5	50.2	57.0	60.8	64.3	63.0	59.6	51.4	44.5	38.2	(31)	
		MCDB	40.0	45.4	55.2	63.1	71.5	78.2	86.0	86.3	78.4	64.4	51.1	41.1	(32)	
	10%	WB	35.0	37.9	43.3	47.6	54.7	58.8	62.7	61.4	57.5	49.0	42.0	35.7	(33)	
		MCDB	37.7	42.3	51.8	58.6	67.9	74.8	84.1	83.8	75.4	59.8	47.4	38.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	17.9	23.2	26.5	27.6	29.8	36.7	38.2	36.1	29.8	20.5	15.2	(35)	
		MCDBR	16.3	21.4	31.6	38.2	37.4	38.5	42.3	44.0	44.4	39.3	26.6	16.2	(36)	
		MCWBR	12.1	14.2	18.5	20.8	18.2	17.6	17.0	17.3	20.2	21.5	17.1	11.9	(37)	
	5% WB	MCDBR	15.2	20.0	29.3	35.2	33.6	35.4	38.9	40.6	40.3	35.5	23.9	14.0	(38)	
		MCWBR	11.7	13.7	17.8	19.5	16.7	16.8	16.6	16.5	18.6	20.0	15.9	10.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.271	0.275	0.292	0.329	0.343	0.336	0.337	0.343	0.328	0.310	0.279	0.268	(40)	
	taud		2.407	2.451	2.499	2.416	2.416	2.463	2.484	2.450	2.480	2.525	2.548	2.472	(41)	
	Ebn at Noon		272	293	302	296	294	295	293	288	285	276	269	263	(42)	
	Edh at Noon		23	27	29	35	36	34	33	33	30	25	20	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		460	757	1137	1629	1950	2260	2429	2076	1564	989	548	367	(44)	
	RadStd		62	89	119	130	157	136	98	110	102	85	48	52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		N/A	N/A	N/A	N/A	-0.52	N/A	N/A	N/A	+140	N/A

Nomenclature: See separate page