

BAKER CITY, OR, USA

WMO: 726886

Lat: 44.843N

Lon: 117.809W

Elev: 1024

StdP: 89.61

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24130

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-17.3	-13.5	-19.9	0.7	-16.6	-16.3	1.0	-12.6	11.4	2.0	10.4	0.5	0.8	160	0.627

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	33.9	17.1	32.2	16.8	30.2	16.2	18.6	30.7	17.7	29.8	16.8	28.6	3.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	11.5	21.6	12.9	10.5	21.2	12.0	9.9	20.7	56.3	30.6	53.3	29.6	50.7	28.7	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 10.6	9.1	8.2	DB	-22.2	37.4	4.1	1.7	-25.1	38.6	-27.5	39.6	-29.8	40.6	-32.8	41.8	(4)
(5)			WB	-22.5	20.8	4.0	1.2	-25.4	21.7	-27.7	22.4	-30.0	23.1	-32.9	24.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-2.7	-0.3	3.9	6.7	11.2	15.0	19.7	19.0	14.2	7.3	1.6	-2.9	(6)	
(7)		DBStd	8.71	4.94	4.24	3.54	3.60	4.04	3.62	2.97	3.12	3.87	3.93	4.52	4.98	(7)	
(8)		HDD10.0	1783	392	288	192	110	34	4	0	0	8	101	254	400	(8)	
(9)		HDD18.3	3986	651	521	448	348	221	111	21	29	134	341	503	658	(9)	
(10)		CDD10.0	973	0	0	2	12	73	154	301	279	133	18	1	0	(10)	
(11)		CDD18.3	133	0	0	0	0	1	9	63	51	8	0	0	0	(11)	
(12)		CDH23.3	3442	0	0	0	13	102	338	1356	1213	397	23	0	0	(12)	
(13)		CDH26.7	1463	0	0	0	1	22	105	629	561	141	4	0	0	(13)	
(14)	Wind	WSAvg	3.0	2.8	3.1	3.5	3.8	3.5	3.2	2.8	2.6	2.5	2.7	2.9	3.0	(14)	
(15)	Precipitation	PrecAvg	267	24	15	21	21	36	31	15	20	17	15	24	26	(15)	
(16)		PrecMax	400	66	42	46	91	107	128	59	89	69	43	55	72	(16)	
(17)		PrecMin	143	5	2	3	1	5	1	0	0	0	0	3	1	(17)	
(18)		PrecStd	57	13	9	10	14	24	23	15	22	17	11	14	16	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	13.5	19.3	25.2	29.1	32.5	36.3	36.2	33.0	26.4	17.0	10.0	(19)	
(20)			MCWB	5.0	7.8	9.3	12.9	15.3	17.3	18.0	17.1	16.8	13.6	9.8	6.2	(20)	
(21)		2%	DB	6.2	10.1	16.3	21.7	26.3	29.7	34.1	33.9	30.4	22.3	13.5	7.5	(21)	
(22)			MCWB	3.4	5.5	8.0	11.3	14.5	16.5	17.5	16.7	15.3	11.5	7.7	4.9	(22)	
(23)		5%	DB	4.8	7.9	13.8	18.3	23.6	27.3	32.4	32.2	28.0	19.1	11.0	5.6	(23)	
(24)			MCWB	2.5	4.3	6.9	9.7	13.2	15.3	17.2	16.5	14.6	10.3	6.7	3.2	(24)	
(25)		10%	DB	3.4	6.1	11.4	15.4	21.0	24.9	30.4	30.0	25.2	16.3	8.8	3.7	(25)	
(26)			MCWB	1.5	3.0	5.9	8.0	12.0	14.4	16.6	16.0	13.6	8.9	5.3	1.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	8.2	10.1	13.7	16.8	19.4	20.1	19.0	18.2	14.3	10.5	6.9	(27)	
(28)			MCDWB	7.3	12.9	17.0	23.2	26.5	29.0	31.9	31.9	29.1	24.0	15.7	9.0	(28)	
(29)		2%	WB	4.0	6.0	8.7	11.7	15.2	17.3	18.9	18.0	16.6	12.3	8.5	5.2	(29)	
(30)			MCDWB	5.8	9.4	15.1	20.4	24.1	27.4	31.0	31.1	27.8	20.7	12.4	7.1	(30)	
(31)		5%	WB	2.7	4.6	7.5	10.1	13.9	16.0	17.9	17.2	15.3	10.8	6.9	3.5	(31)	
(32)			MCDWB	4.5	7.5	12.9	17.3	21.9	25.7	30.0	30.2	25.8	18.0	10.6	5.1	(32)	
(33)		10%	WB	1.7	3.3	6.3	8.7	12.6	14.9	17.1	16.3	14.2	9.4	5.6	2.0	(33)	
(34)			MCDWB	3.2	5.7	11.0	14.8	19.9	23.8	28.9	28.8	24.1	15.5	8.6	3.6	(34)	
(35)	Mean Daily Temperature Range			MDBR	8.4	10.0	12.9	14.7	15.3	16.6	20.4	21.2	20.1	16.6	11.4	8.4	(35)
(36)		5% DB	MCDBR	9.0	11.9	17.5	21.2	20.8	21.4	23.5	24.4	24.7	21.8	14.8	9.0	(36)	
(37)			MCWBR	6.7	7.9	10.3	11.5	10.1	9.8	9.4	9.6	11.2	11.9	9.5	6.6	(37)	
(38)			MCDBR	8.4	11.1	16.3	19.6	18.7	19.6	21.6	22.6	22.4	19.7	13.3	7.8	(38)	
(39)		5% WB	MCWBR	6.5	7.6	9.9	10.8	9.3	9.3	9.2	9.1	10.4	11.1	8.8	6.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.271	0.275	0.292	0.329	0.343	0.336	0.337	0.343	0.328	0.310	0.279	0.268	(40)	
(41)		taud		2.407	2.451	2.499	2.416	2.416	2.463	2.484	2.450	2.480	2.525	2.548	2.472	(41)	
(42)		Ebn at Noon		856	924	951	934	926	930	925	908	897	870	848	828	(42)	
(43)		Edh at Noon		72	84	92	109	113	108	105	105	93	78	63	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg		1.45	2.39	3.58	5.14	6.15	7.12	7.66	6.55	4.93	3.12	1.73	1.16	(44)	
(45)		RadStd		0.19	0.28	0.38	0.41	0.49	0.43	0.31	0.35	0.32	0.27	0.15	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		N/A	N/A	N/A	N/A	-0.29	N/A	N/A	N/A	+78	N/A

Nomenclature: See separate page