

EUGENE, OR, USA

WMO: 726930

Lat: 44.128N

Lon: 123.221W

Elev: 108

StdP: 100.04

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24221

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.6	-2.6	-8.0	1.9	-2.8	-5.2	2.5	-1.4	11.1	9.5	9.7	9.1	1.9	0	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	33.4	19.3	31.3	18.7	29.2	18.0	20.4	30.7	19.5	29.5	18.6	27.8	4.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.7	12.0	23.5	15.7	11.3	22.4	14.8	10.7	21.5	58.7	31.0	55.6	29.3	52.8	27.8	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.8	7.0	-7.9	37.7	3.9	1.9	-10.7	39.0	-13.0	40.1	-15.1	41.2	-18.0	42.5		
(5)			-8.5	22.6	3.8	1.0	-11.2	23.3	-13.5	23.9	-15.6	24.5	-18.4	25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	5.2	6.2	8.2	10.2	13.2	16.1	20.0	20.0	17.1	11.8	7.6	4.8	(6)
(7)		DBStd	6.16	3.49	3.07	2.81	2.73	3.02	2.97	2.80	2.59	2.83	3.00	3.49	3.84	(7)
(8)		HDD10.0	636	151	111	70	30	6	0	0	0	0	16	87	166	(8)
(9)		HDD18.3	2572	406	339	313	244	161	81	13	12	56	203	323	420	(9)
(10)		CDD10.0	1271	3	4	15	36	106	182	311	310	213	71	15	4	(10)
(11)		CDD18.3	166	0	0	0	0	2	13	66	64	19	1	0	0	(11)
(12)		CDH23.3	2767	0	0	1	9	80	283	1052	939	386	17	0	0	(12)
(13)		CDH26.7	1101	0	0	0	0	14	96	461	395	132	2	0	0	(13)
(14)	Wind	WSAvg	3.0	2.9	3.1	3.2	3.0	2.8	3.0	3.2	3.1	2.9	2.8	2.9	3.1	(14)
(15)	Precipitation	PrecAvg	1213	188	135	139	84	62	34	12	24	36	80	202	207	(15)
(16)		PrecMax	1626	383	361	316	199	176	99	76	147	118	206	520	533	(16)
(17)		PrecMin	704	8	22	20	12	4	2	0	0	0	3	34	32	(17)
(18)		PrecStd	231	98	80	70	49	38	26	15	31	29	51	103	122	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	16.5	20.6	24.7	28.5	33.3	37.2	35.7	33.1	25.4	18.8	15.0	(19)
(20)			MCWB	12.6	12.4	13.5	16.9	19.1	20.4	20.4	19.5	17.9	15.6	15.1	12.2	(20)
(21)		2%	DB	13.2	14.0	17.5	21.2	25.6	29.3	33.8	33.2	30.2	22.5	15.8	13.1	(21)
(22)			MCWB	11.2	10.8	12.2	14.8	17.7	18.4	19.6	18.9	17.5	14.4	13.1	11.4	(22)
(23)		5%	DB	11.7	12.4	15.3	18.4	23.0	26.5	31.4	30.9	27.8	19.8	14.1	11.5	(23)
(24)			MCWB	10.1	9.9	11.3	13.0	16.4	17.5	18.8	18.6	17.0	13.7	12.1	10.2	(24)
(25)		10%	DB	10.4	11.1	13.4	16.0	20.3	23.9	29.1	28.7	25.2	17.5	12.7	10.1	(25)
(26)			MCWB	8.9	9.0	10.2	11.5	14.7	16.2	18.1	17.9	16.0	13.3	10.9	8.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.4	13.6	14.4	17.7	20.2	21.0	22.3	21.0	20.0	17.7	15.7	13.1	(27)
(28)			MCD B	14.6	15.7	18.7	23.7	27.0	31.1	34.1	32.4	29.5	22.4	17.8	14.2	(28)
(29)		2%	WB	11.6	11.7	12.9	15.2	18.1	19.3	20.5	20.0	18.7	15.9	13.9	11.6	(29)
(30)			MCD B	12.8	13.1	16.5	20.3	24.5	28.3	31.3	31.0	27.3	19.9	15.3	12.6	(30)
(31)		5%	WB	10.3	10.4	11.7	13.4	16.6	17.9	19.5	19.1	17.7	14.8	12.4	10.3	(31)
(32)			MCD B	11.5	12.0	14.5	17.6	22.4	25.6	29.9	29.4	26.0	18.1	13.7	11.5	(32)
(33)		10%	WB	9.0	9.1	10.6	11.9	15.1	16.6	18.5	18.2	16.7	13.7	11.1	8.8	(33)
(34)			MCD B	10.3	10.8	13.0	15.2	19.9	23.3	28.2	27.5	23.8	16.7	12.4	10.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	8.0	9.5	10.7	12.1	13.6	16.8	16.7	15.2	11.3	7.4	6.0	(35)
(36)			MCD BR	7.7	9.9	13.0	15.8	17.6	18.9	20.8	20.8	20.5	16.1	8.7	6.9	(36)
(37)			MCWBR	5.7	6.8	8.2	9.9	10.4	9.2	8.4	8.5	9.1	8.9	6.1	5.4	(37)
(38)		5% WB	MCD BR	7.2	8.5	12.0	14.5	16.6	17.7	19.4	19.0	17.7	12.0	7.4	6.3	(38)
(39)			MCWBR	5.6	6.1	7.9	9.5	10.1	9.0	8.5	8.2	8.3	7.3	5.5	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.313	0.315	0.318	0.355	0.358	0.355	0.349	0.355	0.344	0.323	0.317	0.322	(40)	
(41)		taud	2.554	2.558	2.558	2.418	2.430	2.442	2.478	2.481	2.497	2.569	2.553	2.500	(41)	
(42)		Ebn at Noon	820	886	927	909	912	913	915	898	883	863	806	765	(42)	
(43)		Edh at Noon	67	78	88	110	112	111	106	102	93	76	66	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.38	2.17	3.18	4.53	5.76	6.42	7.27	6.26	4.71	2.81	1.54	1.11	(44)	
(45)		RadStd	0.20	0.28	0.38	0.38	0.54	0.54	0.42	0.37	0.38	0.30	0.19	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+24
(47) Regional (25 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+92	+30

Nomenclature: See separate page