

NEWPORT MUNICIPAL, OR, USA

WMO: 726950

Lat: 44.583N

Lon: 124.050W

Elev: 122

StdP: 14.63

Time Zone: -8.00 (NAP)

Period: 02-19

WBAN: 24285

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 30.4	(c) 32.3	(d) 18.2	(e) 13.8	(f) 36.7	(g) 23.5	(h) 17.8	(i) 38.5	(j) 36.8	(k) 52.1	(l) 33.6	(m) 51.1	(n) 8.2	(o) 80	(p) 0.614

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	72.0	59.1	68.2	59.9	64.4	58.9	62.9	67.3	61.7	65.5	60.4	63.9	9.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.2	81.1	63.9	59.5	76.2	62.3	59.0	74.9	62.0	28.6	67.6	27.5	65.4	26.7	63.8	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
28.6	24.7	20.7	DB	26.1	87.6	4.1	5.0	23.1	91.2	20.8	94.1	18.5	96.9	15.5	100.6	
			WB	24.4	66.0	4.3	2.3	21.3	67.7	18.8	69.0	16.3	70.3	13.2	72.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	46.0	45.6	46.6	48.1	51.7	55.0	57.3	57.6	56.6	53.2	48.8	44.8
	DBStd	6.35	5.19	5.05	4.30	4.15	4.03	3.16	3.01	3.26	3.98	4.42	4.97	5.42
	HDD50	775	141	136	123	80	23	1	0	0	1	18	78	174
	HDD65	5126	588	543	571	507	416	301	238	231	255	366	485	625
	CDD50	1133	18	12	17	25	74	151	227	236	199	117	43	14
	CDD65	9	0	0	0	1	2	1	0	2	2	1	0	0
	CDH74	133	0	0	0	13	33	16	2	23	42	4	0	0
	CDH80	41	0	0	0	3	11	5	0	8	14	0	0	0
(14) Wind	WSAvg	8.4	10.5	9.0	9.6	8.5	7.5	7.5	7.8	6.5	6.3	7.6	9.5	10.4
(15) Precipitation	PrecAvg	68.2	10.7	7.8	7.3	4.8	3.3	2.6	0.9	1.1	2.2	5.2	10.4	11.7
	PrecMax	102.9	21.3	16.8	13.1	9.6	7.2	6.2	3.2	7.0	6.3	10.6	20.3	22.4
	PrecMin	46.3	0.7	1.6	1.2	1.1	0.4	0.4	0.0	0.0	0.0	0.1	1.9	2.8
	PrecStd	13.1	4.7	3.9	3.1	2.0	1.6	1.6	0.7	1.3	1.7	2.7	4.6	5.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.2	63.4	64.0	72.4	79.2	72.6	70.4	75.1	80.7	72.6	64.1	59.5
		MCWB	52.3	51.1	52.5	56.6	58.9	60.9	63.1	60.0	59.3	56.9	55.5	52.7
	2%	DB	57.1	58.6	58.6	63.0	63.5	64.1	67.9	68.3	70.3	66.0	60.8	55.4
		MCWB	51.7	49.4	51.3	52.7	55.3	58.6	61.4	62.1	60.1	56.8	54.9	52.5
	5%	DB	54.5	54.5	54.8	56.8	60.5	63.0	64.3	65.7	65.9	62.9	57.4	54.3
		MCWB	51.2	50.1	50.5	51.3	55.3	57.5	59.5	61.0	60.1	56.2	53.0	52.1
	10%	DB	53.7	52.5	53.9	54.4	58.5	61.2	63.5	63.7	63.4	60.6	55.1	52.4
		MCWB	51.2	49.3	50.3	50.5	54.1	56.6	58.4	58.9	58.4	56.0	52.6	50.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.7	54.5	55.5	58.2	60.2	62.8	64.1	64.5	63.9	62.7	58.9	56.0
		MCDB	57.3	57.7	61.1	70.5	72.9	70.1	69.2	69.5	68.7	65.1	61.1	58.0
	2%	WB	54.1	52.9	53.5	54.3	57.2	60.0	62.2	62.8	62.3	59.8	56.5	54.2
		MCDB	55.1	54.9	55.6	59.3	62.3	64.3	65.9	66.8	66.1	62.7	59.1	55.3
	5%	WB	52.8	51.3	52.0	52.5	55.7	58.3	60.8	61.3	60.9	58.1	54.8	52.9
		MCDB	53.8	53.5	54.0	55.6	60.0	62.3	64.0	64.5	64.6	61.4	56.5	53.8
	10%	WB	51.1	49.9	50.6	51.3	54.4	57.2	59.5	60.0	59.5	56.4	53.8	50.9
		MCDB	52.5	52.0	52.5	53.8	57.5	61.1	62.8	63.1	62.7	59.5	55.1	51.9
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	11.9	12.1	12.7	12.0	11.7	12.4	13.2	14.4	13.4	11.4	10.3
		MCDBR	12.7	16.0	15.4	18.0	16.1	13.8	14.0	16.4	19.9	17.4	13.7	10.9
		MCWBR	8.6	10.4	10.7	11.3	10.4	9.3	9.4	10.4	11.2	10.4	9.5	8.1
	5% WB	MCDBR	9.1	12.0	13.0	14.5	14.3	12.9	13.2	14.7	15.4	13.0	10.5	8.1
		MCWBR	7.4	9.0	9.9	10.2	9.7	8.8	9.1	9.9	10.1	8.9	8.1	7.3
(40) Clear-Sky Solar Irradiance	taub		0.324	0.322	0.334	0.368	0.375	0.360	0.347	0.354	0.346	0.335	0.330	0.330
	taud		2.531	2.552	2.531	2.396	2.406	2.462	2.518	2.512	2.528	2.559	2.528	2.474
	Ebn at Noon		254	277	287	284	284	288	291	285	279	268	249	236
	Edh at Noon		22	25	29	36	36	35	32	31	29	24	21	21
(44) All-Sky Solar Radiation	RadAvg		420	682	1012	1450	1806	1964	2126	1799	1411	855	479	345
(45)	RadStd		60	75	113	107	149	147	141	139	111	90	61	48

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+31

Nomenclature: See separate page