

NEWPORT MUNICIPAL, OR, USA

WMO: 726950

Lat: 44.583N

Lon: 124.050W

Elev: 37

StdP: 100.88

Time Zone: -8.00 (NAP)

Period: 02-19

WBAN: 24285

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-0.9	0.2	-7.7	2.0	2.6	-4.7	2.5	3.6	16.4	11.1	15.0	10.6	3.7	80	0.614

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	22.2	15.1	20.1	15.5	18.0	14.9	17.2	19.6	16.5	18.6	15.8	17.7	4.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	11.6	17.7	15.3	10.9	16.8	15.0	10.7	16.7	48.6	19.8	46.0	18.5	44.2	17.6	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	11.0	9.2	DB	-3.3	30.9	2.3	2.8	-4.9	32.9	-6.2	34.5	-7.5	36.1	-9.1	38.1	(4)
(5)			WB	-4.2	18.9	2.4	1.3	-6.0	19.8	-7.4	20.6	-8.7	21.3	-10.4	22.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	7.8	7.6	8.1	9.0	10.9	12.8	14.1	14.2	13.7	11.8	9.4	7.1		
	DBStd	3.53	2.88	2.81	2.39	2.30	2.24	1.76	1.67	1.81	2.21	2.46	2.76	3.01		
	HDD10.0	431	78	76	68	44	13	1	0	0	1	10	43	97		
	HDD18.3	2848	327	302	317	282	231	167	132	128	142	203	269	347		
	CDD10.0	629	10	7	9	14	41	84	126	131	111	65	24	8		
	CDD18.3	5	0	0	0	1	1	1	0	1	1	1	0	0		
	CDH23.3	74	0	0	0	7	18	9	1	13	23	2	0	0		
	CDH26.7	23	0	0	0	2	6	3	0	4	8	0	0	0		
(14) Wind	WSAvg	3.8	4.7	4.0	4.3	3.8	3.4	3.3	3.5	2.9	2.8	3.4	4.2	4.7		
(15) Precipitation	PrecAvg	1733	272	198	186	122	85	65	22	29	57	131	264	296		
	PrecMax	2613	540	427	332	243	183	158	82	177	159	269	516	570		
	PrecMin	1175	17	40	31	27	9	10	0	1	1	3	48	70		
	PrecStd	332	120	98	79	52	41	40	19	32	42	69	116	128		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.2	17.4	17.8	22.4	26.2	22.5	21.4	23.9	27.0	22.6	17.8	15.3		
		MCWB	11.3	10.6	11.4	13.7	14.9	16.0	17.3	15.6	15.2	13.8	13.1	11.5		
	2%	DB	14.0	14.8	14.8	17.2	17.5	17.8	19.9	20.2	21.3	18.9	16.0	13.0		
		MCWB	11.0	9.6	10.7	11.5	13.0	14.8	16.3	16.7	15.6	13.8	12.7	11.4		
	5%	DB	12.5	12.5	12.7	13.8	15.8	17.2	18.0	18.7	18.8	17.2	14.1	12.4		
		MCWB	10.7	10.0	10.3	10.7	13.0	14.1	15.3	16.1	15.6	13.5	11.6	11.2		
	10%	DB	12.1	11.4	12.2	12.5	14.7	16.2	17.5	17.6	17.5	15.9	12.8	11.3		
		MCWB	10.7	9.6	10.2	10.3	12.3	13.6	14.7	14.9	14.7	13.3	11.5	10.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	12.5	13.1	14.5	15.7	17.1	17.9	18.0	17.7	17.1	14.9	13.4		
		MCDB	14.0	14.3	16.1	21.4	22.7	21.2	20.7	20.9	20.4	18.4	16.2	14.4		
	2%	WB	12.3	11.6	11.9	12.4	14.0	15.6	16.8	17.1	16.8	15.5	13.6	12.3		
		MCDB	12.8	12.7	13.1	15.2	16.8	17.9	18.8	19.3	19.0	17.0	15.1	12.9		
	5%	WB	11.6	10.7	11.1	11.4	13.2	14.6	16.0	16.3	16.0	14.5	12.7	11.6		
		MCDB	12.1	11.9	12.2	13.1	15.6	16.8	17.8	18.1	18.1	16.3	13.6	12.1		
	10%	WB	10.6	10.0	10.4	10.7	12.4	14.0	15.3	15.6	15.3	13.5	12.1	10.5		
		MCDB	11.4	11.1	11.4	12.1	14.2	16.2	17.1	17.3	17.0	15.3	12.9	11.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	6.6	6.7	7.0	6.7	6.5	6.9	7.3	8.0	7.5	6.3	5.7		
		MCDBR	7.1	8.9	8.6	10.0	8.9	7.7	7.8	9.1	11.1	9.7	7.6	6.0		
	5% WB	MCWBR	4.8	5.8	5.9	6.3	5.8	5.2	5.2	5.8	6.2	5.8	5.3	4.5		
		MCWBR	5.1	6.7	7.2	8.0	7.9	7.1	7.3	8.1	8.6	7.2	5.8	4.5		
(40) Clear-Sky Solar Irradiance	taub	taub	0.324	0.322	0.334	0.368	0.375	0.360	0.347	0.354	0.346	0.335	0.330	0.330		
		taud	2.531	2.552	2.531	2.396	2.406	2.462	2.518	2.512	2.528	2.559	2.528	2.474		
	Ebn at Noon	Ebn at Noon	800	873	906	895	895	908	916	899	880	845	784	745		
		Edh at Noon	68	78	90	112	114	109	102	99	90	77	67	65		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.32	2.15	3.19	4.57	5.69	6.19	6.70	5.67	4.45	2.70	1.51	1.09		
	RadStd	RadStd	0.19	0.24	0.36	0.34	0.47	0.46	0.44	0.44	0.35	0.28	0.19	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+17

Nomenclature: See separate page