

COOS BAY 8 SW, OR, USA

WMO: 726951

Lat: 43.2718N

Lon: 124.3186W

Elev: 12

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 04141

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	26.6	28.7	24.7	18.8	28.1	27.4	21.3	29.6	10.7	56.2	9.6	55.7	0.3	N/A	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.6	(c) 71.6	(d) 61.4	(e) 68.7	(f) 60.4	(g) 66.4	(h) 59.3	(i) 63.0	(j) 69.3	(k) 61.6	(l) 67.2	(m) 60.3	(n) 65.2	(o) 4.6	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.4	78.3	65.3	59.1	75.0	64.0	58.0	72.0	62.7	28.4	69.4	27.5	67.2	26.6	65.3	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.0	(b) 10.0	(c) 8.7	(e) 22.8	(f) 81.9	(g) 4.5	(h) 7.0	(i) 19.6	(j) 86.9	(k) 17.0	(l) 91.0	(m) 14.5	(n) 94.9	(o) 11.2	(p) 99.9		
(a) 11.0	(b) 10.0	(c) 8.7	(e) 23.4	(f) 67.1	(g) 3.0	(h) 3.1	(i) 21.2	(j) 69.3	(k) 19.5	(l) 71.1	(m) 17.8	(n) 72.9	(o) 15.7	(p) 75.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	44.5	45.1	46.3	48.2	51.8	54.9	57.2	58.3	56.6	52.5	47.7	43.1
	DBStd	6.74	4.98	4.96	4.55	4.11	3.63	3.10	2.78	3.04	3.83	4.57	5.30	6.06
	HDD50	928	181	150	132	81	22	1	0	0	1	26	105	229
	HDD65	5276	636	558	579	503	409	303	242	209	252	388	518	679
	CDD50	1128	10	12	18	28	79	148	223	256	199	103	36	16
	CDD65	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH74	70	0	0	0	14	13	6	0	8	24	5	0	0
	CDH80	15	0	0	0	5	2	0	0	0	8	0	0	0
	WSAvg	2.9	2.0	2.3	2.8	3.0	3.3	3.9	4.8	3.8	3.0	2.4	2.0	1.9
	PrecAvg	59.1	9.1	7.0	7.4	5.2	3.1	1.7	0.4	0.5	1.2	4.3	8.4	10.7
(15) Precipitation	PrecMax	99.3	20.0	14.6	13.0	10.7	8.3	4.3	2.1	2.1	5.3	13.7	18.6	21.4
	PrecMin	32.3	2.2	2.8	3.0	2.8	0.1	0.2	0.0	0.0	0.0	0.4	2.6	2.9
	PrecStd	13.9	5.2	3.3	2.9	2.3	2.0	1.0	0.4	0.5	1.4	2.9	4.1	4.9
	PrecStd	13.9	5.2	3.3	2.9	2.3	2.0	1.0	0.4	0.5	1.4	2.9	4.1	4.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	61.2	62.5	64.9	72.3	74.1	72.5	69.7	74.3	75.9	72.4	65.0	60.7	55.8
	0.4% MCWB	53.7	54.4	54.7	57.8	58.8	62.5	61.9	63.2	61.7	59.7	58.8	55.8	51.4
	2% DB	57.2	58.7	59.8	62.1	63.8	66.0	67.0	70.4	70.6	67.2	61.1	57.9	53.4
	2% MCWB	53.0	53.4	52.7	53.8	56.4	59.2	59.7	62.0	61.5	58.8	55.7	51.4	47.0
	5% DB	55.3	56.1	57.2	58.4	60.4	63.6	65.3	67.6	67.9	63.4	59.1	55.7	51.4
	5% MCWB	52.3	52.1	51.8	51.9	54.2	57.6	59.0	60.6	60.0	57.6	55.1	51.4	47.0
	10% DB	53.5	53.6	55.1	56.1	58.6	61.5	63.5	65.3	65.3	61.3	57.1	53.4	49.0
	10% MCWB	51.0	50.6	50.9	50.8	53.2	56.0	58.3	59.4	59.1	56.6	53.9	51.3	47.0
	0.4% WB	56.3	57.2	56.4	60.0	60.0	63.6	62.7	65.1	65.2	62.9	60.1	57.4	53.4
	0.4% MCDB	58.8	60.4	61.2	71.7	71.3	71.3	68.4	71.6	73.9	68.6	63.6	59.6	55.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	54.2	54.8	54.4	55.3	56.8	60.3	60.6	62.8	62.4	60.4	57.4	55.3	51.4
	2% MCDB	56.5	57.6	58.2	60.8	63.2	65.4	65.6	68.9	68.3	64.3	59.7	57.4	53.4
	5% WB	52.8	52.7	52.9	53.2	55.0	58.3	59.5	61.4	61.2	59.0	55.8	53.4	49.0
	5% MCDB	55.1	55.2	56.4	56.8	59.5	62.3	63.9	66.7	66.4	62.2	58.2	55.4	51.4
	10% WB	51.2	50.9	51.4	51.7	53.8	57.0	58.6	59.9	59.8	57.3	53.9	51.4	47.0
	10% MCDB	53.5	53.2	54.8	55.1	57.7	60.6	62.8	64.4	64.1	60.6	56.3	53.7	49.0
(35) Mean Daily Temperature Range	MDBR	16.0	15.2	16.3	16.4	14.2	13.8	11.5	13.6	17.9	18.7	16.2	14.2	11.4
	5% DB MCDBR	18.5	19.8	19.7	21.7	18.3	17.8	14.7	18.9	22.9	22.2	17.8	12.1	8.8
	5% DB MCWBR	13.9	13.8	13.5	13.8	11.5	12.0	9.0	11.7	14.2	14.8	13.3	8.8	5.4
	5% WB MCDBR	16.3	15.7	17.2	18.3	16.3	15.7	13.5	17.6	20.0	17.2	15.0	10.6	6.8
	5% WB MCWBR	13.1	12.0	12.5	12.5	10.6	10.5	8.5	11.2	13.2	12.2	11.8	8.3	4.9
	5% WB MCWBR	13.1	12.0	12.5	12.5	10.6	10.5	8.5	11.2	13.2	12.2	11.8	8.3	4.9
(40) Clear-Sky Solar Irradiance	taub	0.321	0.322	0.330	0.360	0.367	0.355	0.348	0.352	0.343	0.333	0.323	0.327	0.327
	taud	2.554	2.561	2.555	2.421	2.443	2.485	2.519	2.524	2.534	2.568	2.570	2.519	2.519
	Ebn at Noon	260	280	291	287	287	290	291	287	282	272	257	245	245
	Edh at Noon	22	25	28	35	35	34	32	31	29	24	21	21	21
(44) All-Sky Solar Radiation	RadAvg	482	739	1087	1540	1925	2108	2235	1881	1499	940	541	394	251
	RadStd	69	87	119	114	124	135	113	128	96	85	67	65	65

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+9

Nomenclature: See separate page