

COOS BAY 8 SW, OR, USA

WMO: 726951

Lat: 43.2718N

Lon: 124.3186W

Elev: 4

StdP: 101.28

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 04141

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.0	-1.9	-4.1	2.7	-2.2	-2.6	3.0	-1.3	4.8	13.5	4.3	13.2	0.1	N/A	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	22.0	16.3	20.4	15.8	19.1	15.2	17.2	20.7	16.4	19.6	15.7	18.4	2.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.8	11.2	18.5	15.1	10.7	17.8	14.5	10.3	17.1	48.3	20.8	46.0	19.5	44.0	18.5	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.9	4.5	3.9	DB	-5.1	27.7	2.5	3.9	-6.9	30.5	-8.3	32.8	-9.7	34.9	-11.5	37.7	(4)
(5)			WB	-4.8	19.5	1.6	1.7	-6.0	20.7	-7.0	21.7	-7.9	22.7	-9.1	24.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	6.9	7.3	8.0	9.0	11.0	12.7	14.0	14.6	13.7	11.4	8.7	6.2
	DBStd	3.75	2.76	2.76	2.53	2.28	2.02	1.72	1.55	1.69	2.13	2.54	2.94	3.37
	HDD10.0	516	101	83	73	45	12	1	0	0	1	14	58	127
	HDD18.3	2931	353	310	322	279	227	168	134	116	140	216	288	377
	CDD10.0	627	6	7	10	16	44	82	124	142	111	57	20	9
	CDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH23.3	39	0	0	0	8	7	3	0	4	13	3	0	0
	CDH26.7	8	0	0	0	3	1	0	0	0	4	0	0	0
Wind	WSAvg	1.3	0.9	1.0	1.3	1.3	1.5	1.7	2.1	1.7	1.4	1.1	0.9	0.9
Precipitation	PrecAvg	1500	232	178	189	132	80	42	9	12	31	110	213	273
	PrecMax	2523	507	372	329	272	210	108	53	53	135	347	472	543
	PrecMin	820	57	72	76	70	3	4	0	0	1	9	67	73
	PrecStd	354	133	83	73	59	51	25	11	13	35	73	105	124
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.2	16.9	18.3	22.4	23.4	22.5	21.0	23.5	24.4	22.5	18.4	15.9
		MCWB	12.0	12.4	12.6	14.3	14.9	17.0	16.6	17.4	16.5	15.4	14.9	13.2
	2%	DB	14.0	14.8	15.4	16.7	17.7	18.9	19.5	21.4	21.4	19.6	16.2	14.4
		MCWB	11.6	11.9	11.5	12.1	13.6	15.1	15.4	16.7	16.4	14.9	13.2	12.4
	5%	DB	12.9	13.4	14.0	14.7	15.8	17.6	18.5	19.8	19.9	17.4	15.0	13.2
		MCWB	11.3	11.1	11.0	11.0	12.3	14.2	15.0	15.9	15.6	14.2	12.8	11.8
	10%	DB	11.9	12.0	12.8	13.4	14.8	16.4	17.5	18.5	18.5	16.3	13.9	11.9
		MCWB	10.5	10.3	10.5	10.4	11.8	13.3	14.6	15.2	15.0	13.7	12.2	10.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.5	14.0	13.6	15.6	15.5	17.6	17.1	18.4	18.4	17.2	15.6	14.1
		MCDB	14.9	15.8	16.2	22.0	21.8	21.9	20.2	22.0	23.3	20.3	17.5	15.3
	2%	WB	12.4	12.6	12.5	12.9	13.8	15.7	15.9	17.1	16.9	15.8	14.1	12.9
		MCDB	13.6	14.2	14.6	16.0	17.3	18.5	18.7	20.5	20.2	17.9	15.4	14.1
	5%	WB	11.5	11.5	11.6	11.8	12.8	14.6	15.3	16.3	16.2	15.0	13.2	11.9
		MCDB	12.8	12.9	13.5	13.8	15.3	16.8	17.7	19.3	19.1	16.8	14.5	13.0
	10%	WB	10.7	10.5	10.8	10.9	12.1	13.9	14.8	15.5	15.4	14.0	12.2	10.8
		MCDB	12.0	11.8	12.6	12.8	14.3	15.9	17.1	18.0	17.9	15.9	13.5	12.1
Mean Daily Temperature Range	5% DB	MDBR	8.9	8.4	9.1	9.1	7.9	7.7	6.4	7.6	9.9	10.4	9.0	7.9
		MCDBR	10.3	11.0	11.0	12.1	10.2	9.9	8.2	10.5	12.7	12.3	9.9	6.7
		MCWBR	7.7	7.7	7.5	7.7	6.4	6.7	5.0	6.5	7.9	8.2	7.4	4.9
	5% WB	MCDBR	9.0	8.7	9.5	10.2	9.0	8.7	7.5	9.8	11.1	9.6	8.3	5.9
		MCWBR	7.3	6.7	6.9	6.9	5.9	5.9	4.7	6.2	7.3	6.8	6.6	4.6
Clear-Sky Solar Irradiance	taub	0.321	0.322	0.330	0.360	0.367	0.355	0.348	0.352	0.343	0.333	0.323	0.327	
	taud	2.554	2.561	2.555	2.421	2.443	2.485	2.519	2.524	2.534	2.568	2.570	2.519	
	Ebn at Noon	819	883	917	906	906	915	917	904	889	856	810	771	
	Edh at Noon	68	79	89	110	111	107	102	98	90	77	67	65	
All-Sky Solar Radiation	RadAvg	1.52	2.33	3.43	4.86	6.07	6.65	7.04	5.93	4.73	2.96	1.71	1.24	
	RadStd	0.22	0.27	0.38	0.36	0.39	0.43	0.36	0.40	0.30	0.27	0.21	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+5

Nomenclature: See separate page