

JOHN DAY 35 WNW, OR, USA

WMO: 726970

Lat: 44.5560N

Lon: 119.6459W

Elev: 2245

StdP: 13.54

Time Zone: -8.00 (NAP)

Period: 04-19

WBAN: 04125

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.1	16.1	3.3	7.1	15.9	8.0	9.0	20.0	12.8	47.8	11.3	44.4	3.6	N/A	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.9	98.6	61.8	95.7	61.3	92.5	60.3	64.4	89.6	63.0	89.0	61.8	88.4	5.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.9	75.1	69.5	54.5	68.6	66.8	51.8	62.1	67.2	30.6	89.1	29.5	89.1	28.6	88.8	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.7	9.1	8.5	3.5	104.4	6.0	3.2	-0.8	106.8	-4.3	108.7	-7.7	110.5	-12.0	112.8
			1.2	67.4	7.2	2.0	-3.9	68.8	-8.1	70.0	-12.2	71.1	-17.4	72.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.0	36.5	39.2	44.8	49.7	58.0	65.0	74.6	72.9	64.4	52.5	42.2	34.8	(6)
	DBStd	15.38	8.72	8.00	6.83	6.84	7.48	7.15	5.80	6.13	7.49	7.14	8.84	9.42	(7)
	HDD50	1802	419	307	187	87	13	0	0	0	2	55	258	474	(8)
	HDD65	5138	882	721	626	459	242	85	4	9	100	391	684	935	(9)
	CDD50	2894	2	6	26	79	262	450	762	709	435	133	25	5	(10)
	CDD65	754	0	0	0	1	26	84	301	254	84	4	0	0	(11)
	CDH74	12132	0	0	2	81	507	1546	4740	3814	1351	90	1	0	(12)
	CDH80	6176	0	0	0	16	172	672	2672	2038	586	20	0	0	(13)
(14) Wind	WSAvg	4.1	4.4	4.2	4.5	4.2	3.9	3.9	4.1	3.9	3.7	3.8	3.9	4.0	(14)
(15) Precipitation	PrecAvg	13.6	1.6	1.0	1.2	1.4	1.6	1.3	0.6	0.5	0.5	1.1	1.5	1.5	(15)
	PrecMax	18.8	3.2	2.0	2.1	2.4	3.9	2.2	2.1	1.3	1.0	1.8	2.7	3.3	(16)
	PrecMin	9.6	0.4	0.4	0.5	0.6	0.3	0.1	0.1	0.0	0.1	0.4	0.4	0.7	(17)
	PrecStd	2.6	0.7	0.4	0.5	0.5	1.0	0.6	0.5	0.4	0.3	0.4	0.7	0.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.3	63.7	71.2	82.3	90.8	98.8	102.7	102.0	96.3	82.4	69.3	59.9	(19)
		MCWB	46.4	47.4	51.4	55.6	59.7	65.4	63.2	62.4	60.2	55.8	52.2	47.9	(20)
	2%	DB	55.1	59.1	65.5	75.5	85.0	92.6	99.2	98.2	91.4	75.5	64.0	55.9	(21)
		MCWB	43.7	46.6	49.3	53.1	57.7	62.2	61.4	61.4	59.4	53.0	50.4	45.8	(22)
	5%	DB	51.9	55.3	61.5	69.5	79.6	87.4	96.5	94.6	87.0	70.3	59.4	52.3	(23)
		MCWB	42.5	44.7	47.5	50.5	56.0	59.3	61.3	60.7	58.8	51.5	47.5	43.2	(24)
	10%	DB	49.1	51.8	57.8	63.9	74.7	83.1	93.4	91.1	82.2	65.7	55.6	48.8	(25)
		MCWB	41.1	42.5	45.8	48.5	54.1	57.3	60.4	60.0	56.7	49.9	44.9	41.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	49.9	53.2	57.4	61.9	67.5	66.9	64.9	63.9	57.9	54.1	49.8	(27)
		MCDB	57.3	62.1	65.5	77.7	83.2	92.3	91.8	90.2	85.2	76.6	66.6	58.9	(28)
	2%	WB	44.8	48.0	50.7	54.9	59.5	64.5	64.3	63.4	61.8	55.2	51.4	47.2	(29)
		MCDB	53.6	59.2	61.6	74.2	78.1	88.1	90.5	90.6	86.0	69.7	61.9	55.9	(30)
	5%	WB	42.7	45.9	48.9	52.1	57.9	61.7	62.9	62.2	59.9	53.3	48.5	43.9	(31)
		MCDB	50.6	56.1	60.0	67.9	75.2	85.3	90.2	89.6	84.8	66.8	58.4	51.7	(32)
	10%	WB	41.1	43.8	46.8	49.9	56.1	59.5	61.8	61.1	57.9	51.3	46.1	41.2	(33)
		MCDB	47.9	52.5	57.7	62.6	72.0	80.2	89.9	88.2	80.2	63.6	54.7	48.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.3	18.0	20.6	23.1	25.4	28.2	33.9	33.1	30.2	23.7	17.7	14.6	(35)
		MCDBR	18.6	22.3	27.1	33.2	34.3	36.4	37.3	37.8	37.3	30.9	21.5	16.3	(36)
		MCWBR	11.5	12.2	13.8	15.3	13.2	13.1	13.0	12.8	14.1	14.1	11.0	9.5	(37)
	5% WB	MCDBR	18.3	20.5	23.6	30.0	29.0	33.6	33.5	34.0	34.1	26.6	19.7	15.1	(38)
		MCWBR	11.0	11.7	12.6	14.1	11.5	12.0	11.7	11.2	13.0	12.9	10.4	9.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.290	0.299	0.309	0.349	0.359	0.347	0.352	0.357	0.336	0.318	0.298	0.291	(40)
	taud		2.515	2.527	2.519	2.391	2.392	2.459	2.460	2.439	2.476	2.532	2.534	2.505	(41)
	Ebn at Noon		267	285	296	290	289	292	289	284	282	274	262	254	(42)
	Edh at Noon		21	25	29	36	37	35	34	34	30	25	21	20	(43)
(44) All-Sky Solar Radiation	RadAvg		495	771	1151	1621	1947	2285	2468	2104	1586	993	562	390	(44)
	RadStd		56	88	109	137	160	121	91	122	97	79	47	55	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page