

LIMESTONE 4 NNW, ME, USA

WMO: 727100

Lat: 46.9601N

Lon: 67.8833W

Elev: 225

StdP: 98.66

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 94645

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.5	-23.7	-29.3	0.3	-25.1	-27.0	0.3	-22.5	7.9	-4.6	6.5	-6.7	0.9	N/A	0.539

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	28.1	19.6	26.4	18.7	24.8	18.0	21.3	25.5	20.3	24.3	19.5	23.4	2.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	15.0	22.9	19.0	14.1	22.3	18.0	13.3	21.5	62.7	25.5	59.3	24.4	56.5	23.2	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.7	4.8	4.0	DB	-31.2	31.2	3.0	1.4	-33.4	32.1	-35.1	33.0	-36.8	33.7	-39.0	34.7	(4)
(5)			WB	-30.6	22.8	2.3	0.6	-32.2	23.3	-33.6	23.6	-34.8	23.9	-36.5	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.0	-12.1	-10.7	-5.1	2.7	10.2	15.0	18.4	17.3	12.9	6.3	-0.6	-7.9	(6)	
	DBStd	11.69	7.18	6.38	6.02	4.47	4.01	3.59	2.87	3.01	3.98	4.35	5.04	6.22	(7)	
	HDD10.0	3022	684	578	468	222	47	2	0	0	16	133	318	554	(8)	
	HDD18.3	5325	942	812	726	469	254	111	34	55	167	374	568	813	(9)	
	CDD10.0	821	0	0	1	3	53	154	261	228	103	17	1	0	(10)	
	CDD18.3	81	0	0	0	0	2	12	37	24	5	0	0	0	(11)	
	CDH23.3	681	0	0	0	1	45	127	288	172	46	2	0	0	(12)	
	CDH26.7	122	0	0	0	0	11	26	54	26	6	0	0	0	(13)	
(14) Wind	WSAvg	1.7	1.8	1.9	1.9	1.9	1.8	1.6	1.4	1.4	1.5	1.7	1.8	1.7	(14)	
(15) Precipitation	PrecAvg	1158	91	68	86	79	97	108	113	102	101	111	95	107	(15)	
	PrecMax	1480	156	128	169	133	154	212	186	179	208	212	199	189	(16)	
	PrecMin	784	36	23	33	33	32	62	37	44	40	33	40	32	(17)	
	PrecStd	150	32	24	32	26	31	37	40	38	42	48	37	37	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.3	6.1	11.9	20.2	28.0	29.6	30.2	29.2	27.3	22.4	15.4	8.5	(19)	
		MCWB	6.7	4.5	8.7	10.3	18.2	18.8	20.4	20.6	19.5	15.8	14.3	8.2	(20)	
	2%	DB	3.7	2.7	6.9	15.6	23.8	26.7	28.2	27.0	24.5	18.2	11.7	5.0	(21)	
		MCWB	2.8	0.5	3.5	9.6	14.6	17.4	19.8	19.5	18.9	14.4	9.5	4.2	(22)	
	5%	DB	1.3	0.8	4.8	12.6	20.7	24.4	26.4	25.2	22.2	15.7	9.0	2.7	(23)	
		MCWB	0.4	-0.6	1.9	7.7	12.7	16.8	19.2	18.6	17.0	13.0	7.1	1.8	(24)	
	10%	DB	-0.9	-0.7	3.0	10.0	18.2	22.3	24.8	23.6	20.3	13.6	6.9	0.8	(25)	
		MCWB	-1.9	-1.9	0.7	5.9	11.8	15.2	18.4	17.7	16.6	11.0	5.2	0.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	5.8	10.9	13.6	19.5	20.8	23.0	22.0	21.6	17.0	13.7	8.8	(27)	
		MCDB	7.2	6.6	15.7	16.3	26.0	25.4	27.9	27.1	26.7	18.8	14.7	9.1	(28)	
	2%	WB	3.1	1.5	5.1	10.4	16.7	19.3	21.5	20.8	20.0	15.5	9.9	5.1	(29)	
		MCDB	3.8	2.6	6.1	13.0	20.9	23.2	25.6	24.7	23.1	17.4	10.8	5.5	(30)	
	5%	WB	0.5	-0.1	2.2	8.1	14.9	17.9	20.6	19.9	18.8	13.7	7.0	2.6	(31)	
		MCDB	1.3	1.0	4.2	12.0	17.9	21.8	24.6	23.7	21.5	15.5	8.1	3.2	(32)	
	10%	WB	-1.8	-1.9	0.6	6.0	13.1	16.4	19.8	19.0	17.5	11.6	5.1	0.6	(33)	
		MCDB	-0.8	-0.7	2.5	8.9	17.1	20.2	23.9	22.4	20.6	13.6	6.7	1.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	10.5	10.3	10.0	11.3	10.9	10.8	10.9	11.3	9.2	7.5	8.5	(35)	
		MCDBR	9.7	10.0	11.2	15.1	16.2	14.2	12.8	12.9	13.6	13.1	10.3	8.5	(36)	
	5% WB	MCWBR	10.0	9.9	8.4	9.4	8.3	7.6	6.3	6.3	7.7	8.9	9.0	7.7	(37)	
		MCWBR	10.2	11.1	9.6	12.6	12.3	11.7	11.0	10.9	11.3	10.3	9.4	8.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.253	0.270	0.302	0.341	0.354	0.374	0.405	0.385	0.356	0.319	0.291	0.272	(40)	
		taud	2.353	2.287	2.287	2.375	2.413	2.355	2.291	2.347	2.418	2.524	2.524	2.385	(41)	
	Ebn at Noon	Ebn at Noon	852	905	922	914	910	889	854	858	854	844	805	780	(42)	
		Edh at Noon	70	94	110	112	112	120	126	115	97	75	61	62	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.40	2.29	3.47	4.44	5.01	5.44	5.43	4.77	3.76	2.25	1.28	0.98	(44)	
	RadStd	RadStd	0.17	0.26	0.24	0.40	0.52	0.38	0.46	0.30	0.28	0.20	0.15	0.09	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (25 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page