

CARIBOU, ME, USA

WMO: 727120

Lat: 46.871N

Lon: 68.017W

Elev: 190

StdP: 99.06

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14607

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.4	-22.7	-29.5	0.3	-24.1	-27.1	0.3	-22.0	11.7	-9.1	10.7	-8.8	2.4	260	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	29.2	20.3	27.4	19.4	25.8	18.5	21.9	26.6	20.9	25.1	20.0	24.0	4.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.4	15.4	23.8	19.4	14.5	23.0	18.5	13.7	22.2	64.9	26.8	61.4	25.1	58.1	24.0	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.5	7.6	-29.8	31.9	3.4	1.4	-32.3	32.9	-34.3	33.7	-36.2	34.5	-38.7	35.5		
(5)			-29.3	23.6	2.8	1.0	-31.3	24.3	-33.0	24.9	-34.5	25.4	-36.6	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-11.3	-9.8	-4.0	3.5	11.0	16.1	19.2	18.0	13.6	7.0	0.2	-6.8
	DBStd	11.61	6.95	6.33	5.78	4.26	4.06	3.72	2.93	3.09	4.03	4.27	5.03	6.04
	HDD10.0	2824	659	553	434	199	36	2	0	0	11	114	296	521
	HDD18.3	5051	918	786	692	446	230	87	24	43	149	352	544	779
	CDD10.0	932	0	0	1	3	67	185	286	249	119	20	1	0
	CDD18.3	118	0	0	0	0	2	21	52	34	9	0	0	0
	CDH23.3	1026	0	0	0	2	54	201	412	279	76	2	0	0
	CDH26.7	225	0	0	0	0	11	46	90	62	16	0	0	0
Wind	WSAvg	3.2	3.5	3.6	3.8	3.8	3.4	2.9	2.6	2.5	2.8	3.2	3.4	3.4
Precipitation	PrecAvg	973	67	55	65	68	83	88	105	97	87	88	87	86
	PrecMax	1380	144	120	134	157	145	229	202	307	224	222	207	202
	PrecMin	709	8	7	17	14	12	22	24	14	22	23	17	19
	PrecStd	153	30	23	27	28	31	41	39	50	39	44	39	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	7.5	12.6	20.4	28.1	30.5	31.2	30.8	28.8	22.8	16.0	8.6
		MCWB	7.2	5.0	7.0	11.1	16.9	20.9	21.2	21.0	21.0	15.8	14.7	7.4
	2%	DB	4.0	3.7	7.7	16.0	24.5	27.9	29.1	28.5	25.6	18.7	12.5	5.5
		MCWB	3.0	1.8	3.8	9.1	14.8	19.1	20.6	20.1	19.2	14.0	10.1	4.5
	5%	DB	1.6	1.8	5.5	13.0	21.6	25.7	27.3	26.3	22.9	16.3	9.7	3.1
		MCWB	0.5	0.3	2.5	7.6	13.5	18.1	19.7	19.0	17.4	13.0	7.6	1.9
	10%	DB	-0.9	0.1	3.8	10.4	19.0	23.5	25.7	24.5	20.9	14.0	7.5	1.5
		MCWB	-1.9	-1.1	1.3	6.0	12.3	16.7	18.8	18.2	16.7	11.0	5.8	0.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	5.7	8.5	13.7	19.1	22.6	23.6	22.6	22.2	17.5	14.9	7.9
		MCDB	7.9	6.9	10.5	18.2	25.0	28.3	28.0	27.9	27.5	20.3	16.0	8.5
	2%	WB	3.1	2.2	4.9	10.6	16.7	20.8	22.1	21.4	20.4	15.3	10.9	4.8
		MCDB	3.8	3.2	7.0	13.7	21.4	25.5	26.4	25.8	23.6	17.7	11.7	5.4
	5%	WB	0.5	0.5	3.0	8.4	14.9	19.6	21.0	20.4	18.9	13.4	7.9	2.2
		MCDB	1.4	1.5	5.0	12.5	19.3	23.9	25.3	24.4	21.9	15.9	9.2	2.9
	10%	WB	-1.8	-1.1	1.5	6.4	13.4	18.1	20.1	19.5	17.4	11.3	6.0	0.6
		MCDB	-0.9	0.1	3.5	9.9	18.2	21.7	24.1	23.1	20.3	13.6	7.5	1.4
Mean Daily Temperature Range	5% DB	MDBR	9.4	10.1	9.6	9.4	11.1	11.0	10.8	11.2	11.0	9.0	7.2	7.9
		MCDBR	11.2	9.2	11.0	14.7	15.8	14.2	12.9	13.6	13.5	12.7	10.1	8.5
		MCWBR	10.3	8.1	8.1	9.2	8.1	7.1	6.1	6.5	7.8	8.4	8.4	8.2
	5% WB	MCDBR	10.6	8.6	9.5	12.8	12.9	11.7	10.9	10.9	11.3	11.0	9.1	8.4
		MCWBR	10.5	8.1	7.7	9.0	7.7	6.9	6.0	6.1	7.3	8.4	8.5	8.4
Clear-Sky Solar Irradiance	taub	0.253	0.270	0.304	0.342	0.357	0.378	0.407	0.387	0.358	0.320	0.293	0.272	
	taud	2.359	2.296	2.294	2.379	2.409	2.348	2.289	2.344	2.415	2.523	2.522	2.394	
	Ebn at Noon	854	906	921	914	908	886	853	857	853	843	803	783	
	Edh at Noon	70	93	110	112	113	121	127	115	98	76	62	62	
All-Sky Solar Radiation	RadAvg	1.40	2.29	3.48	4.45	5.02	5.44	5.44	4.78	3.77	2.26	1.28	0.98	
	RadStd	0.17	0.26	0.24	0.40	0.53	0.37	0.47	0.30	0.28	0.20	0.15	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74	N/A
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page