

LIMESTONE LORING, ME, USA

WMO: 727125

Lat: 46.950N

Lon: 67.883W

Elev: 745

StdP: 14.30

Time Zone: -5.00 (NAE)

Period: 86-94

WBAN: 14623

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.6	-10.6	-22.3	1.7	-11.9	-19.2	2.0	-7.9	28.6	16.2	26.0	10.9	8.1	320	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	84.2	68.1	81.0	66.6	77.9	64.6	71.3	79.8	69.3	76.9	67.5	74.0	8.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.8	108.7	75.1	66.7	101.0	72.8	64.9	94.6	71.1	35.6	79.6	33.8	76.9	32.2	74.0	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.1	20.2	18.2	-19.7	91.3	2.4	2.1	-21.5	92.8	-22.9	94.0	-24.3	95.2	-26.0	96.8		
(5)			-19.9	74.9	2.4	2.4	-21.7	76.7	-23.1	78.1	-24.5	79.4	-26.3	81.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.2	10.5	11.3	23.8	38.9	52.6	60.1	65.1	64.4	54.0	42.6	29.8	15.9		
	DBStd	21.48	12.46	10.24	10.89	7.27	7.79	6.82	6.20	6.37	7.12	7.23	8.79	11.60		
	HDD50	5485	1225	1082	811	344	61	5	0	0	39	255	606	1057		
	HDD65	9595	1690	1502	1276	783	390	179	77	87	338	696	1055	1522		
	CDD50	1560	0	0	0	11	142	308	467	448	158	24	2	0		
	CDD65	193	0	0	0	0	6	32	79	70	6	0	0	0		
	CDH74	1649	0	0	0	8	112	312	671	501	45	0	0	0		
	CDH80	383	0	0	0	1	31	61	173	113	4	0	0	0		
(14) Wind	WSAvg	7.8	8.7	8.3	9.0	7.9	8.0	7.4	6.1	6.1	7.1	7.9	8.5	8.4		
(15) Precipitation	PrecAvg	45.6	3.6	2.7	3.4	3.1	3.8	4.3	4.4	4.0	4.0	4.4	3.7	4.2		
	PrecMax	58.3	6.1	5.0	6.7	5.2	6.1	8.3	7.3	7.0	8.2	8.3	7.8	7.4		
	PrecMin	30.9	1.4	0.9	1.3	1.3	1.3	2.4	1.5	1.7	1.6	1.3	1.6	1.3		
	PrecStd	5.9	1.3	0.9	1.3	1.0	1.2	1.5	1.6	1.5	1.7	1.9	1.5	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	46.0	56.5	70.3	84.6	85.4	89.4	87.6	78.8	67.3	57.3	43.4		
		MCWB	42.1	40.4	45.7	55.4	63.7	66.8	71.6	71.7	67.0	62.5	54.5	40.7		
	2%	DB	37.1	37.4	48.7	62.1	76.4	81.3	84.4	83.3	74.3	63.2	49.9	37.8		
		MCWB	35.5	33.6	42.1	50.2	58.6	63.9	69.5	67.8	64.2	58.4	48.2	36.0		
	5%	DB	34.6	32.3	42.6	56.2	72.4	77.7	81.0	79.7	70.4	58.9	46.2	34.7		
		MCWB	32.9	29.4	38.3	46.6	56.4	62.9	67.5	67.2	62.2	54.1	43.8	33.3		
	10%	DB	30.7	27.6	39.6	51.4	67.9	73.4	77.6	76.0	66.6	55.1	42.2	32.3		
		MCWB	28.5	25.3	35.6	43.0	54.6	60.8	64.9	65.5	59.7	51.1	39.2	30.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	41.3	47.3	59.4	65.5	70.5	75.0	73.5	70.4	64.7	54.9	42.2		
		MCDB	42.8	45.8	54.1	68.0	76.8	78.4	82.2	81.2	74.3	65.9	56.7	42.6		
	2%	WB	36.1	33.8	42.4	54.0	62.1	67.6	72.1	70.9	67.1	59.2	48.6	36.5		
		MCDB	36.7	37.0	47.0	58.7	74.2	75.5	82.3	77.9	72.0	61.7	49.9	37.6		
	5%	WB	32.9	29.8	39.2	48.3	59.1	65.2	69.6	69.1	64.2	55.0	44.4	33.6		
		MCDB	34.4	32.0	42.9	54.1	67.6	73.4	78.4	76.3	68.4	58.0	45.8	34.3		
	10%	WB	28.4	25.2	35.4	44.1	56.3	62.9	67.4	67.4	61.0	51.4	39.3	31.1		
		MCDB	30.8	27.7	38.4	49.8	64.4	71.2	74.0	74.0	65.5	54.2	41.5	32.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.5	17.9	17.8	16.5	20.8	19.3	18.4	17.9	17.6	14.9	12.3	14.6		
		MCDBR	19.4	19.9	20.1	26.6	28.2	25.6	23.6	22.7	23.2	18.8	15.1	15.0		
	5% WB	MCWBR	19.2	17.2	16.0	16.7	14.7	13.1	11.5	11.2	14.1	14.2	15.6	14.5		
		MCWBR	20.0	19.7	19.6	22.9	23.1	20.8	20.5	19.1	20.3	17.3	14.8	14.7		
(40) Clear-Sky Solar Irradiance	taub	taub	0.253	0.270	0.302	0.341	0.354	0.375	0.405	0.385	0.356	0.319	0.291	0.272		
		taud	2.353	2.288	2.288	2.376	2.413	2.355	2.291	2.347	2.418	2.525	2.524	2.386		
	Ebn at Noon	Ebn at Noon	270	287	292	290	289	282	271	272	271	268	255	247		
		Edh at Noon	22	30	35	36	36	38	40	36	31	24	19	20		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	444	725	1102	1409	1590	1725	1722	1512	1192	714	405	311		
	RadStd	RadStd	55	81	76	127	164	119	147	95	90	65	49	29		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page