

PRESQUE ISLE, ME, USA

WMO: 727130

Lat: 46.683N

Lon: 68.050W

Elev: 534

StdP: 14.41

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14604

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -16.9	(c) -10.9	(d) -26.4	(e) 1.3	(f) -12.4	(g) -21.9	(h) 1.7	(i) -9.3	(j) 26.3	(k) 22.6	(l) 24.2	(m) 20.6	(n) 2.4	(o) 0	(p) 0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	84.5	68.5	81.7	66.5	79.2	65.0	71.2	80.8	69.3	78.2	67.7	75.5	10.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 68.1	(b) 105.1	(c) 75.6	(d) 66.1	(e) 98.0	(f) 74.1	(g) 64.2	(h) 91.7	(i) 71.8	(j) 35.2	(k) 80.6	(l) 33.7	(m) 78.6	(n) 32.3	(o) 75.3	(p) 79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 23.3	(b) 20.1	(c) 18.1	(e) -25.2	(f) 90.3	(g) 5.7	(h) 2.8	(i) -29.3	(j) 92.4	(k) -32.6	(l) 94.0	(m) -35.8	(n) 95.6	(o) -39.9	(p) 97.6		
(a) 23.3	(b) 20.1	(c) 18.1	(e) -23.8	(f) 74.4	(g) 3.5	(h) 2.0	(i) -26.3	(j) 75.8	(k) -28.4	(l) 77.0	(m) -30.3	(n) 78.1	(o) -32.8	(p) 79.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.3	12.1	14.1	24.7	37.9	51.1	60.3	66.1	64.0	56.0	43.9	32.4	19.6		
	DBStd	20.77	13.04	11.83	10.79	7.54	7.13	6.84	5.34	5.71	7.39	7.64	9.30	11.31		
	HDD50	5128	1174	1005	785	369	72	3	0	0	25	220	531	944		
	HDD65	9203	1639	1425	1250	814	435	174	51	89	285	654	978	1409		
	CDD50	1595	0	0	1	5	106	313	498	433	204	32	3	0		
	CDD65	192	0	0	0	0	4	34	84	56	14	0	0	0		
	CDH74	2009	0	0	0	3	102	398	795	559	147	5	0	0		
	CDH80	478	0	0	0	0	23	100	188	133	34	0	0	0		
(14) Wind	WSAvg	7.4	7.6	7.9	8.8	8.5	8.0	6.9	6.0	5.6	6.4	7.3	7.8	7.6		
(15) Precipitation	PrecAvg	35.4	2.3	1.7	2.1	2.3	3.3	3.1	3.9	3.7	3.6	3.4	3.0	2.7		
	PrecMax	51.6	5.5	4.7	4.5	5.4	6.6	7.8	7.0	8.5	9.4	8.7	7.6	6.4		
	PrecMin	23.1	0.3	0.1	0.4	0.5	0.5	0.7	0.7	1.2	0.9	0.9	1.4	0.6		
	PrecStd	5.9	1.1	0.9	0.9	1.0	1.4	1.5	1.4	1.7	1.8	1.8	1.5	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	46.4	55.3	69.7	82.5	88.4	88.9	88.4	84.2	73.0	61.4	48.1		
		MCWB	47.4	42.3	44.4	51.1	62.7	70.3	70.5	69.6	70.2	60.4	57.9	46.1		
	2%	DB	40.3	39.1	46.3	61.3	76.6	82.3	84.3	83.7	78.9	65.9	55.1	43.0		
		MCWB	37.5	35.6	38.9	48.7	58.4	65.8	69.1	68.4	66.8	57.7	50.2	39.7		
	5%	DB	36.2	36.2	43.1	55.2	71.7	79.1	81.6	80.6	73.2	61.6	50.3	37.4		
		MCWB	33.9	33.4	36.9	46.1	56.2	63.8	67.1	66.2	63.0	55.1	46.3	34.8		
	10%	DB	31.6	33.5	39.0	51.7	65.9	74.6	79.0	76.6	70.2	57.1	45.9	35.7		
		MCWB	30.0	31.0	34.3	43.2	53.4	61.6	65.8	64.7	61.8	50.9	42.5	33.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.1	42.9	48.1	56.7	66.3	72.3	74.2	72.5	71.8	63.1	58.6	46.4		
		MCDB	47.4	46.2	52.8	65.7	78.2	84.1	83.2	82.6	82.4	68.1	61.8	47.4		
	2%	WB	38.3	36.9	41.2	51.6	61.6	69.1	71.4	70.3	68.4	59.3	51.8	40.5		
		MCDB	40.0	38.6	45.8	57.3	70.5	78.8	80.1	79.4	75.3	64.8	54.6	43.2		
	5%	WB	33.4	33.2	37.7	47.2	58.3	66.8	69.4	68.5	65.9	55.6	46.3	36.0		
		MCDB	35.7	35.5	41.5	54.2	67.0	75.0	78.6	76.5	71.7	61.0	48.7	37.6		
	10%	WB	29.8	30.5	34.9	43.6	55.4	64.1	67.8	66.7	62.9	52.2	42.8	32.8		
		MCDB	31.5	32.7	39.1	50.3	65.2	71.2	75.9	74.1	68.1	56.6	46.3	34.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	19.6	21.3	19.4	18.6	21.5	21.5	20.8	21.7	21.8	18.3	14.1	16.3		
		MCDBR	20.1	18.5	21.7	28.3	31.5	27.9	25.4	26.6	26.7	25.2	19.6	15.9		
	5% WB	MCWBR	19.6	16.1	16.3	17.9	16.6	14.7	12.8	13.8	16.1	17.8	16.6	15.3		
		MCWBR	19.5	16.2	19.2	24.7	24.8	22.7	21.5	21.4	22.3	22.5	17.5	16.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.254	0.271	0.306	0.341	0.361	0.382	0.409	0.391	0.360	0.321	0.296	0.273		
		taud	2.374	2.308	2.314	2.389	2.401	2.337	2.285	2.338	2.409	2.522	2.522	2.407		
	Ebn at Noon	Ebn at Noon	272	288	292	290	287	280	270	271	270	267	254	249		
		Edh at Noon	22	29	34	35	36	39	40	37	31	24	20	20		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	449	731	1106	1413	1592	1726	1727	1522	1208	725	415	317		
	RadStd	RadStd	56	80	75	126	170	116	147	95	90	66	48	28		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	+4.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page