

WISCASSET, ME, USA

WMO: 727135

Lat: 43.964N

Lon: 69.712W

Elev: 68

StdP: 14.66

Time Zone: -5.00 (NAE)

Period: 95-19

WBAN: 94623

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.2	1.4	-16.1	2.3	1.1	-10.9	3.1	5.8	17.7	37.8	15.7	33.4	2.0	300	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	85.8	71.3	82.4	69.2	79.9	67.4	73.5	81.9	71.7	79.1	70.1	76.4	6.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.8	113.9	77.7	69.6	109.2	75.8	67.8	102.2	73.9	37.1	81.8	35.5	79.2	34.1	75.9	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.8	12.4	10.9	-10.9	91.7	6.9	2.8	-15.8	93.7	-19.8	95.3	-23.7	96.9	-28.7	98.9		
			-11.5	76.7	6.6	1.7	-16.2	77.9	-20.1	78.9	-23.7	79.8	-28.5	81.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.8	21.8	24.6	32.3	43.2	53.5	62.1	68.4	67.3	60.1	48.6	38.4	28.4
	DBStd	17.76	10.82	9.86	8.79	6.64	6.47	6.23	4.91	4.83	6.69	7.19	7.95	9.36
	HDD50	3536	874	711	551	222	33	1	0	0	4	115	356	669
	HDD65	7297	1339	1131	1013	654	364	128	22	31	174	510	798	1133
	CDD50	2017	0	0	3	18	140	365	569	535	308	71	8	0
	CDD65	303	0	0	0	0	6	41	126	101	28	1	0	0
	CDH74	2519	0	0	4	6	121	389	1028	754	205	12	0	0
	CDH80	590	0	0	0	0	33	95	257	161	43	1	0	0
Wind	WSAvg	3.9	4.0	4.3	4.8	4.7	4.4	3.8	3.4	3.1	3.3	3.8	3.8	3.7
Precipitation	PrecAvg	48.1	3.1	3.3	4.2	3.9	3.9	4.4	3.5	3.2	4.2	5.2	4.6	4.7
	PrecMax	71.5	5.2	6.9	7.6	9.4	7.7	8.8	7.8	6.1	9.4	16.0	7.5	6.5
	PrecMin	34.1	0.5	1.5	1.1	0.4	1.1	1.0	0.6	0.8	0.2	1.1	1.4	2.4
	PrecStd	8.6	1.2	1.2	1.9	2.0	1.9	2.3	2.0	1.7	2.5	3.3	1.4	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.5	51.2	64.4	72.9	84.4	88.0	90.1	88.8	85.0	74.9	62.8	54.9
		MCWB	50.9	46.7	52.2	57.0	65.1	71.9	73.5	73.4	72.3	62.6	55.8	51.2
	2%	DB	47.5	46.4	54.2	64.1	76.7	82.2	85.8	84.1	79.7	67.9	58.6	50.5
		MCWB	44.1	41.8	44.8	50.7	61.5	68.6	71.6	71.0	67.2	60.1	54.2	48.1
	5%	DB	42.6	43.1	48.4	59.7	71.1	78.8	82.5	81.2	75.1	64.1	55.2	46.6
		MCWB	38.9	38.4	42.0	48.3	58.4	65.9	69.6	68.9	65.2	58.3	51.5	43.7
	10%	DB	37.4	39.1	45.3	55.5	65.8	74.6	79.8	78.6	72.1	61.2	52.3	43.0
		MCWB	33.8	35.1	39.8	46.5	55.5	63.0	67.8	67.1	63.9	55.6	48.6	39.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.7	48.2	53.7	59.6	67.8	74.2	76.2	75.7	73.1	66.0	59.2	52.9
		MCDB	52.9	49.5	61.4	68.8	79.8	83.8	86.5	85.4	82.5	69.5	61.3	54.1
	2%	WB	45.1	43.5	47.5	54.5	63.8	71.1	73.5	73.4	70.2	62.4	55.6	48.5
		MCDB	46.8	45.8	51.0	59.9	72.9	79.8	82.2	80.6	76.0	65.9	57.3	50.2
	5%	WB	39.0	39.1	43.7	51.0	60.5	68.4	71.8	71.3	68.1	59.7	52.6	44.7
		MCDB	42.2	42.1	47.5	56.4	68.4	75.2	79.4	77.4	72.7	63.6	54.5	46.2
	10%	WB	34.4	35.8	40.3	47.9	57.2	65.8	70.1	69.6	65.8	57.0	48.8	39.4
		MCDB	37.0	38.8	44.6	54.1	64.1	71.7	76.6	75.1	70.2	60.3	51.9	42.4
Mean Daily Temperature Range	5% DB	MDBR	18.4	19.1	17.9	19.7	20.0	19.2	19.7	20.0	20.0	19.0	16.7	16.8
		MCDBR	21.0	20.5	22.8	27.4	29.1	25.3	24.1	23.3	23.7	22.2	19.0	20.5
		MCWBR	19.0	16.9	15.6	16.3	15.2	12.9	11.4	11.7	13.4	15.1	15.7	18.4
	5% WB	MCDBR	20.7	19.1	20.7	21.8	24.9	22.3	19.6	19.2	18.7	19.3	16.5	19.8
		MCWBR	19.6	17.4	16.1	15.3	14.4	13.0	10.4	10.9	11.9	15.0	15.5	19.5
Clear-Sky Solar Irradiance	taub	0.292	0.304	0.328	0.354	0.382	0.428	0.443	0.411	0.372	0.338	0.319	0.294	
	taud	2.440	2.414	2.440	2.415	2.383	2.265	2.243	2.322	2.411	2.508	2.525	2.509	
	Ebn at Noon	266	283	289	289	282	268	262	267	271	267	255	256	
	Edh at Noon	23	28	31	35	37	42	43	38	32	26	22	20	
All-Sky Solar Radiation	RadAvg	515	800	1174	1461	1646	1767	1855	1679	1352	865	550	407	
	RadStd	37	62	71	156	199	148	132	87	81	78	50	43	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+185	+65
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	N/A

Nomenclature: See separate page