

BRITT, ON, Canada

WMO: 727320

Lat: 45.800N

Lon: 80.530W

Elev: 190

StdP: 99.06

Time Zone: -5.00 (NAE)

Period: 86-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -30.6	(c) -26.7	(d) -35.9	(e) 0.1	(f) -30.1	(g) -32.2	(h) 0.2	(i) -26.1	(j) 7.9	(k) -5.8	(l) 7.2	(m) -4.9	(n) 0.5	(o) 10	(p) 0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	28.2	20.7	26.7	19.8	25.2	18.9	22.3	25.9	21.3	24.7	20.4	23.6	2.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	16.1	24.2	20.2	15.2	23.3	19.3	14.4	22.1	66.4	26.1	62.8	24.7	59.6	23.5	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.5	(b) 5.7	(c) 5.1	(e) -37.2	(f) 31.0	(g) 3.6	(h) 1.6	(i) -39.8	(j) 32.1	(k) -41.9	(l) 33.0	(m) -43.9	(n) 33.9	(o) -46.6	(p) 35.1		
(a) 6.5	(b) 5.7	(c) 5.1	(e) -35.4	(f) 24.2	(g) 4.2	(h) 1.0	(i) -38.4	(j) 24.9	(k) -40.8	(l) 25.4	(m) -43.1	(n) 26.0	(o) -46.2	(p) 26.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-10.5	-10.1	-3.9	3.9	11.3	15.8	18.7	17.5	12.8	7.1	-0.1	-6.5
	DBStd	11.59	8.26	7.16	6.81	4.23	4.12	3.64	2.90	3.37	4.21	4.15	4.84	7.47
	HDD10.0	2799	637	562	432	188	35	2	0	1	21	108	302	511
	HDD18.3	5053	896	795	691	433	220	92	32	57	170	347	552	769
	CDD10.0	882	0	0	0	5	75	177	268	232	105	20	1	0
	CDD18.3	94	0	0	0	0	2	16	42	31	4	0	0	0
	CDH23.3	819	0	0	0	4	35	161	349	237	33	1	0	0
	CDH26.7	129	0	0	0	1	2	26	60	37	4	0	0	0
Wind	WSAvg	1.8	2.2	2.0	2.0	2.1	1.8	1.6	1.4	1.3	1.5	2.0	2.1	1.9
Precipitation	PrecAvg	991	73	54	57	82	90	84	84	94	100	109	88	77
	PrecMax	1171	120	112	139	147	156	141	137	168	192	177	138	155
	PrecMin	811	38	20	8	31	33	29	38	47	38	48	41	33
	PrecStd	97	21	24	28	29	31	28	28	28	35	35	25	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	7.8	14.3	21.2	26.2	29.1	30.6	29.7	26.5	20.8	13.6	8.2
		MCWB	7.5	5.5	9.5	13.9	16.7	21.4	21.1	22.8	19.5	15.5	11.9	7.2
	2%	DB	3.6	4.8	10.4	16.6	24.1	27.2	28.2	27.5	23.8	18.1	11.2	5.9
		MCWB	2.8	2.8	7.0	10.6	15.6	19.6	20.7	20.9	18.6	14.1	10.5	4.9
	5%	DB	2.0	2.6	7.4	14.0	21.9	25.1	26.6	26.0	22.0	16.1	8.7	4.4
		MCWB	1.3	1.1	4.5	8.4	14.6	18.2	19.9	20.1	17.8	13.5	7.5	3.4
	10%	DB	0.8	0.9	4.9	11.7	19.7	23.4	25.2	24.4	20.2	14.2	6.5	2.8
		MCWB	0.3	0.0	2.5	6.5	13.5	17.2	19.1	19.3	17.0	11.6	5.2	1.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	6.7	10.8	15.4	18.9	22.8	23.4	24.1	20.8	17.0	12.5	7.7
		MCDB	7.9	7.1	12.5	18.7	23.7	27.6	27.7	28.5	23.3	18.6	13.0	7.9
	2%	WB	3.0	2.9	7.4	11.9	17.2	21.1	22.2	22.4	19.7	15.2	10.4	5.2
		MCDB	3.3	4.2	10.0	15.4	21.9	25.9	25.8	25.8	22.3	17.0	11.2	5.8
	5%	WB	1.5	1.3	5.0	9.1	15.9	19.7	21.3	21.3	18.9	13.8	7.9	3.4
		MCDB	1.9	2.3	7.0	12.4	19.9	23.3	24.8	24.3	21.2	15.8	8.4	4.2
	10%	WB	0.3	-0.1	2.8	7.2	14.5	18.3	20.4	20.3	17.8	12.1	5.3	1.9
		MCDB	0.8	0.9	4.7	10.8	18.5	21.7	23.9	23.1	19.8	14.0	6.4	2.8
Mean Daily Temperature Range	5% DB	MDBR	12.0	13.2	11.6	10.9	12.5	12.4	11.8	11.9	11.4	9.6	7.7	9.8
		MCDBR	9.8	9.0	12.3	14.9	16.5	14.5	13.6	13.1	13.5	11.5	8.9	7.9
		MCWBR	9.5	7.5	9.1	9.4	9.0	7.9	7.0	7.1	8.6	8.0	8.1	7.4
	5% WB	MCDBR	8.8	8.3	11.9	12.8	13.4	11.7	10.5	10.3	11.5	10.0	9.0	7.5
		MCWBR	8.7	7.3	9.5	9.3	8.2	7.2	6.1	6.3	8.1	7.8	8.7	7.5
Clear-Sky Solar Irradiance	taub	0.279	0.289	0.315	0.344	0.365	0.396	0.401	0.396	0.366	0.346	0.312	0.277	
	taud	2.378	2.319	2.351	2.378	2.405	2.334	2.357	2.363	2.436	2.461	2.498	2.464	
	Ebn at Noon	831	891	916	914	903	871	862	852	851	817	789	801	
	Edh at Noon	73	93	105	113	114	123	119	114	97	82	66	61	
All-Sky Solar Radiation	RadAvg	1.19	2.11	3.56	4.62	5.50	5.97	6.06	5.12	3.93	2.32	1.25	0.87	
	RadStd	0.15	0.21	0.34	0.40	0.52	0.44	0.31	0.29	0.38	0.27	0.18	0.08	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page