

TWO HARBORS HELGESON, MN, USA

WMO: 727444

Lat: 47.049N

Lon: 91.745W

Elev: 329

StdP: 97.43

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 04979

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.3	-23.9	-32.5	0.2	-26.6	-29.2	0.3	-22.6	9.0	-5.3	8.2	-6.3	2.4	290	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	28.8	22.1	27.4	20.5	26.0	19.2	23.2	27.5	21.7	26.1	20.2	24.4	4.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	17.4	26.7	20.1	15.4	24.6	18.7	14.1	23.3	70.6	27.5	64.5	26.0	59.5	24.4	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	7.9	6.9	DB	-30.6	32.2	3.7	1.8	-33.3	33.5	-35.5	34.5	-37.6	35.6	-40.3	36.9	(4)
(5)			WB	-30.8	25.1	3.5	1.7	-33.3	26.3	-35.4	27.4	-37.4	28.3	-39.9	29.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.4	-11.2	-9.4	-3.1	3.6	10.0	15.3	18.8	17.6	13.2	6.4	-1.1	-8.0	(6)	
	DBStd	11.60	7.30	6.75	6.50	4.74	4.37	3.68	3.30	3.17	4.34	4.29	5.81	6.57	(7)	
	HDD10.0	2899	659	542	406	197	53	4	0	0	18	128	334	557	(8)	
	HDD18.3	5174	917	776	663	441	259	104	35	51	161	369	583	816	(9)	
	CDD10.0	866	0	0	1	6	55	162	273	236	114	18	1	0	(10)	
	CDD18.3	99	0	0	0	0	2	11	49	29	7	0	0	0	(11)	
	CDH23.3	967	0	0	0	2	56	143	453	249	62	2	0	0	(12)	
	CDH26.7	202	0	0	0	0	11	24	108	51	8	0	0	0	(13)	
(14) Wind	WSAvg	2.7	2.8	2.8	2.9	3.3	3.1	2.5	2.3	2.2	2.4	2.8	2.8	2.7	(14)	
(15) Precipitation	PrecAvg	785	28	27	39	67	78	97	96	83	94	84	56	36	(15)	
	PrecMax	957	73	87	87	213	133	164	242	165	176	173	169	64	(16)	
	PrecMin	614	4	7	10	16	22	13	28	26	11	28	8	5	(17)	
	PrecStd	103	17	18	18	40	27	38	53	35	40	36	39	18	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	7.9	16.0	22.2	27.9	29.3	31.6	31.1	27.7	22.4	17.1	7.1	(19)	
		MCWB	3.0	4.4	10.6	12.9	18.1	23.0	23.5	23.9	20.9	15.5	11.4	4.1	(20)	
	2%	DB	2.6	4.1	11.3	17.7	24.1	27.1	29.0	27.7	25.1	18.8	12.2	3.9	(21)	
		MCWB	1.0	1.8	6.7	10.5	15.7	19.3	22.3	21.5	19.4	14.2	9.5	2.3	(22)	
	5%	DB	1.0	2.4	7.8	14.8	21.4	24.9	27.6	26.2	22.7	16.5	8.9	2.5	(23)	
		MCWB	-0.3	0.9	4.6	8.5	14.1	18.0	21.1	19.8	17.9	12.0	6.3	1.1	(24)	
	10%	DB	-1.2	0.3	5.9	12.2	18.0	22.8	26.2	24.0	21.1	13.7	7.2	1.1	(25)	
		MCWB	-2.1	-0.9	2.9	6.9	12.5	17.0	19.7	18.7	16.8	10.3	4.7	-0.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	5.1	11.0	14.5	19.7	24.0	25.0	24.7	22.9	17.2	12.4	4.5	(27)	
		MCDB	6.0	7.7	14.3	19.2	26.5	28.1	29.1	29.7	26.6	19.8	15.9	6.3	(28)	
	2%	WB	1.0	2.6	7.2	11.2	16.9	20.6	23.6	22.6	20.4	14.9	9.3	2.7	(29)	
		MCDB	2.5	4.2	9.7	17.0	22.2	25.1	27.9	27.0	24.1	18.2	12.0	3.9	(30)	
	5%	WB	-0.4	0.8	4.8	9.0	15.0	19.1	22.1	20.9	18.8	12.8	6.8	0.8	(31)	
		MCDB	0.8	2.2	7.8	14.4	20.1	23.4	26.7	24.8	22.2	15.9	8.7	2.2	(32)	
	10%	WB	-2.3	-1.0	3.0	7.1	13.2	17.7	20.5	19.6	17.2	10.6	4.6	-0.2	(33)	
		MCDB	-1.6	0.2	5.7	11.4	17.9	21.6	24.9	23.4	20.0	13.2	6.8	1.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.2	9.8	10.1	11.6	11.5	11.4	11.0	10.6	9.1	8.0	8.0	(35)	
		MCDBR	9.2	11.0	12.5	16.3	16.9	14.8	13.5	13.2	13.4	13.9	11.5	8.2	(36)	
	5% WB	MCWBR	7.9	8.8	9.0	10.5	9.9	9.0	8.3	8.2	9.1	9.6	8.5	6.8	(37)	
		MCWBR	8.8	9.6	11.9	15.4	14.9	13.1	12.9	12.1	12.1	12.5	10.6	7.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.249	0.278	0.314	0.344	0.372	0.377	0.385	0.382	0.361	0.313	0.288	0.266	(40)	
		taud	2.424	2.352	2.359	2.384	2.369	2.386	2.390	2.421	2.450	2.560	2.521	2.431	(41)	
	Edn at Noon	Edn at Noon	864	898	911	911	893	887	874	863	851	853	809	793	(42)	
		Edh at Noon	66	88	103	111	117	116	114	106	95	73	61	59	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.33	2.36	3.56	4.60	5.35	5.77	6.09	5.12	3.82	2.31	1.32	0.97	(44)	
	RadStd	RadStd	0.14	0.23	0.33	0.47	0.39	0.40	0.25	0.35	0.24	0.28	0.16	0.10	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (35 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page