

GOGEBIC-IRON COUNTY AP, MI, USA

WMO: 727445

Lat: 46.533N

Lon: 90.133W

Elev: 375

StdP: 96.90

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 94926

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -25.5	(c) -22.4	(d) -31.0	(e) 0.2	(f) -23.9	(g) -27.6	(h) 0.3	(i) -21.1	(j) 10.9	(k) -10.6	(l) 9.9	(m) -11.0	(n) 3.5	(o) 250	(p) 0.614

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	29.9	21.2	27.9	20.1	27.0	19.3	22.7	28.1	21.5	26.6	20.4	25.1	4.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	16.5	26.1	19.6	15.0	24.7	18.6	14.1	24.0	68.8	28.1	64.1	26.3	60.6	25.6	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.8	(b) 8.6	(c) 7.8	(e) -29.6	(f) 32.7	(g) 2.9	(h) 1.8	(i) -31.6	(j) 34.0	(k) -33.3	(l) 35.1	(m) -34.9	(n) 36.1	(o) -37.0	(p) 37.4		
(a) 9.8	(b) 8.6	(c) 7.8	(e) -29.6	(f) 32.7	(g) 2.9	(h) 1.8	(i) -31.6	(j) 34.0	(k) -33.3	(l) 35.1	(m) -34.9	(n) 36.1	(o) -37.0	(p) 37.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.2	-9.9	-8.5	-2.7	4.1	11.2	16.4	19.0	17.7	14.0	7.3	0.0	-6.6
	DBStd	11.57	6.81	7.00	7.24	5.66	5.14	4.44	3.73	3.66	4.99	5.24	5.67	6.19
	HDD10.0	2731	616	518	398	193	47	4	0	0	17	120	302	516
	HDD18.3	4937	874	751	653	429	229	88	37	57	149	345	549	774
	CDD10.0	987	0	0	3	14	83	195	279	238	136	35	3	0
	CDD18.3	151	0	0	0	1	8	29	58	37	17	2	0	0
	CDH23.3	1428	0	0	1	8	109	284	564	324	127	11	0	0
	CDH26.7	341	0	0	0	1	29	66	147	69	28	1	0	0
Wind	WSAvg	3.5	3.9	3.7	3.5	3.5	3.5	3.0	2.9	2.9	3.3	3.8	3.9	3.8
Precipitation	PrecAvg	887	49	34	52	63	85	98	99	97	95	87	74	54
	PrecMax	1174	110	92	114	201	175	186	233	180	188	171	207	129
	PrecMin	661	16	5	17	12	16	22	25	17	30	32	16	7
	PrecStd	121	25	19	26	33	39	40	47	42	41	38	37	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	10.2	18.9	24.0	30.0	31.2	32.7	31.3	30.2	25.1	17.4	7.9
		MCWB	2.4	6.1	13.5	13.8	18.6	22.2	23.4	22.3	21.3	16.4	10.8	4.6
	2%	DB	2.9	7.1	13.7	20.1	26.7	28.6	30.0	28.1	27.0	22.0	13.0	5.4
		MCWB	0.8	3.5	8.3	10.9	16.5	20.5	21.8	20.6	19.3	14.8	8.9	2.4
	5%	DB	1.2	3.8	10.9	17.3	23.0	26.9	27.9	27.0	24.2	18.7	11.0	2.8
		MCWB	-0.1	1.0	6.4	9.1	14.9	18.8	20.6	20.0	18.3	13.9	7.0	1.0
	10%	DB	-1.0	1.3	7.5	13.9	21.0	24.3	27.0	25.0	22.4	16.2	7.9	1.4
		MCWB	-2.0	-0.6	3.7	7.4	13.4	17.3	19.8	18.8	17.0	11.4	4.9	0.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	6.3	14.5	15.2	21.6	23.2	24.6	23.6	22.0	19.2	12.5	6.1
		MCDB	5.5	10.1	18.1	22.2	27.5	29.5	30.1	28.8	27.7	22.5	15.5	7.6
	2%	WB	1.3	3.7	9.4	11.9	18.1	21.5	22.9	22.1	20.6	15.9	9.8	2.8
		MCDB	3.0	6.7	13.1	18.7	23.4	27.3	28.3	26.7	25.2	20.0	13.3	4.6
	5%	WB	-0.2	1.2	6.4	9.8	16.0	20.0	21.7	20.8	19.3	13.9	7.3	1.3
		MCDB	1.2	3.7	10.4	15.9	21.5	24.9	26.9	25.4	23.5	18.4	9.8	2.9
	10%	WB	-2.0	-0.6	3.7	7.9	14.2	18.5	20.5	19.7	17.8	11.8	5.2	0.1
		MCDB	-1.0	1.2	7.1	13.7	20.0	23.1	25.1	24.4	21.5	15.6	8.1	1.5
Mean Daily Temperature Range	5% DB	MDBR	7.9	9.8	10.6	10.9	12.3	11.9	11.8	11.5	10.8	8.9	7.3	7.0
		MCDBR	8.8	11.1	12.4	16.5	16.1	13.5	13.2	13.0	12.4	12.2	11.3	8.6
		MCWBR	7.3	8.3	8.2	9.7	8.5	7.4	7.2	7.3	7.3	7.7	8.1	6.8
	5% WB	MCDBR	8.3	10.1	11.5	14.9	13.5	11.8	11.8	11.6	10.9	10.9	10.4	7.6
		MCWBR	7.0	7.7	8.1	9.5	7.9	7.2	6.9	7.1	7.0	7.8	7.9	6.3
Clear-Sky Solar Irradiance	taub	0.244	0.266	0.298	0.331	0.361	0.362	0.363	0.360	0.344	0.308	0.285	0.255	
	taud	2.435	2.366	2.392	2.431	2.402	2.423	2.450	2.471	2.500	2.576	2.539	2.461	
	Ebn at Noon	879	919	932	927	904	903	896	887	873	864	821	822	
	Edh at Noon	66	87	100	106	114	112	108	102	90	72	61	58	
All-Sky Solar Radiation	RadAvg	1.29	2.31	3.56	4.51	5.34	5.79	6.05	5.05	3.81	2.31	1.31	0.92	
	RadStd	0.12	0.23	0.31	0.47	0.41	0.41	0.25	0.32	0.22	0.28	0.17	0.10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page