

CAMBRIDGE, MN, USA

WMO: 727503

Lat: 45.559N

Lon: 93.265W

Elev: 288

StdP: 97.91

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 04909

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.1	-23.7	-31.3	0.2	-25.7	-28.0	0.3	-22.8	8.5	-9.3	7.8	-9.1	1.0	280	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	32.5	23.7	31.0	22.9	28.8	21.8	25.0	30.5	23.8	28.9	22.6	27.6	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	18.3	28.1	22.2	17.5	27.5	21.1	16.3	26.4	77.7	30.3	72.4	29.0	67.9	27.6	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.2	6.0	-30.7	35.9	3.7	3.3	-33.4	38.2	-35.6	40.2	-37.6	42.0	-40.3	44.4		
(5)			-30.8	26.7	3.5	1.4	-33.3	27.7	-35.4	28.5	-37.4	29.3	-39.9	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.9	-10.3	-7.9	-0.8	7.1	13.9	19.3	22.1	20.4	16.2	8.7	0.6	-7.1	(6)
(7)		DBStd	12.59	7.63	7.12	6.98	5.57	4.85	4.09	3.41	3.38	5.02	5.14	6.14	7.04	(7)
(8)		HDD10.0	2521	629	502	339	121	17	1	0	0	8	87	287	531	(8)
(9)		HDD18.3	4494	888	735	593	340	155	36	7	17	99	302	532	789	(9)
(10)		CDD10.0	1394	1	0	5	32	137	280	375	322	193	46	4	0	(10)
(11)		CDD18.3	324	0	0	0	2	16	65	124	80	35	3	0	0	(11)
(12)		CDH23.3	3113	4	0	2	27	207	643	1208	700	294	27	0	0	(12)
(13)		CDH26.7	996	3	0	0	7	66	201	429	207	81	4	0	0	(13)
(14)	Wind	WSAvg	2.4	2.4	2.5	2.6	2.9	2.8	2.3	2.0	1.9	2.3	2.6	2.6	2.3	(14)
(15)	Precipitation	PrecAvg	787	22	21	38	69	85	116	107	100	85	73	45	26	(15)
(16)		PrecMax	997	52	44	75	188	176	192	183	247	179	172	136	50	(16)
(17)		PrecMin	580	1	2	18	15	18	62	30	17	18	29	1	9	(17)
(18)		PrecStd	127	14	12	17	37	42	41	44	51	47	39	37	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	11.2	21.1	27.2	32.4	33.7	35.9	33.9	32.3	27.0	18.9	8.9	(19)
(20)			MCWB	3.8	7.5	14.0	16.8	21.6	23.8	24.7	23.1	23.3	19.1	13.1	6.6	(20)
(21)		2%	DB	3.7	6.3	16.1	22.5	27.8	31.2	32.6	31.2	28.8	22.7	15.2	6.1	(21)
(22)			MCWB	1.6	3.3	11.2	13.1	18.8	22.3	24.3	23.6	21.8	16.2	10.7	3.5	(22)
(23)		5%	DB	2.1	3.8	12.3	19.8	25.9	28.8	31.1	28.7	27.1	19.2	12.3	3.3	(23)
(24)			MCWB	0.6	1.8	8.4	12.0	17.2	21.2	23.4	22.1	20.2	14.2	8.6	1.5	(24)
(25)		10%	DB	0.0	2.2	8.7	17.2	22.7	27.2	28.9	27.3	24.1	17.3	9.0	2.2	(25)
(26)			MCWB	-1.2	0.7	5.7	10.3	15.4	19.6	22.2	20.8	18.5	12.7	6.2	0.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.9	7.5	15.4	17.7	23.1	25.4	26.9	26.2	24.1	20.2	14.1	6.9	(27)
(28)			MCDWB	6.6	10.5	19.3	25.3	31.1	32.0	32.6	31.2	29.4	24.8	17.5	8.4	(28)
(29)		2%	WB	1.9	3.9	11.2	14.7	20.0	23.5	25.4	24.3	22.3	17.2	11.5	3.7	(29)
(30)			MCDWB	3.4	6.0	15.8	20.7	26.2	29.0	31.0	29.3	27.2	21.3	15.0	5.7	(30)
(31)		5%	WB	0.2	2.1	8.2	12.4	18.1	22.0	24.2	22.8	20.9	15.2	8.5	1.9	(31)
(32)			MCDWB	1.6	3.9	11.5	18.6	23.8	27.4	29.3	27.4	25.7	19.2	11.6	3.2	(32)
(33)		10%	WB	-1.3	0.5	5.5	10.6	16.3	20.5	23.0	21.6	19.4	12.9	6.4	0.5	(33)
(34)			MCDWB	-0.2	1.9	8.4	16.0	21.7	25.8	28.0	25.9	24.0	16.6	8.9	2.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.5	10.0	10.0	11.6	12.1	11.6	11.5	11.3	11.5	10.1	8.6	8.1	(35)
(36)			MCDBR	10.0	10.3	13.7	16.2	15.9	13.5	12.9	12.9	13.1	13.8	12.7	8.9	(36)
(37)			MCWBR	8.0	8.2	9.4	9.5	8.9	7.2	6.6	7.1	7.3	8.8	8.8	7.3	(37)
(38)		5% WB	MCDBR	9.3	9.8	12.9	14.4	13.9	12.0	11.7	11.5	11.9	12.3	11.8	8.4	(38)
(39)			MCWBR	8.0	7.8	9.3	9.4	8.8	7.3	7.0	7.2	7.3	8.5	8.7	7.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.263	0.272	0.316	0.375	0.407	0.393	0.388	0.399	0.370	0.317	0.288	0.264	(40)	
(41)		taud	2.397	2.363	2.366	2.286	2.244	2.329	2.366	2.340	2.393	2.536	2.508	2.421	(41)	
(42)		Ebn at Noon	859	918	916	883	862	874	874	849	846	858	825	817	(42)	
(43)		Edh at Noon	71	90	104	124	134	124	118	117	102	76	65	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.70	2.79	3.89	4.64	5.33	5.90	6.24	5.20	4.02	2.51	1.59	1.18	(44)	
(45)		RadStd	0.19	0.26	0.34	0.43	0.43	0.44	0.21	0.39	0.27	0.34	0.14	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page