

CUT BANK, MT, USA

WMO: 727690

Lat: 48.603N

Lon: 112.375W

Elev: 1170

StdP: 88.04

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24137

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.7	-24.6	-31.4	0.2	-27.2	-27.9	0.3	-24.0	21.5	4.7	18.9	2.9	2.6	340	0.779

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	31.9	15.4	29.9	14.9	27.8	14.4	16.9	27.4	16.0	26.7	15.2	25.7	5.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.2	10.9	19.2	12.2	10.2	18.6	11.1	9.5	18.0	51.5	27.2	48.7	26.8	46.2	25.9	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.6	14.9	12.9	-33.4	34.9	4.1	2.0	-36.3	36.3	-38.7	37.5	-41.1	38.6	-44.1	40.0		
(5)			-32.3	18.8	3.0	1.2	-34.5	19.6	-36.2	20.3	-37.8	20.9	-40.0	21.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-5.4	-5.2	-0.6	4.6	9.7	14.1	18.7	17.7	12.6	5.8	-0.6	-5.3	(6)
(7)		DBStd	10.64	8.89	8.68	7.44	5.02	4.42	3.45	3.29	3.49	4.69	5.60	7.64	8.25	(7)
(8)		HDD10.0	2439	477	425	328	171	59	6	1	1	26	150	320	476	(8)
(9)		HDD18.3	4746	735	658	586	413	267	132	35	53	176	390	567	734	(9)
(10)		CDD10.0	828	1	0	1	8	51	129	271	241	105	18	3	0	(10)
(11)		CDD18.3	94	0	0	0	0	1	6	47	35	6	0	0	0	(11)
(12)		CDH23.3	1958	0	0	0	2	42	145	862	708	194	5	0	0	(12)
(13)		CDH26.7	678	0	0	0	0	5	33	331	253	56	0	0	0	(13)
(14)	Wind	WSAvg	5.6	6.4	5.7	5.9	5.8	5.5	5.3	4.6	4.4	4.8	5.8	6.3	6.3	(14)
(15)	Precipitation	PrecAvg	298	9	6	12	23	52	67	36	39	28	11	9	8	(15)
(16)		PrecMax	593	32	18	45	59	163	202	228	97	105	56	34	34	(16)
(17)		PrecMin	127	0	0	0	0	9	12	1	1	1	0	0	0	(17)
(18)		PrecStd	107	7	5	10	15	30	50	41	28	26	10	8	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	13.2	17.1	22.6	27.1	30.4	34.6	33.6	31.2	23.6	17.7	11.4	(19)
(20)			MCWB	4.9	4.9	7.3	10.1	13.3	16.2	16.2	15.5	14.6	11.3	8.3	4.8	(20)
(21)		2%	DB	9.2	10.0	14.0	19.1	24.1	27.2	32.4	31.5	28.1	20.0	13.8	8.7	(21)
(22)			MCWB	3.6	3.9	6.0	8.7	12.3	14.6	15.8	15.0	13.2	9.6	6.6	3.1	(22)
(23)		5%	DB	7.3	7.7	11.9	16.3	21.9	24.7	30.4	29.6	25.6	17.1	11.3	7.0	(23)
(24)			MCWB	2.6	2.4	5.0	7.3	11.3	13.7	15.3	14.6	12.6	8.7	5.1	2.3	(24)
(25)		10%	DB	5.5	5.8	9.3	13.3	18.9	22.5	28.0	27.6	22.6	14.1	9.0	4.9	(25)
(26)			MCWB	1.5	1.4	3.6	5.8	9.9	12.7	14.9	14.0	11.6	7.0	4.1	1.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.0	6.0	8.2	11.0	14.1	17.6	18.6	17.3	15.7	12.3	9.3	5.6	(27)
(28)			MCDWB	10.6	11.7	15.5	20.8	24.6	27.0	28.4	28.3	26.6	21.5	16.3	10.1	(28)
(29)		2%	WB	4.1	4.1	6.5	9.2	12.8	15.8	17.3	16.2	14.3	10.4	7.1	3.8	(29)
(30)			MCDWB	8.6	9.4	13.0	18.5	22.7	24.6	27.5	27.7	25.7	18.7	13.1	8.1	(30)
(31)		5%	WB	2.8	2.7	5.1	7.7	11.7	14.6	16.5	15.4	13.0	8.9	5.5	2.4	(31)
(32)			MCDWB	7.0	7.3	11.2	15.6	20.4	22.8	27.2	26.8	23.9	16.1	10.5	6.5	(32)
(33)		10%	WB	1.6	1.5	3.8	6.3	10.4	13.5	15.6	14.7	11.9	7.6	4.1	1.0	(33)
(34)			MCDWB	5.3	5.6	9.0	12.8	17.9	21.0	26.2	25.7	22.0	14.0	8.7	4.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.4	11.0	11.5	12.3	12.9	13.0	16.1	16.2	14.6	12.4	10.3	10.0	(35)
(36)			MCDBR	11.0	12.9	14.9	17.4	17.9	17.4	19.9	20.4	20.4	16.5	12.3	10.5	(36)
(37)			MCWBR	7.4	8.2	8.8	9.2	8.4	7.5	7.1	7.8	8.8	8.8	7.2	7.0	(37)
(38)		5% WB	MCDBR	10.7	12.6	13.9	16.4	16.1	15.6	17.4	17.5	18.5	15.6	12.1	10.2	(38)
(39)			MCWBR	7.7	8.3	8.4	8.9	7.8	7.4	7.0	7.1	8.3	8.6	7.4	7.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.246	0.255	0.275	0.309	0.320	0.322	0.324	0.341	0.307	0.278	0.253	0.236	(40)	
(41)		taud	2.465	2.484	2.494	2.422	2.442	2.486	2.487	2.410	2.478	2.544	2.519	2.463	(41)	
(42)		Ebn at Noon	854	926	954	944	941	938	930	898	903	883	839	822	(42)	
(43)		Edh at Noon	60	75	88	105	108	104	103	106	89	70	57	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.24	2.23	3.42	4.70	5.61	6.30	7.15	5.79	4.12	2.51	1.38	0.99	(44)	
(45)		RadStd	0.10	0.17	0.32	0.29	0.50	0.51	0.44	0.39	0.34	0.23	0.10	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page