

MULLAN, ID, USA

WMO: 727836

Lat: 47.470N

Lon: 115.800W

Elev: 3317

StdP: 13.02

Time Zone: -8.00 (NAP)

Period: 82-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-1.2	7.6	-11.3	3.4	-0.4	-0.6	6.0	7.4	12.0	16.6	10.7	18.4	2.2	10	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.3	87.0	62.2	84.1	61.4	80.9	60.3	64.8	81.2	63.2	79.4	61.7	77.3	3.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.5	85.8	68.7	57.3	79.4	67.7	55.6	74.4	66.6	31.4	80.7	30.2	79.1	29.0	77.1	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.6	9.5	8.0	-6.0	92.3	7.9	1.7	-11.6	93.6	-16.2	94.6	-20.6	95.6	-26.3	96.9
			-7.1	68.8	7.7	2.0	-12.6	70.2	-17.0	71.4	-21.3	72.5	-26.9	74.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	29.3	31.5	37.1	43.8	50.8	57.6	62.3	62.4	54.5	44.8	33.3	26.8	(6)
	DBStd	14.34	7.60	8.74	5.93	6.53	7.38	7.04	6.16	6.02	6.98	7.48	7.78	7.94	(7)
	HDD50	3319	641	519	399	210	82	16	1	3	34	194	500	720	(8)
	HDD65	7546	1106	939	863	636	442	236	124	121	319	625	950	1185	(9)
	CDD50	1350	0	0	0	24	107	243	384	388	170	34	0	0	(10)
	CDD65	103	0	0	0	0	2	13	42	41	5	0	0	0	(11)
	CDH74	2670	0	0	0	11	169	418	950	875	227	20	0	0	(12)
	CDH80	744	0	0	0	2	35	87	298	271	50	1	0	0	(13)
(14) Wind	WSAvg	2.2	1.7	2.0	2.3	2.6	2.7	2.7	2.4	2.2	2.2	1.7	1.7	1.6	(14)
(15) Precipitation	PrecAvg	38.9	4.7	3.5	4.1	3.3	3.2	3.0	1.0	1.0	1.6	3.8	5.3	5.0	(15)
	PrecMax	52.2	8.7	7.4	10.1	7.8	6.0	6.2	3.2	4.7	5.6	9.8	12.3	11.3	(16)
	PrecMin	29.9	1.3	0.6	1.3	1.4	1.0	1.4	0.1	0.0	0.3	0.3	2.1	0.4	(17)
	PrecStd	6.0	1.9	1.6	1.8	1.4	1.3	1.1	0.8	1.0	1.1	2.0	2.2	2.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.0	54.7	63.5	75.1	85.9	87.3	90.4	90.3	85.4	76.4	55.3	42.6	(19)
		MCWB	39.8	45.2	48.2	55.8	61.4	63.9	63.7	62.8	59.7	56.8	48.3	40.2	(20)
	2%	DB	42.5	48.4	57.1	68.6	79.0	83.1	86.6	87.0	80.7	69.1	49.9	39.5	(21)
		MCWB	38.7	41.6	45.1	52.1	58.6	61.3	62.3	62.0	58.5	53.8	46.2	37.8	(22)
	5%	DB	40.0	44.2	52.1	62.6	73.6	79.5	83.8	83.5	76.4	63.4	45.7	37.2	(23)
		MCWB	37.3	39.3	42.7	49.1	55.6	60.0	61.7	61.3	57.6	51.3	42.9	35.5	(24)
	10%	DB	37.8	40.5	47.0	56.8	67.3	75.2	80.1	79.7	71.6	57.8	42.4	35.4	(25)
		MCWB	35.7	37.7	40.7	46.4	53.1	58.6	60.5	60.3	56.2	48.4	40.1	33.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.4	45.5	49.3	57.5	63.3	65.3	67.2	67.5	62.8	57.7	49.5	40.6	(27)
		MCDB	43.4	51.8	61.4	71.7	82.2	80.8	83.1	82.2	80.0	73.0	53.7	41.7	(28)
	2%	WB	39.4	42.3	46.1	53.2	59.3	63.3	64.8	64.7	60.3	54.7	46.6	38.2	(29)
		MCDB	41.8	46.8	55.2	65.0	74.9	78.7	81.8	80.5	76.5	68.0	50.0	39.4	(30)
	5%	WB	37.7	40.1	43.6	50.1	56.8	61.5	63.1	62.9	58.2	51.7	43.6	35.8	(31)
		MCDB	39.6	43.4	51.1	61.5	71.2	75.2	79.4	79.0	73.5	60.7	46.0	36.8	(32)
	10%	WB	35.8	38.0	41.2	47.3	54.3	59.7	61.4	61.2	56.2	49.3	40.2	34.3	(33)
		MCDB	37.4	40.3	46.0	55.8	66.2	72.5	77.1	76.8	70.4	56.6	42.2	35.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.1	14.2	17.0	20.4	23.3	25.0	27.3	28.3	25.7	20.3	10.0	9.8	(35)
		MCDBR	12.5	19.5	27.0	32.1	35.6	34.4	35.4	35.6	35.7	31.8	15.8	8.8	(36)
	5% WB	MCWBR	9.5	14.1	16.9	17.5	17.2	15.3	15.0	14.9	16.9	17.2	11.4	7.7	(37)
		MCWBR	10.9	17.6	23.3	30.0	33.0	29.7	31.8	30.9	32.3	28.8	14.3	8.4	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.253	0.259	0.290	0.335	0.348	0.350	0.348	0.367	0.339	0.294	0.283	0.249	(40)
		taud	2.465	2.452	2.445	2.390	2.415	2.438	2.452	2.397	2.458	2.597	2.540	2.519	(41)
	Ebn at Noon	Ebn at Noon	272	294	298	292	290	289	288	278	277	278	258	262	(42)
		Edh at Noon	20	25	30	35	36	35	34	35	30	22	19	17	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	344	620	981	1434	1772	1947	2308	1916	1350	801	391	271	(44)
	RadStd	RadStd	42	79	105	128	141	174	147	124	140	91	40	33	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+149	N/A	

Nomenclature: See separate page