

MULLAN, ID, USA

WMO: 727836

Lat: 47.470N

Lon: 115.800W

Elev: 1011

StdP: 89.75

Time Zone: -8.00 (NAP)

Period: 82-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-18.4	-13.5	-24.0	0.5	-18.0	-18.1	0.9	-13.7	5.4	-8.5	4.8	-7.5	1.0	10	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	30.6	16.8	28.9	16.3	27.2	15.7	18.2	27.3	17.4	26.3	16.5	25.2	1.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	12.3	20.4	14.1	11.3	19.8	13.1	10.6	19.2	55.1	27.0	52.4	26.1	49.7	25.0	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.7	4.3	3.6	-21.1	33.5	4.4	1.0	-24.2	34.2	-26.8	34.8	-29.2	35.3	-32.4	36.0		
(5)			-21.7	20.4	4.3	1.1	-24.8	21.2	-27.2	21.9	-29.6	22.5	-32.7	23.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-1.5	-0.3	2.9	6.6	10.5	14.2	16.9	12.5	7.1	0.7	-2.9	(6)	
(7)		DBStd	7.96	4.22	4.86	3.29	3.63	4.10	3.91	3.42	3.34	3.88	4.16	4.32	4.41	(7)
(8)		HDD10.0	1844	356	288	222	117	46	9	1	2	19	108	278	400	(8)
(9)		HDD18.3	4192	614	522	479	353	246	131	69	67	177	347	528	658	(9)
(10)		CDD10.0	750	0	0	0	13	59	135	213	216	94	19	0	0	(10)
(11)		CDD18.3	57	0	0	0	0	1	7	23	23	3	0	0	0	(11)
(12)		CDH23.3	1483	0	0	0	6	94	232	528	486	126	11	0	0	(12)
(13)		CDH26.7	413	0	0	0	1	19	48	166	151	28	1	0	0	(13)
(14)	Wind	WSAvg	1.0	0.8	0.9	1.0	1.2	1.2	1.1	1.0	1.0	0.7	0.8	0.7	(14)	
(15)	Precipitation	PrecAvg	989	119	89	104	84	81	76	26	41	97	134	127	(15)	
(16)		PrecMax	1325	220	188	256	197	152	158	82	119	142	248	312	288	(16)
(17)		PrecMin	760	32	14	34	36	25	35	2	1	8	8	54	11	(17)
(18)		PrecStd	153	49	41	46	35	34	28	20	26	28	50	57	61	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.8	12.6	17.5	23.9	29.9	30.7	32.4	29.7	24.7	12.9	5.9	(19)	
(20)			MCWB	4.3	7.3	9.0	13.2	16.3	17.7	17.6	17.1	15.4	13.8	9.1	4.5	(20)
(21)		2%	DB	5.8	9.1	14.0	20.3	26.1	28.4	30.4	30.6	27.0	20.6	10.0	4.1	(21)
(22)			MCWB	3.7	5.3	7.3	11.2	14.8	16.3	16.9	16.7	14.7	12.1	7.9	3.2	(22)
(23)		5%	DB	4.4	6.8	11.2	17.0	23.1	26.4	28.8	28.6	24.7	17.5	7.6	2.9	(23)
(24)			MCWB	3.0	4.1	6.0	9.5	13.1	15.6	16.5	16.3	14.2	10.7	6.1	1.9	(24)
(25)		10%	DB	3.2	4.7	8.4	13.8	19.6	24.0	26.7	26.5	22.0	14.3	5.8	1.9	(25)
(26)			MCWB	2.1	3.2	4.8	8.0	11.7	14.8	15.9	15.7	13.4	9.1	4.5	1.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	7.5	9.6	14.2	17.4	18.5	19.5	19.7	17.1	14.3	9.7	4.8	(27)
(28)			MCDWB	6.4	11.0	16.3	22.1	27.9	27.1	28.4	27.9	26.7	22.8	12.0	5.4	(28)
(29)		2%	WB	4.1	5.7	7.8	11.8	15.2	17.4	18.2	18.2	15.7	12.6	8.1	3.4	(29)
(30)			MCDWB	5.4	8.2	12.9	18.3	23.8	25.9	27.7	26.9	24.7	20.0	10.0	4.1	(30)
(31)		5%	WB	3.1	4.5	6.5	10.0	13.8	16.4	17.3	17.2	14.5	10.9	6.4	2.1	(31)
(32)			MCDWB	4.2	6.3	10.6	16.4	21.8	24.0	26.3	26.1	23.1	15.9	7.8	2.7	(32)
(33)		10%	WB	2.1	3.4	5.1	8.5	12.4	15.4	16.3	16.2	13.4	9.6	4.6	1.3	(33)
(34)			MCDWB	3.0	4.6	7.8	13.2	19.0	22.5	25.1	24.9	21.3	13.7	5.7	1.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	7.9	9.4	11.3	12.9	13.9	15.2	15.7	14.3	11.3	5.6	5.4	(35)
(36)			MCDBR	6.9	10.8	15.0	17.8	19.8	19.1	19.7	19.8	19.8	17.7	8.8	4.9	(36)
(37)			MCWBR	5.3	7.8	9.4	9.7	9.6	8.5	8.3	8.3	9.4	9.6	6.4	4.3	(37)
(38)		5% WB	MCDBR	6.1	9.8	12.9	16.7	18.3	16.5	17.7	17.2	17.9	16.0	7.9	4.7	(38)
(39)			MCWBR	5.0	7.4	8.5	9.3	9.3	8.0	7.9	7.8	9.1	9.1	6.0	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.253	0.259	0.290	0.335	0.348	0.350	0.348	0.367	0.339	0.294	0.283	0.249	(40)	
(41)		taud	2.465	2.452	2.445	2.390	2.415	2.438	2.452	2.397	2.458	2.597	2.540	2.519	(41)	
(42)		Ebn at Noon	858	927	940	919	915	912	909	875	872	876	812	825	(42)	
(43)		Edh at Noon	63	79	94	110	112	110	107	109	93	69	59	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.08	1.96	3.09	4.52	5.59	6.14	7.28	6.04	4.26	2.52	1.23	0.85	(44)	
(45)		RadStd	0.13	0.25	0.33	0.40	0.44	0.55	0.46	0.39	0.44	0.29	0.13	0.10	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page