

DEER PARK, WA, USA

WMO: 727870

Lat: 47.974N

Lon: 117.429W

Elev: 668

StdP: 93.56

Time Zone: -8.00 (NAP)

Period: 01-19

WBAN: 94119

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-16.7	-12.9	-21.0	0.6	-15.2	-17.4	0.9	-11.0	10.6	-2.8	8.9	-2.3	1.6	340	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	33.8	16.8	32.3	16.5	30.2	16.1	18.5	29.6	17.6	29.0	16.7	28.0	3.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	11.5	20.9	13.6	10.6	19.5	12.5	9.8	18.8	54.7	29.5	51.7	28.9	49.1	28.0	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.7	6.7	-22.8	36.9	4.5	1.6	-26.1	38.1	-28.8	39.0	-31.3	40.0	-34.6	41.1		
(5)			-23.1	20.3	4.4	1.5	-26.3	21.4	-28.9	22.3	-31.4	23.1	-34.6	24.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-2.5	-0.9	3.1	7.1	12.0	15.2	19.6	19.0	14.1	7.2	1.6	-2.5	(6)
(7)		DBStd	8.76	4.95	4.31	3.87	3.60	3.96	3.70	3.26	3.14	3.89	4.02	4.33	4.60	(7)
(8)		HDD10.0	1791	387	306	214	102	25	3	0	0	8	105	253	388	(8)
(9)		HDD18.3	3984	646	539	472	336	199	108	25	29	136	345	503	647	(9)
(10)		CDD10.0	986	0	0	1	15	87	158	297	279	131	18	1	0	(10)
(11)		CDD18.3	139	0	0	0	0	2	14	64	50	9	0	0	0	(11)
(12)		CDH23.3	3387	0	0	0	9	114	374	1399	1181	302	7	0	0	(12)
(13)		CDH26.7	1436	0	0	0	1	23	134	654	523	101	1	0	0	(13)
(14)	Wind	WSAvg	2.5	2.1	2.4	2.8	3.0	2.9	2.7	2.5	2.3	2.3	2.3	2.1		(14)
(15)	Precipitation	PrecAvg	622	72	46	73	47	46	50	14	18	25	54	75	86	(15)
(16)		PrecMax	789	195	65	124	77	85	108	39	60	65	185	147	144	(16)
(17)		PrecMin	524	33	16	38	25	30	15	2	3	9	13	51	35	(17)
(18)		PrecStd	73	38	12	26	13	17	27	11	15	13	38	25	31	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	11.0	17.4	24.6	29.1	33.7	36.4	36.2	32.6	23.9	14.0	9.5	(19)
(20)			MCWB	5.2	6.4	9.2	12.7	15.4	17.6	18.0	17.0	16.0	13.5	10.7	7.1	(20)
(21)		2%	DB	5.6	8.1	14.1	21.0	26.4	30.6	34.1	33.7	29.6	20.1	11.7	6.4	(21)
(22)			MCWB	3.8	4.6	7.9	11.2	14.4	16.8	17.1	16.5	15.4	11.7	8.7	4.7	(22)
(23)		5%	DB	4.0	6.5	12.2	17.5	23.9	27.5	32.5	32.0	27.1	17.3	9.6	4.1	(23)
(24)			MCWB	2.8	3.7	6.8	9.4	13.4	15.8	16.8	16.1	14.3	10.4	7.3	3.0	(24)
(25)		10%	DB	2.8	4.8	9.8	15.0	21.3	24.9	30.8	29.7	24.0	14.7	7.9	2.7	(25)
(26)			MCWB	2.0	2.7	5.6	8.0	12.1	14.5	16.4	15.6	13.1	9.2	6.0	1.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	7.3	10.5	13.8	16.7	19.3	20.8	18.6	17.7	14.9	11.4	7.7	(27)
(28)			MCDWB	7.0	9.8	14.8	23.1	26.2	30.3	30.7	30.8	27.7	21.1	12.9	8.7	(28)
(29)		2%	WB	4.0	5.7	8.8	11.6	15.3	17.7	19.1	17.7	15.9	12.8	9.2	5.0	(29)
(30)			MCDWB	5.2	7.5	13.2	18.9	24.0	27.9	29.7	30.1	26.8	18.4	11.0	6.4	(30)
(31)		5%	WB	3.0	4.2	7.4	10.1	14.2	16.4	17.9	16.9	14.9	11.4	7.8	3.3	(31)
(32)			MCDWB	3.9	5.9	10.9	16.7	22.1	25.5	29.2	29.1	25.3	15.8	9.1	4.1	(32)
(33)		10%	WB	2.2	2.9	6.3	8.8	13.0	15.2	17.0	16.2	13.8	10.0	6.4	2.1	(33)
(34)			MCDWB	2.9	4.5	9.5	14.0	19.6	23.6	28.4	28.0	22.9	14.1	7.9	2.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	8.7	10.9	13.2	14.6	15.2	19.2	19.2	17.4	13.2	8.2	6.2	(35)
(36)			MCDBR	6.3	10.3	14.8	17.5	19.1	20.2	22.6	22.8	22.2	17.6	10.1	6.8	(36)
(37)			MCWBR	5.0	7.0	9.3	9.4	8.7	8.6	8.8	8.9	9.9	10.1	7.2	5.5	(37)
(38)		5% WB	MCDWB	5.7	8.8	12.6	15.8	17.1	18.4	20.1	19.6	19.5	14.6	8.6	6.2	(38)
(39)			MCWBR	4.7	6.3	8.4	8.9	8.0	8.3	8.2	8.0	9.0	8.6	6.6	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.278	0.284	0.298	0.322	0.336	0.335	0.335	0.347	0.323	0.305	0.288	0.273	(40)	
(41)		taud	2.472	2.511	2.550	2.472	2.454	2.487	2.491	2.453	2.508	2.552	2.545	2.486	(41)	
(42)		Ebn at Noon	815	893	932	933	926	926	921	894	889	854	799	775	(42)	
(43)		Edh at Noon	63	75	85	101	107	105	103	102	88	72	58	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.00	1.93	2.95	4.44	5.72	6.10	7.27	6.04	4.29	2.52	1.18	0.79	(44)	
(45)		RadStd	0.14	0.26	0.36	0.43	0.46	0.56	0.44	0.41	0.42	0.30	0.14	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+93	+44

Nomenclature: See separate page