

SEATTLE KING COUNTY INTL, WA, USA

WMO: 727935

Lat: 47.530N

Lon: 122.301W

Elev: 18

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24234

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	26.8	29.8	13.0	10.6	32.9	18.9	14.2	35.1	22.4	49.1	19.4	47.7	3.8	140	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	85.9	65.2	82.2	63.9	79.2	62.7	66.8	82.5	65.2	79.3	63.9	76.5	7.4	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.3	81.0	69.5	59.7	76.5	69.1	58.5	73.1	68.5	31.2	82.8	30.0	79.2	29.0	76.2	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Max
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(p)
(4) 18.1	15.8	13.2		21.4	93.0	4.1	3.9	18.4	95.8	16.1	98.1	13.8	100.3	10.9	103.1	
(5)			DB	19.7	69.3	4.1	2.3	16.7	71.0	14.3	72.3	12.0	73.6	9.0	75.3	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.0	43.0	43.9	47.4	51.6	57.8	62.5	67.9	67.8	62.9	53.9	46.7	42.1	(6)
	DBStd	10.54	5.78	5.21	4.95	4.87	5.48	5.26	4.97	4.25	4.57	4.57	5.65	5.66	(7)
	HDD50	940	223	176	111	35	3	0	0	0	0	16	127	249	(8)
	HDD65	4299	681	590	546	402	233	108	23	18	94	345	550	709	(9)
	CDD50	2410	7	6	30	84	245	376	554	553	386	136	28	5	(10)
	CDD65	294	0	0	0	1	10	35	112	106	30	0	0	0	(11)
	CDH74	2222	0	0	2	15	102	309	891	714	187	2	0	0	(12)
	CDH80	580	0	0	0	2	15	87	272	174	30	0	0	0	(13)
(14) Wind	WSAvg	5.7	5.8	5.8	6.5	6.3	5.7	5.9	5.4	5.1	5.0	5.3	5.9	5.9	(14)
(15) Precipitation	PrecAvg	40.0	5.7	3.9	4.3	2.8	2.0	1.7	0.7	0.9	1.7	4.1	6.0	6.5	(15)
	PrecMax	52.3	11.7	9.6	8.3	5.6	3.9	3.0	1.7	3.0	5.1	8.3	14.0	11.7	(16)
	PrecMin	29.8	2.8	0.4	1.4	0.4	0.5	0.3	0.0	0.0	0.2	0.8	2.2	2.6	(17)
	PrecStd	6.3	2.3	2.0	1.8	1.5	1.0	0.8	0.5	0.9	1.2	2.0	2.6	2.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.9	59.8	68.4	75.8	81.9	87.8	91.9	89.6	83.7	71.8	63.1	57.5	(19)
		MCWB	52.0	49.1	52.6	58.1	61.6	65.5	67.5	66.1	63.5	58.4	56.1	52.9	(20)
	2%	DB	55.2	56.3	62.5	68.4	76.7	82.0	87.0	84.4	79.2	66.7	59.3	54.3	(21)
		MCWB	50.8	49.1	51.3	54.4	59.6	62.9	65.6	65.2	62.8	57.0	54.5	49.7	(22)
	5%	DB	53.2	54.2	58.2	64.0	72.2	76.9	82.2	81.3	75.2	63.8	56.8	52.0	(23)
		MCWB	48.9	48.2	49.8	52.6	58.3	60.8	64.2	64.1	61.7	56.1	53.0	48.0	(24)
	10%	DB	51.0	51.9	55.3	60.5	68.0	72.8	78.9	78.1	72.1	61.3	54.7	49.9	(25)
		MCWB	47.4	46.9	48.5	50.9	56.5	59.5	62.9	62.9	60.3	55.1	50.8	46.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.2	53.8	55.4	59.4	64.2	66.8	69.7	68.3	67.0	62.1	58.4	54.5	(27)
		MCDB	57.8	56.6	62.0	71.1	75.1	84.6	87.7	84.8	79.3	67.4	61.2	57.1	(28)
	2%	WB	52.0	51.3	53.2	56.2	61.3	63.9	67.0	66.4	64.4	59.3	55.7	50.9	(29)
		MCDB	54.0	54.4	58.9	65.5	73.7	78.4	83.8	81.5	74.9	64.1	58.6	53.1	(30)
	5%	WB	49.8	49.1	51.2	53.9	59.1	62.0	65.2	65.0	62.7	57.5	53.5	48.7	(31)
		MCDB	51.8	52.5	56.9	61.8	70.5	74.8	80.6	78.5	72.4	61.9	56.0	51.1	(32)
	10%	WB	47.8	47.3	49.6	52.0	57.2	60.2	63.6	63.7	61.3	55.7	51.5	46.5	(33)
		MCDB	50.3	50.9	54.9	58.7	66.5	71.3	76.6	76.0	70.1	60.4	54.1	48.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	11.8	13.1	14.4	15.4	15.7	18.0	17.6	15.7	12.6	10.9	9.5	(35)
		MCDBR	11.7	15.2	17.7	21.3	23.1	23.1	24.1	23.2	21.7	16.5	12.1	10.7	(36)
	5% WB	MCWBR	7.9	9.2	9.2	10.1	10.1	9.4	8.7	8.5	8.7	8.6	8.2	7.7	(37)
		MCWBR	9.1	11.1	14.7	18.1	20.1	20.8	22.3	20.9	18.3	12.6	10.0	9.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.328	0.319	0.327	0.360	0.378	0.368	0.354	0.360	0.348	0.332	0.323	0.333	(40)
		taud	2.486	2.545	2.540	2.419	2.387	2.441	2.499	2.490	2.515	2.563	2.537	2.402	(41)
	Ebn at Noon		239	271	285	284	281	284	287	280	274	262	240	218	(42)
		Edh at Noon	21	24	28	34	36	35	32	31	28	23	19	20	(43)
(44) All-Sky Solar Radiation	RadAvg		322	600	903	1327	1672	1838	2054	1751	1272	720	377	262	(44)
	RadStd		46	79	103	123	135	180	151	116	113	79	50	38	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (60 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page