

QUILLAYUTE, WA, USA

WMO: 727970

Lat: 47.938N

Lon: 124.555W

Elev: 185

StdP: 14.60

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 94240

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	25.5	28.1	14.0	11.3	32.7	19.8	15.0	33.9	23.6	45.2	20.4	45.3	4.1	60	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.7	80.1	63.0	74.5	61.3	70.2	60.1	64.5	75.9	62.8	71.7	61.4	68.3	8.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.8	80.2	65.8	59.6	76.8	64.5	58.6	73.9	63.3	29.6	76.2	28.3	71.4	27.3	68.1	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.8	12.9	20.3	89.9	2.5	4.2	18.5	92.9	17.0	95.4	15.6	97.7	13.8	100.8		
(5)			18.9	68.6	2.8	1.8	16.9	69.9	15.3	71.0	13.8	72.0	11.8	73.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.7	42.3	42.2	44.0	47.0	51.5	55.5	59.3	59.9	57.1	50.6	45.1	41.1		
	DBStd	8.11	5.75	4.99	4.38	4.32	4.43	4.22	3.69	3.62	4.20	4.32	5.38	5.29		
	HDD50	1284	244	222	192	109	32	2	0	0	1	44	161	277		
	HDD65	5610	705	640	651	539	418	289	183	165	240	445	596	739		
	CDD50	1171	4	2	6	19	80	167	289	308	214	63	16	3		
	CDD65	23	0	0	0	0	1	5	7	8	2	0	0	0		
	CDH74	519	0	0	1	7	36	99	134	155	84	3	0	0		
	CDH80	150	0	0	0	0	9	35	40	50	16	0	0	0		
(14) Wind	WSAvg	5.3	6.0	6.1	6.3	5.7	5.1	4.8	4.6	4.2	4.1	4.8	5.8	6.0		
(15) Precipitation	PrecAvg	102.4	14.4	11.0	12.0	7.9	4.9	3.3	2.0	2.4	4.7	10.6	14.9	14.4		
	PrecMax	131.7	24.0	26.2	23.2	14.4	12.4	8.8	11.0	15.1	12.8	27.2	29.1	27.8		
	PrecMin	60.2	1.2	0.9	1.9	1.8	0.7	0.2	0.0	0.2	0.1	1.4	4.4	3.6		
	PrecStd	16.4	5.2	5.1	4.6	3.2	2.8	1.9	2.0	2.7	3.0	5.7	5.8	5.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.7	60.1	65.4	72.4	79.1	85.1	85.1	86.4	82.5	71.0	59.4	56.3		
		MCWB	50.3	47.9	50.8	56.5	59.4	63.1	67.1	65.2	62.7	58.1	54.0	51.5		
	2%	DB	53.8	54.5	58.1	63.5	70.2	74.0	77.1	78.0	75.5	65.1	56.5	53.1		
		MCWB	50.7	48.0	49.5	51.9	56.2	61.3	63.2	63.6	60.6	54.9	53.4	50.5		
	5%	DB	52.0	51.8	53.6	58.5	63.9	67.0	71.1	71.9	70.0	60.8	55.0	50.8		
		MCWB	49.6	48.1	48.6	50.4	55.0	58.5	61.4	61.7	60.1	55.3	52.8	48.9		
	10%	DB	50.3	49.9	51.1	54.7	59.7	63.2	67.4	68.2	65.8	58.3	53.5	49.3		
		MCWB	48.1	46.9	47.8	48.8	53.4	56.7	59.9	60.4	58.5	54.6	51.7	47.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	53.3	53.8	58.0	60.8	65.6	67.8	66.7	65.6	60.9	56.5	53.7		
		MCDB	54.5	54.9	58.9	69.3	72.7	80.1	82.5	80.6	76.2	65.9	57.5	54.5		
	2%	WB	51.9	50.9	51.4	53.7	58.2	62.0	64.2	64.2	63.0	58.5	54.9	51.3		
		MCDB	52.8	52.3	54.2	60.0	67.3	73.0	74.9	75.3	70.9	61.3	55.8	52.0		
	5%	WB	50.5	49.1	50.2	51.5	55.7	59.3	62.2	62.5	61.4	56.7	53.5	49.8		
		MCDB	51.4	50.7	52.9	55.9	62.2	65.9	70.1	70.7	67.0	59.2	54.4	50.4		
	10%	WB	48.6	47.5	48.3	50.1	53.9	57.3	60.4	61.1	59.9	55.0	51.6	47.8		
		MCDB	49.8	49.4	50.9	53.8	58.6	62.2	66.2	67.4	64.7	57.6	52.9	48.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.1	12.8	13.5	14.9	15.4	14.7	15.4	16.7	17.7	15.4	12.3	10.8		
		MCDBR	13.6	16.8	18.9	23.6	26.0	24.6	26.2	26.4	27.6	20.8	13.5	11.5		
		MCWBR	10.2	11.3	12.2	14.0	14.7	14.1	14.3	14.3	16.1	13.6	10.4	9.8		
	5% WB	MCDBR	9.3	11.6	15.3	18.2	20.1	21.0	21.4	22.2	20.7	15.8	9.6	9.3		
		MCWBR	8.3	9.1	10.7	11.7	12.2	12.5	12.2	12.8	13.1	11.8	8.7	8.9		
(40) Clear-Sky Solar Irradiance	taub		0.317	0.316	0.332	0.359	0.381	0.355	0.345	0.348	0.340	0.334	0.322	0.311		
	taud		2.526	2.555	2.521	2.423	2.376	2.478	2.541	2.533	2.546	2.551	2.518	2.508		
	Ebn at Noon		244	272	283	284	280	288	289	284	277	260	238	230		
	Edh at Noon		20	23	28	34	37	34	31	30	27	23	20	18		
(44) All-Sky Solar Radiation	RadAvg		305	592	907	1361	1664	1820	1847	1567	1225	712	372	256		
	RadStd		42	76	98	119	132	150	128	125	97	83	53	33		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (67 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page