

QUILLAYUTE, WA, USA

WMO: 727970

Lat: 47.938N

Lon: 124.555W

Elev: 56

StdP: 100.65

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 94240

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.6	-2.2	-10.0	1.6	0.4	-6.8	2.1	1.1	10.6	7.4	9.1	7.4	1.8	60	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.3	26.7	17.2	23.6	16.3	21.2	15.6	18.1	24.4	17.1	22.1	16.4	20.2	3.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	11.5	18.8	15.4	11.0	18.0	14.8	10.6	17.4	51.0	24.6	48.0	21.9	45.6	20.0	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.1	5.8	-6.5	32.2	1.4	2.3	-7.5	33.9	-8.3	35.2	-9.1	36.5	-10.1	38.2		
(5)			-7.3	20.3	1.5	1.0	-8.4	21.1	-9.3	21.7	-10.1	22.2	-11.2	23.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	5.7	5.6	6.7	8.4	10.9	13.1	15.2	15.5	13.9	10.4	7.3	5.1		
	DBStd	4.51	3.20	2.77	2.43	2.40	2.46	2.34	2.05	2.01	2.33	2.40	2.99	2.94		
	HDD10.0	713	136	123	107	61	18	1	0	0	1	24	89	154		
	HDD18.3	3117	392	356	362	299	232	161	102	92	133	247	331	411		
	CDD10.0	651	2	1	3	11	44	93	161	171	119	35	9	2		
	CDD18.3	13	0	0	0	0	1	3	4	4	1	0	0	0		
	CDH23.3	288	0	0	1	4	20	55	74	86	47	2	0	0		
	CDH26.7	83	0	0	0	0	5	19	22	28	9	0	0	0		
(14) Wind	WSAvg	2.4	2.7	2.7	2.8	2.6	2.3	2.2	2.1	1.9	1.8	2.1	2.6	2.7		
(15) Precipitation	PrecAvg	2601	366	279	305	200	125	84	52	62	120	268	378	366		
	PrecMax	3344	610	666	590	366	316	224	280	383	326	690	740	707		
	PrecMin	1530	31	22	47	45	17	5	0	4	3	35	112	92		
	PrecStd	416	132	129	116	82	71	47	52	69	75	145	147	130		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	15.6	18.6	22.4	26.2	29.5	29.5	30.2	28.1	21.7	15.2	13.5		
		MCWB	10.2	8.9	10.4	13.6	15.2	17.3	19.5	18.4	17.0	14.5	12.2	10.9		
	2%	DB	12.1	12.5	14.5	17.5	21.2	23.3	25.1	25.6	24.2	18.4	13.6	11.7		
		MCWB	10.4	8.9	9.7	11.1	13.4	16.3	17.3	17.6	15.9	12.7	11.9	10.3		
	5%	DB	11.1	11.0	12.0	14.7	17.7	19.4	21.7	22.1	21.1	16.0	12.8	10.4		
		MCWB	9.8	8.9	9.2	10.2	12.8	14.7	16.3	16.5	15.6	12.9	11.5	9.4		
	10%	DB	10.2	9.9	10.6	12.6	15.4	17.3	19.7	20.1	18.8	14.6	12.0	9.6		
		MCWB	8.9	8.3	8.8	9.3	11.9	13.7	15.5	15.8	14.7	12.5	10.9	8.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	11.8	12.1	14.4	16.0	18.7	19.9	19.3	18.6	16.1	13.6	12.0		
		MCDB	12.5	12.7	14.9	20.7	22.6	26.7	28.1	27.0	24.6	18.8	14.1	12.5		
	2%	WB	11.1	10.5	10.8	12.0	14.5	16.6	17.9	17.9	17.2	14.7	12.7	10.7		
		MCDB	11.5	11.3	12.3	15.6	19.6	22.8	23.8	24.0	21.6	16.3	13.2	11.1		
	5%	WB	10.3	9.5	10.1	10.8	13.2	15.2	16.8	16.9	16.3	13.7	11.9	9.9		
		MCDB	10.8	10.4	11.6	13.3	16.8	18.9	21.2	21.5	19.5	15.1	12.5	10.2		
	10%	WB	9.2	8.6	9.1	10.1	12.2	14.1	15.8	16.2	15.5	12.8	10.9	8.8		
		MCDB	9.9	9.7	10.5	12.1	14.8	16.8	19.0	19.7	18.1	14.2	11.6	9.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	7.1	7.5	8.3	8.5	8.2	8.6	9.3	9.9	8.5	6.8	6.0		
		MCDBR	7.6	9.3	10.5	13.1	14.4	13.7	14.6	14.7	15.3	11.6	7.5	6.4		
	5% WB	MCWBR	5.7	6.3	6.8	7.8	8.2	7.8	8.0	7.9	8.9	7.6	5.8	5.4		
		MCWBR	5.2	6.5	8.5	10.1	11.2	11.7	11.9	12.3	11.5	8.8	5.3	5.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.317	0.316	0.332	0.359	0.381	0.355	0.345	0.348	0.340	0.334	0.322	0.311		
		taud	2.526	2.555	2.521	2.423	2.376	2.478	2.541	2.533	2.546	2.551	2.518	2.508		
	Ebn at Noon	Ebn at Noon	768	856	892	894	882	907	911	895	872	820	751	724		
		Edh at Noon	62	73	88	107	116	106	98	95	85	73	62	56		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.96	1.86	2.86	4.29	5.25	5.74	5.82	4.94	3.86	2.24	1.17	0.81		
	RadStd	RadStd	0.13	0.24	0.31	0.38	0.42	0.47	0.40	0.39	0.30	0.26	0.17	0.10		

Historical Trends

		Heating		Cooling		Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (67 neighbors)		(m)								
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page