

NANISIVIK AP, NU, Canada

WMO: 729140

Lat: 72.980N

Lon: 84.620W

Elev: 2106

StdP: 13.61

Time Zone: -5.00 (NAE)

Period: 00-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-38.6	-35.3	-46.4	0.4	-38.1	-43.5	0.5	-35.4	40.3	-9.7	35.4	-13.1	7.0	140	1.118

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	56.2	49.3	53.6	47.6	51.1	45.9	51.2	54.0	48.3	52.7	46.1	50.6	10.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.7	57.0	52.9	45.6	48.8	49.4	43.0	44.1	47.5	21.7	54.0	19.9	52.8	18.8	50.7	57.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.6	29.1	24.5	-42.7	58.8	3.9	4.8	-45.5	62.2	-47.8	65.0	-50.0	67.7	-52.8	71.2		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-17.9	-18.2	-15.3	-1.7	15.3	32.0	43.1	37.9	24.5	12.4	-4.9	-11.2		
	DBStd	23.33	8.18	10.79	11.76	8.87	8.64	6.06	7.04	7.76	6.85	8.34	9.50	11.34		
	HDD50	15293	2105	1908	2025	1551	1075	540	234	380	764	1167	1646	1898		
	HDD65	20743	2570	2328	2490	2001	1540	990	680	839	1214	1632	2096	2363		
	CDD50	25	0	0	0	0	0	0	19	6	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	10.1	8.9	9.2	10.9	10.5	9.5	9.9	11.0	10.7	9.2	11.6	10.5	8.8		
	PrecAvg	8.1	0.2	0.2	0.4	0.4	0.6	0.8	1.4	1.5	1.0	0.9	0.4	0.3		
	PrecMax	14.6	0.5	0.6	1.6	1.7	1.7	1.5	3.6	3.0	2.4	2.5	1.2	0.8		
(15) Precipitation	PrecMin	4.6	0.0	0.1	0.0	0.0	0.1	0.0	0.2	0.3	0.3	0.3	0.0	0.0		
	PrecStd	2.3	0.1	0.1	0.3	0.4	0.4	0.5	0.7	0.7	0.5	0.6	0.2	0.2		
	DB	9.0	23.4	19.9	25.6	34.3	52.1	60.6	57.7	41.4	31.6	19.6	25.8			
	MCWB	7.0	22.5	18.2	21.0	29.9	44.7	53.5	50.5	34.6	31.0	18.6	22.5			
	2% DB	3.2	5.6	14.4	19.1	31.9	47.6	57.5	54.0	38.2	27.7	15.7	16.4			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	1.5	3.9	12.6	16.5	28.6	42.6	50.2	50.0	35.0	26.4	15.1	14.9			
	5% DB	-1.1	0.4	5.2	13.6	29.2	42.9	55.6	51.6	36.0	25.7	12.1	9.4			
	MCWB	-2.4	-0.8	4.0	11.8	26.8	39.0	48.6	47.7	34.1	24.8	11.2	7.4			
	10% DB	-6.0	-4.4	-0.3	10.2	26.9	39.9	53.3	49.3	33.3	23.8	9.1	4.8			
	MCWB	-7.2	-5.5	-1.3	8.6	24.9	36.6	46.6	45.4	31.9	23.1	8.1	3.7			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	6.5	23.5	18.5	21.6	30.9	45.9	54.9	52.9	36.9	31.1	18.9	23.5			
	MCDB	8.3	24.7	20.0	25.0	33.1	50.3	58.3	54.7	38.2	31.5	19.7	25.7			
	2% WB	0.2	4.3	13.0	16.3	29.1	42.7	53.1	50.9	35.5	26.9	15.0	15.6			
	MCDB	1.4	5.9	14.6	18.7	31.3	48.0	56.3	53.2	37.5	27.3	15.6	17.0			
	5% WB	-3.0	-0.4	4.8	12.0	27.1	39.5	49.2	48.5	34.0	25.1	11.4	7.2			
(33) Mean Daily Temperature Range	MCDB	-1.8	0.7	5.8	13.5	29.1	42.5	53.8	52.2	36.0	25.5	11.9	9.0			
	10% WB	-7.7	-5.2	-0.7	8.8	25.0	37.1	47.0	45.7	32.2	23.1	8.1	3.7			
	MCDB	-6.6	-4.4	0.4	9.9	26.6	39.6	52.2	48.7	33.3	23.9	8.9	4.9			
	5% DB	8.4	8.5	8.8	8.5	7.5	6.3	7.5	6.9	5.1	6.9	8.4	8.5			
	MCDBR	12.3	11.7	12.6	9.6	8.9	8.1	8.8	7.9	7.1	7.3	10.1	11.1			
(36) Clear-Sky Solar Irradiance	MCWBR	10.5	11.6	12.0	8.3	7.5	5.9	5.3	5.2	5.4	6.9	9.7	10.1			
	5% WB	11.6	12.1	13.3	9.2	9.0	7.7	8.9	8.4	6.2	7.1	10.2	11.4			
	MCDBR	10.7	11.6	12.6	8.2	8.0	5.7	5.9	5.4	5.0	6.9	10.0	10.6			
	taub	N/A	0.152	0.219	0.271	0.286	0.284	0.297	0.282	0.239	0.160	N/A	N/A			
	taud	N/A	1.926	2.211	2.135	2.205	2.429	2.515	2.544	2.431	1.935	N/A	N/A			
(42) All-Sky Solar Radiation	Ebn at Noon	0	152	245	266	279	286	277	267	241	133	0	0			
	Edh at Noon	0	8	19	31	34	28	25	21	16	7	0	0			
	RadAvg	0	52	478	1308	1966	2005	1575	1019	410	98	0	0			
(45)	RadStd	0	5	31	63	114	218	152	127	62	15	0	0			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page