

NICHOLSON PENINSULA, NT, Canada

WMO: 729560

Lat: 69.930N

Lon: 128.970W

Elev: 291

StdP: 14.54

Time Zone: -7.00 (NAM)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.8	-38.7	-39.1	0.6	-32.2	-37.5	0.7	-31.4	36.7	1.9	33.5	8.3	8.9	250	1.093

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	67.7	57.5	63.6	55.0	59.9	53.0	58.3	65.7	55.6	62.9	53.1	59.6	9.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.3	63.3	63.1	51.5	57.0	59.6	48.8	51.7	56.3	25.4	66.3	23.7	63.1	22.2	59.7	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.3	27.9	24.9	-43.4	73.6	5.0	4.7	-46.9	77.0	-49.8	79.7	-52.6	82.4	-56.2	85.8		
			-35.8	61.4	1.3	3.1	-36.7	63.6	-37.5	65.5	-38.2	67.2	-39.1	69.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-19.3	-18.6	-12.8	2.2	21.1	40.1	46.7	44.1	34.5	16.8	-8.0	-13.1
	DBStd	26.92	12.13	14.37	11.54	12.35	9.94	9.15	9.23	7.15	7.32	11.13	11.84	12.33
	HDD50	14253	2149	1919	1947	1434	895	323	181	213	467	1029	1739	1957
	HDD65	19596	2614	2339	2412	1884	1360	747	571	648	916	1494	2189	2422
	CDD50	136	0	0	0	0	0	26	78	30	2	0	0	0
	CDD65	3	0	0	0	0	0	0	3	0	0	0	0	0
	CDH74	12	0	0	0	0	0	1	11	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.0	11.8	12.4	10.1	12.3	13.2	13.2	11.7	13.1	13.6	13.3	9.7	9.7
Precipitation	PrecAvg	4.2	0.1	0.1	0.1	0.1	0.2	0.4	0.8	1.2	0.6	0.4	0.1	0.1
	PrecMax	7.2	0.6	0.6	0.6	0.3	0.5	1.8	2.1	2.4	1.4	1.0	0.4	0.5
	PrecMin	2.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0
	PrecStd	1.2	0.2	0.2	0.1	0.1	0.2	0.4	0.5	0.7	0.4	0.3	0.1	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	20.0	21.6	33.7	49.5	70.7	75.3	68.9	57.2	38.5	21.6	20.3
		MCWB	18.2	19.3	20.6	32.2	44.3	56.9	62.0	60.1	51.4	36.2	20.8	19.5
	2%	DB	12.4	16.1	15.3	27.8	42.2	64.0	69.4	63.2	50.7	34.6	19.0	15.5
		MCWB	11.9	15.5	14.7	27.1	39.7	53.1	57.9	56.2	46.5	33.3	18.4	14.5
	5%	DB	3.7	10.4	9.5	22.9	37.6	60.8	66.2	59.3	47.0	32.0	14.5	11.8
		MCWB	3.1	9.8	8.9	22.3	36.1	51.8	56.9	53.4	43.6	31.3	13.8	11.1
	10%	DB	-1.3	3.7	3.9	19.2	34.0	56.2	61.9	55.3	43.7	29.7	8.1	5.9
		MCWB	-1.9	3.2	3.3	18.5	33.1	49.0	54.7	50.7	41.3	29.0	7.3	5.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.7	19.9	20.7	32.3	45.1	57.4	64.3	60.4	51.5	36.7	21.0	19.8
		MCDB	19.1	20.4	21.4	33.5	48.8	66.9	74.9	67.6	56.5	37.9	21.4	20.0
	2%	WB	12.5	16.3	14.8	27.1	39.8	54.3	59.4	56.9	47.1	33.6	18.3	14.9
		MCDB	13.1	16.8	15.4	27.7	42.2	63.1	67.1	62.5	50.3	34.4	18.9	15.6
	5%	WB	4.1	11.2	9.2	22.2	36.2	52.2	57.2	53.6	44.0	31.3	13.8	11.2
		MCDB	4.6	11.8	9.9	22.8	37.7	60.4	65.0	58.4	46.7	32.1	14.7	11.9
	10%	WB	-0.5	5.0	3.6	18.5	33.1	49.0	54.6	50.8	41.4	29.1	7.6	5.7
		MCDB	0.3	5.6	4.2	19.1	34.1	56.2	61.7	54.9	43.3	29.6	8.2	6.4
Mean Daily Temperature Range	5% DB	MDBR	9.4	9.8	10.0	10.3	9.1	12.5	12.2	10.3	7.2	6.2	7.6	8.9
		MCDBR	16.2	15.4	14.6	13.0	13.2	20.9	18.7	16.6	14.0	6.4	10.2	14.6
		MCWBR	15.9	15.3	14.4	12.7	10.9	12.9	10.7	10.6	10.3	5.8	10.3	14.4
	5% WB	MCDBR	16.6	15.7	14.6	13.0	13.3	20.1	17.2	15.6	13.5	6.1	10.2	14.4
		MCWBR	16.3	15.5	14.4	12.6	11.1	13.4	11.0	10.9	10.4	5.6	10.3	14.3
Clear-Sky Solar Irradiance	taub	N/A	0.196	0.243	0.299	0.330	0.327	0.336	0.320	0.290	0.216	N/A	N/A	
	taud	N/A	2.069	2.201	2.113	2.167	2.383	2.468	2.540	2.541	2.181	N/A	N/A	
	Ebn at Noon	0	181	249	262	267	275	268	260	237	167	0	0	
	Edh at Noon	0	12	22	34	37	31	28	23	17	10	0	0	
All-Sky Solar Radiation	RadAvg	0	124	628	1397	1871	1992	1666	1021	523	150	0	0	
	RadStd	0	10	28	60	154	162	167	118	49	16	0	0	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	+1.19	+2.25	+2.88	N/A	N/A	N/A	-491	-468	N/A	N/A

Nomenclature: See separate page