

GLADMAN POINT, NU, Canada

WMO: 729720

Lat: 68.670N

Lon: 97.800W

Elev: 46

StdP: 14.67

Time Zone: -7.00 (NAM)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-48.5	-45.6	-40.6	0.5	-33.7	-39.3	0.6	-33.2	35.0	-20.2	29.8	-23.2	6.1	N/A	1.162

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	59.9	53.4	56.2	50.6	52.7	48.3	53.9	59.3	51.0	55.6	48.4	52.3	9.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
50.4	54.2	57.3	47.8	49.3	53.3	45.5	45.0	50.9	22.5	59.9	20.8	55.7	19.4	52.4	61.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.9	28.0	24.5	-51.0	65.6	4.1	4.2	-53.9	68.6	-56.2	71.1	-58.5	73.4	-61.5	76.5		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	-31.9	-30.6	-23.0	-7.4	13.9	34.2	45.9	40.5	31.7	12.7	-11.4	-22.8		
	DBStd	29.39	9.81	10.56	10.38	11.90	10.06	7.15	6.25	5.24	6.17	11.43	13.44	11.00		
	HDD50	16641	2540	2257	2262	1721	1118	477	162	302	548	1157	1841	2256		
	HDD65	22075	3005	2677	2727	2171	1583	925	594	761	998	1622	2291	2721		
	CDD50	41	0	0	0	0	0	2	33	6	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.2	11.3	11.3	12.4	11.8	11.8	12.0	11.5	13.0	13.3	14.4	12.4	11.4		
	PrecAvg	4.9	0.1	0.1	0.1	0.2	0.4	0.4	1.0	1.1	0.8	0.6	0.2	0.1		
(15) Precipitation	PrecMax	7.9	0.3	0.4	0.4	0.9	1.5	1.4	2.4	2.8	1.7	1.4	0.6	0.6		
	PrecMin	2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.2	0.1	0.0	0.0		
	PrecStd	1.2	0.1	0.1	0.1	0.2	0.3	0.3	0.6	0.6	0.4	0.3	0.2	0.1		
	PrecStd	1.2	0.1	0.1	0.1	0.2	0.3	0.3	0.6	0.6	0.4	0.3	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	7.4	7.6	9.8	25.9	33.8	58.7	67.2	62.0	49.2	36.1	23.8	17.2			
	0.4% MCWB	7.0	7.1	9.2	25.0	32.7	51.7	56.3	56.1	46.9	35.3	22.8	16.6			
	2% DB	-2.9	-2.4	5.4	21.6	32.6	52.2	61.7	55.7	46.4	32.9	19.3	11.8			
	2% MCWB	-3.4	-2.8	4.9	21.1	32.0	47.7	54.1	50.6	44.5	32.6	18.8	11.5			
	5% DB	-9.9	-9.3	0.9	15.6	31.1	48.2	58.8	51.8	43.7	31.1	15.6	1.3			
	5% MCWB	-10.4	-9.8	0.3	14.9	30.7	44.8	52.2	47.8	42.4	30.8	15.1	0.8			
	10% DB	-15.8	-15.2	-5.7	11.4	29.1	44.5	55.9	48.5	40.4	28.6	10.0	-6.9			
	10% MCWB	-16.1	-15.7	-6.2	10.9	28.6	42.1	50.4	45.4	39.2	28.1	9.5	-7.4			
	0.4% WB	12.2	8.2	9.2	25.3	33.2	52.3	58.2	56.8	47.7	35.5	23.8	19.0			
	0.4% MCDB	13.4	8.5	9.6	25.9	33.4	58.0	65.9	61.5	48.9	35.8	24.3	19.1			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	-0.6	2.4	4.9	21.4	32.2	47.9	55.1	51.7	44.8	32.7	19.3	12.4			
	2% MCDB	-0.1	2.8	5.1	22.1	32.7	51.7	60.9	54.5	46.0	32.9	19.8	12.9			
	5% WB	-6.9	-4.1	1.5	15.5	30.8	44.7	52.7	48.2	42.4	30.9	15.5	3.9			
	5% MCDB	-6.6	-3.6	2.1	16.1	31.2	48.0	58.1	51.4	44.0	31.1	16.2	4.4			
	10% WB	-11.2	-9.3	-5.1	11.5	28.7	42.0	50.6	45.6	39.2	28.3	10.6	-5.0			
	10% MCDB	-10.9	-8.7	-4.6	12.1	29.1	44.5	55.5	48.4	40.3	28.7	11.2	-4.5			
(35) Mean Daily Temperature Range	MDBR	10.4	10.5	11.5	13.5	10.7	7.5	10.2	8.3	5.5	8.8	9.7	9.9			
	5% DB	20.9	17.2	16.8	14.6	8.1	13.2	14.9	13.9	8.4	6.4	11.6	15.6			
	5% WB	18.2	14.9	15.1	14.4	8.2	10.3	9.6	9.8	7.1	6.3	11.4	14.5			
	MCDBR	21.2	15.9	15.5	14.2	8.3	12.5	14.1	12.5	8.4	6.5	11.1	13.9			
	MCWBR	20.8	15.9	15.1	14.0	8.4	10.0	10.3	9.6	7.3	6.4	10.9	13.8			
	MCWBR	20.8	15.9	15.1	14.0	8.4	10.0	10.3	9.6	7.3	6.4	10.9	13.8			
(40) Clear-Sky Solar Irradiance	taub	0.153	0.210	0.243	0.312	0.332	0.337	0.379	0.339	0.312	0.235	0.159	N/A			
	taud	1.889	2.062	2.224	2.051	2.081	2.300	2.293	2.454	2.406	2.136	1.896	N/A			
	Ebn at Noon	31	187	256	259	268	272	254	254	228	168	22	0			
	Edh at Noon	2	14	23	37	41	34	34	26	20	13	2	0			
	Edh at Noon	2	14	23	37	41	34	34	26	20	13	2	0			
(44) All-Sky Solar Radiation	RadAvg	7	129	612	1333	1957	2013	1714	1123	536	167	22	0			
	RadStd	1	14	30	65	152	149	126	91	52	25	2	0			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+1.08	+1.75	N/A	N/A	N/A	N/A	-419	-412	N/A	N/A	N/A

Nomenclature: See separate page