

SABLE ISLAND, NS, CanadaWMO: **730250**Lat: **43.9314N**Lon: **60.0083W**Elev: **205**StdP: **14.59**Time Zone: **-4.00 (NAA)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.2	19.2	7.1	8.0	18.0	9.5	9.0	20.1	46.9	32.7	42.6	31.6	21.5	300	0.771

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	71.8	68.2	70.2	67.1	68.9	66.0	69.3	70.9	67.9	69.7	66.6	68.4	12.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.5	105.5	70.5	67.1	100.2	69.2	65.7	95.7	68.0	33.4	71.2	32.2	69.8	31.2	68.6	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.3	34.1	29.9	12.1	74.2	3.6	2.0	9.5	75.6	7.4	76.7	5.4	77.8	2.8	79.3		
(5)			10.8	70.8	3.4	1.6	8.4	72.0	6.4	72.9	4.5	73.9	2.1	75.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.9	32.8	31.2	33.9	39.4	45.4	52.6	61.2	65.3	61.8	54.0	46.0	38.2	(6)
(7)		DBStd	12.56	6.80	6.28	5.26	4.01	3.69	3.89	3.40	2.90	4.41	5.22	5.92	6.40	(7)
(8)		HDD50	2579	534	526	499	318	148	18	0	0	0	22	148	366	(8)
(9)		HDD65	6668	999	946	964	768	607	373	124	30	114	342	571	830	(9)
(10)		CDD50	1448	0	0	0	0	7	94	348	474	353	145	26	1	(10)
(11)		CDD65	64	0	0	0	0	0	0	8	40	16	0	0	0	(11)
(12)		CDH74	5	0	0	0	0	0	0	0	3	2	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	15.3	19.2	18.9	17.8	15.9	13.2	12.1	10.9	10.9	13.2	16.0	17.2	18.9	(14)
(15)	Precipitation	PrecAvg	53.3	5.2	4.3	4.8	3.8	3.7	3.8	4.1	4.1	4.8	5.3	5.5	(15)	
(16)		PrecMax	72.4	12.4	7.3	8.5	11.0	7.6	10.6	7.8	10.2	11.8	10.5	8.8	11.8	(16)
(17)		PrecMin	26.6	0.4	1.5	1.1	1.0	0.4	1.3	0.2	0.9	0.7	0.7	1.3	2.2	(17)
(18)		PrecStd	9.2	2.0	1.6	1.8	1.6	1.8	1.8	1.9	1.9	2.4	2.4	1.9	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	48.1	47.7	50.7	57.0	64.0	71.8	74.2	73.4	67.2	60.9	54.5	(19)
(20)			MCWB	49.9	47.5	46.3	48.8	53.6	60.6	67.5	70.5	70.5	64.1	59.1	53.6	(20)
(21)		2%	DB	47.6	45.1	45.5	48.6	54.5	61.6	69.4	72.4	71.0	65.0	58.5	52.2	(21)
(22)			MCWB	46.9	44.3	44.3	47.0	52.0	58.7	66.1	68.8	67.7	62.0	56.7	51.2	(22)
(23)		5%	DB	45.0	42.6	43.8	47.0	52.8	59.7	67.7	71.0	69.4	63.3	56.6	50.2	(23)
(24)			MCWB	44.1	41.5	42.4	45.3	50.7	57.2	64.9	67.7	66.4	60.4	54.9	49.0	(24)
(25)		10%	DB	42.6	40.1	41.6	45.4	51.1	58.1	66.3	69.8	67.9	61.6	54.8	47.6	(25)
(26)			MCWB	41.2	38.8	40.1	43.5	49.0	55.8	63.9	66.8	64.8	58.7	53.3	46.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.2	46.8	46.7	49.7	54.9	61.7	68.8	71.6	71.0	64.7	59.6	53.9	(27)
(28)			MCDB	50.4	47.1	47.0	50.3	56.4	63.0	70.9	73.2	72.8	66.2	60.6	54.3	(28)
(29)		2%	WB	47.1	43.8	44.5	47.5	52.9	59.6	67.0	69.9	68.6	62.8	57.1	51.6	(29)
(30)			MCDB	47.5	44.3	45.0	48.3	53.9	60.9	68.7	71.5	70.2	64.2	58.1	52.1	(30)
(31)		5%	WB	44.5	41.3	42.6	46.0	51.1	57.9	65.7	68.6	66.9	60.9	55.3	49.1	(31)
(32)			MCDB	45.0	42.0	43.5	46.8	52.1	59.1	67.2	70.3	68.7	62.5	56.3	49.9	(32)
(33)		10%	WB	41.6	38.6	40.2	44.0	49.4	56.4	64.4	67.5	65.2	59.1	53.4	46.2	(33)
(34)			MCDB	42.5	39.6	41.4	45.1	50.6	57.7	65.8	69.2	67.1	61.1	54.6	47.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.9	9.0	8.1	7.8	8.0	7.9	7.5	7.5	8.1	7.5	8.1	8.7	(35)
(36)			MCDBR	13.4	12.7	11.2	9.3	9.7	8.8	8.8	8.5	8.4	8.5	9.8	11.6	(36)
(37)			MCWBR	15.0	13.5	10.9	8.5	7.6	6.3	6.2	6.1	6.7	8.1	10.8	13.3	(37)
(38)		5% WB	MCDBR	13.5	12.3	10.6	9.0	9.0	7.5	7.7	7.6	7.6	8.0	9.9	11.9	(38)
(39)			MCWBR	15.1	13.6	11.2	9.1	7.8	6.2	5.9	6.0	6.7	8.6	11.0	13.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.317	0.309	0.327	0.353	0.369	0.387	0.409	0.383	0.357	0.343	0.322	0.305	(40)	
(41)		taud	2.482	2.551	2.514	2.471	2.467	2.439	2.425	2.482	2.534	2.552	2.562	2.547	(41)	
(42)		Ebn at Noon	257	284	291	290	286	280	272	277	277	266	255	252	(42)	
(43)		Edh at Noon	23	25	29	33	34	36	36	32	29	25	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	377	636	1070	1427	1650	1758	1684	1585	1331	836	489	325	(44)	
(45)		RadStd	36	56	99	111	139	162	138	126	91	67	56	27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)			N/A	N/A	N/A	+1.15	N/A	N/A	N/A	N/A	+32

Nomenclature: See separate page