

NORTHEAST MARGAREE, NS, Canada

WMO: 730270

Lat: 46.369N

Lon: 60.976W

Elev: 177

StdP: 14.60

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.6	2.3	-7.5	3.7	-1.7	-2.3	4.9	4.7	19.1	32.3	16.8	31.6	1.8	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	82.2	68.8	79.5	67.4	76.8	66.2	71.8	79.0	70.1	76.2	68.4	73.8	7.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	108.2	75.3	67.9	103.1	74.1	66.3	97.6	72.4	35.6	79.0	34.2	76.1	32.8	74.0	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.8	12.6	10.6	DB	-11.1	87.8	6.6	3.0	-15.8	90.0	-19.7	91.7	-23.3	93.4	-28.1	95.6	(4)
(5)			WB	-11.1	74.3	6.4	1.6	-15.7	75.4	-19.4	76.4	-23.0	77.3	-27.6	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.8	22.9	21.0	26.9	37.2	47.0	55.7	64.7	63.9	56.4	47.2	38.8	29.8
	DBStd	16.59	9.00	9.88	9.07	7.01	6.59	6.89	5.57	5.31	6.71	6.50	7.48	7.58
	HDD50	4042	841	812	716	388	140	22	0	0	15	133	348	627
	HDD65	8259	1305	1232	1181	833	559	290	76	84	269	551	787	1092
	CDD50	1399	1	0	0	5	47	192	456	432	208	48	10	0
	CDD65	141	0	0	0	0	1	10	67	50	12	1	0	0
	CDH74	1247	0	0	0	1	23	127	584	431	79	2	0	0
	CDH80	196	0	0	0	0	2	14	100	71	9	0	0	0
Wind	WSAvg	4.3	4.9	4.8	5.3	4.8	4.2	4.0	3.6	3.2	3.6	3.8	4.8	4.5
Precipitation	PrecAvg	58.3	5.7	4.8	4.5	4.3	3.7	3.9	3.4	4.3	4.7	6.3	5.8	6.9
	PrecMax	68.5	8.4	7.4	8.2	7.3	6.7	8.0	6.3	10.3	11.5	10.4	10.5	16.1
	PrecMin	42.2	2.3	1.8	1.9	2.0	1.6	1.7	1.5	1.9	1.3	2.6	3.7	3.3
	PrecStd	5.6	1.5	1.5	1.7	1.4	1.3	1.6	1.2	1.7	2.6	2.1	1.7	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	49.4	53.1	66.2	77.1	82.0	86.3	85.8	80.7	71.6	64.4	56.0
		MCWB	52.0	47.3	46.2	55.5	62.1	65.9	72.2	70.0	69.8	64.4	60.5	53.9
	2%	DB	45.9	44.3	47.8	58.7	71.1	77.9	83.0	81.6	76.1	66.4	59.8	50.2
		MCWB	44.6	41.0	43.6	51.5	57.2	64.5	69.8	68.8	67.3	60.8	57.0	48.2
	5%	DB	39.4	39.5	43.1	53.8	65.6	74.0	80.1	78.7	72.1	63.1	56.1	44.9
		MCWB	37.3	37.0	38.9	48.2	54.6	62.2	67.9	66.9	65.2	58.7	53.3	42.9
	10%	DB	35.3	35.3	39.4	49.6	61.0	70.1	77.2	75.9	69.2	59.4	51.6	40.3
		MCWB	33.5	33.2	35.4	44.6	52.1	61.2	66.7	66.1	63.6	55.1	48.8	38.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.7	47.9	49.2	58.9	65.1	71.0	74.2	73.4	71.8	66.4	61.1	54.2
		MCDB	53.7	48.9	51.7	65.1	74.5	79.7	83.2	82.4	78.3	69.1	63.7	56.1
	2%	WB	43.4	41.5	44.5	53.6	60.9	67.6	72.2	71.2	69.1	62.5	57.5	49.2
		MCDB	44.6	43.1	47.7	57.9	67.7	73.1	79.8	77.7	73.9	65.9	59.8	50.9
	5%	WB	36.9	36.7	39.5	49.3	57.0	64.4	70.6	69.6	67.2	59.4	53.7	43.8
		MCDB	38.2	38.7	42.5	52.9	63.4	70.4	77.0	75.4	71.2	62.5	56.1	45.6
	10%	WB	33.4	33.2	35.7	45.2	53.5	61.7	68.9	67.9	65.0	55.7	48.9	39.1
		MCDB	34.8	34.9	38.7	49.2	59.9	67.7	74.4	73.5	68.7	58.9	51.2	40.6
Mean Daily Temperature Range	5% DB	MDBR	13.8	17.5	17.4	17.3	20.7	21.3	20.8	20.9	20.7	17.1	13.4	11.4
		MCDBR	19.7	22.3	23.0	25.6	30.8	28.8	25.4	25.3	24.1	23.5	20.1	18.2
		MCWBR	18.8	20.5	18.8	17.9	18.2	16.9	14.1	13.9	15.7	18.0	18.4	17.4
	5% WB	MCDBR	19.4	21.8	21.2	22.5	24.9	21.8	20.9	20.0	19.9	20.8	19.7	18.4
		MCWBR	19.0	20.5	18.4	17.7	16.9	14.6	12.3	12.0	14.2	17.7	18.6	17.9
Clear-Sky Solar Irradiance	taub	0.303	0.294	0.327	0.355	0.368	0.389	0.416	0.395	0.362	0.345	0.324	0.302	
	taud	2.315	2.321	2.303	2.380	2.420	2.379	2.351	2.412	2.477	2.490	2.470	2.393	
	Ebn at Noon	248	279	285	286	285	278	269	270	271	259	242	237	
	Edh at Noon	24	30	35	36	36	37	38	34	30	25	21	21	
All-Sky Solar Radiation	RadAvg	313	560	954	1321	1603	1729	1739	1538	1176	720	372	238	
	RadStd	23	77	101	112	136	155	113	99	95	68	45	19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.79	N/A	N/A	N/A

Nomenclature: See separate page