

NORTHEAST MARGAREE, NS, Canada

WMO: 730270

Lat: 46.369N

Lon: 60.976W

Elev: 54

StdP: 100.68

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.8	-16.5	-21.9	0.5	-18.7	-19.1	0.7	-15.1	8.6	0.2	7.5	-0.2	0.8	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	27.9	20.5	26.4	19.7	24.9	19.0	22.1	26.1	21.2	24.5	20.2	23.2	3.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	15.5	24.0	19.9	14.7	23.4	19.1	13.9	22.4	64.9	26.1	61.7	24.5	58.4	23.3	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.6	5.7	4.7	DB	-23.9	31.0	3.7	1.7	-26.6	32.2	-28.7	33.2	-30.7	34.1	-33.4	35.3	(4)
(5)			WB	-23.9	23.5	3.5	0.9	-26.5	24.1	-28.6	24.6	-30.6	25.1	-33.1	25.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.0	-5.1	-6.1	-2.8	2.9	8.3	13.2	18.2	17.7	13.6	8.5	3.8	-1.2	(6)	
	DBStd	9.22	5.00	5.49	5.04	3.90	3.66	3.83	3.10	2.95	3.73	3.61	4.15	4.21	(7)	
	HDD10.0	2246	467	451	398	216	78	12	0	0	8	74	193	348	(8)	
	HDD18.3	4588	725	684	656	463	311	161	42	47	149	306	437	607	(9)	
	CDD10.0	777	1	0	0	3	26	107	253	240	116	27	6	0	(10)	
	CDD18.3	78	0	0	0	0	1	6	37	28	7	1	0	0	(11)	
	CDH23.3	693	0	0	0	1	13	71	324	239	44	1	0	0	(12)	
	CDH26.7	109	0	0	0	0	1	8	56	39	5	0	0	0	(13)	
(14) Wind	WSAvg	1.9	2.2	2.2	2.4	2.1	1.9	1.8	1.6	1.4	1.6	1.7	2.2	2.0	(14)	
(15) Precipitation	PrecAvg	1481	144	121	115	108	95	98	87	109	120	161	147	175	(15)	
	PrecMax	1739	214	189	208	186	170	204	161	262	292	265	266	408	(16)	
	PrecMin	1071	58	46	48	50	41	43	39	49	33	67	93	83	(17)	
	PrecStd	143	39	39	43	36	34	41	31	44	67	54	42	66	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	9.6	11.7	19.0	25.1	27.8	30.2	29.9	27.1	22.0	18.0	13.3	(19)	
		MCWB	11.1	8.5	7.9	13.1	16.7	18.8	22.3	21.1	21.0	18.0	15.9	12.1	(20)	
	2%	DB	7.7	6.8	8.8	14.8	21.7	25.5	28.3	27.6	24.5	19.1	15.4	10.1	(21)	
		MCWB	7.0	5.0	6.4	10.8	14.0	18.1	21.0	20.4	19.6	16.0	13.9	9.0	(22)	
	5%	DB	4.1	4.2	6.2	12.1	18.6	23.3	26.7	25.9	22.3	17.3	13.4	7.2	(23)	
		MCWB	3.0	2.8	3.8	9.0	12.5	16.8	19.9	19.4	18.4	14.8	11.8	6.0	(24)	
	10%	DB	1.9	1.8	4.1	9.8	16.1	21.2	25.1	24.4	20.7	15.2	10.9	4.6	(25)	
		MCWB	0.9	0.6	1.9	7.0	11.2	16.2	19.3	19.0	17.6	12.9	9.3	3.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	8.8	9.5	15.0	18.4	21.6	23.4	23.0	22.1	19.1	16.2	12.4	(27)	
		MCDB	12.1	9.4	11.0	18.4	23.6	26.5	28.5	28.0	25.7	20.6	17.6	13.4	(28)	
	2%	WB	6.3	5.3	6.9	12.0	16.1	19.8	22.3	21.8	20.6	17.0	14.1	9.6	(29)	
		MCDB	7.0	6.2	8.7	14.4	19.8	22.8	26.5	25.4	23.3	18.8	15.5	10.5	(30)	
	5%	WB	2.7	2.6	4.1	9.6	13.9	18.0	21.4	20.9	19.6	15.2	12.1	6.6	(31)	
		MCDB	3.5	3.7	5.8	11.6	17.5	21.3	25.0	24.1	21.8	16.9	13.4	7.6	(32)	
	10%	WB	0.8	0.6	2.1	7.3	12.0	16.5	20.5	19.9	18.3	13.2	9.4	3.9	(33)	
		MCDB	1.5	1.6	3.7	9.6	15.5	19.9	23.5	23.1	20.4	15.0	10.7	4.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	9.7	9.7	9.6	11.5	11.8	11.5	11.6	11.5	9.5	7.4	6.4	(35)	
		MCDBR	10.9	12.4	12.8	14.2	17.1	16.0	14.1	14.1	13.4	13.0	11.2	10.1	(36)	
	5% WB	MCWBR	10.4	11.4	10.5	10.0	10.1	9.4	7.8	7.7	8.7	10.0	10.2	9.6	(37)	
		MCWBR	10.8	12.1	11.8	12.5	13.8	12.1	11.6	11.1	11.0	11.6	11.0	10.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.303	0.294	0.327	0.355	0.368	0.389	0.416	0.395	0.362	0.345	0.324	0.302	(40)	
		taud	2.315	2.321	2.303	2.380	2.420	2.379	2.351	2.412	2.477	2.490	2.470	2.393	(41)	
	Edn at Noon	Edn at Noon	783	880	897	902	898	877	847	852	854	815	763	747	(42)	
		Edh at Noon	77	93	110	112	112	117	119	108	93	79	67	65	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.99	1.77	3.01	4.17	5.05	5.45	5.48	4.85	3.71	2.27	1.17	0.75	(44)	
	RadStd	RadStd	0.07	0.24	0.32	0.35	0.43	0.49	0.36	0.31	0.30	0.21	0.14	0.06	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.44	N/A	N/A	N/A	N/A

Nomenclature: See separate page