

MALAY FALLS, NS, Canada

WMO: 730290

Lat: 44.980N

Lon: 62.480W

Elev: 130

StdP: 14.63

Time Zone: -4.00 (NAA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.5	(c) 1.0	(d) -9.3	(e) 3.4	(f) 0.2	(g) -4.5	(h) 4.3	(i) 4.1	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 20.4	(c) 82.8	(d) 69.0	(e) 79.6	(f) 67.3	(g) 76.7	(h) 65.8	(i) 71.8	(j) 78.4	(k) 70.0	(l) 75.7	(m) 68.4	(n) 73.4	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.7	109.8	74.2	68.1	103.7	72.7	66.5	98.1	71.1	35.6	78.5	34.1	76.0	32.7	73.4	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-11.3	89.2	4.9	3.3	-14.8	91.6	-17.7	93.5	-20.4	95.4	-24.0	97.9
			-10.6	74.7	4.8	2.8	-14.1	76.7	-16.8	78.3	-19.5	79.9	-23.0	82.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	22.6	23.3	30.0	39.1	48.6	57.1	65.3	65.3	58.6	47.9	39.0	29.5	(6)
	DBStd	16.73	10.53	9.63	8.28	6.18	5.81	6.20	4.74	4.77	7.04	7.29	8.35	9.62	(7)
	HDD50	3773	850	747	621	330	97	10	0	0	9	130	342	637	(8)
	HDD65	7837	1315	1167	1085	776	511	245	55	54	215	532	780	1102	(9)
	CDD50	1574	0	0	1	4	52	224	474	476	266	64	12	1	(10)
	CDD65	162	0	0	0	0	1	9	64	65	22	1	0	0	(11)
	CDH74	1294	0	0	2	1	36	159	480	464	148	4	0	0	(12)
	CDH80	254	0	0	0	0	11	33	95	80	35	0	0	0	(13)
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
	PrecAvg	60.8	5.4	4.3	4.6	4.4	4.3	4.8	4.6	4.6	4.6	5.9	6.3	6.9	(15)
(15) Precipitation	PrecMax	75.0	8.4	6.5	8.6	8.7	7.3	9.3	8.1	8.3	13.6	13.3	10.0	12.6	(16)
	PrecMin	48.2	2.8	1.6	1.9	1.6	2.0	1.9	2.2	2.3	1.5	2.1	4.1	5.0	(17)
	PrecStd	6.5	1.3	1.4	1.5	1.5	1.4	1.7	1.6	1.5	2.5	2.5	1.7	1.7	(18)
	PrecStd	6.5	1.3	1.4	1.5	1.5	1.4	1.7	1.6	1.5	2.5	2.5	1.7	1.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	49.8	58.2	64.7	79.6	84.4	88.0	86.0	84.4	72.7	62.4	55.5	(19)
		MCWB	50.7	46.9	47.7	50.7	60.6	67.8	71.9	71.1	69.7	62.4	59.0	54.4	(20)
	2%	DB	46.4	45.1	49.5	58.6	70.2	78.2	82.3	82.1	77.8	67.5	59.2	51.8	(21)
		MCWB	45.4	42.9	43.8	48.5	55.9	63.9	69.3	69.1	68.4	62.1	57.1	50.5	(22)
	5%	DB	41.9	41.0	46.0	54.2	65.1	74.3	79.1	79.1	73.9	64.0	56.6	48.0	(23)
		MCWB	40.7	39.3	41.6	46.5	53.7	62.3	67.4	67.2	66.0	59.8	54.8	46.9	(24)
	10%	DB	37.7	37.1	42.6	50.6	60.8	70.3	76.1	76.2	70.8	61.2	53.6	44.0	(25)
		MCWB	36.2	35.0	38.9	45.4	51.5	60.8	65.8	65.9	64.9	57.4	51.6	42.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.0	48.4	49.6	55.8	64.6	70.6	74.6	73.5	73.3	67.0	60.1	54.1	(27)
		MCDB	51.9	49.4	52.5	60.6	76.0	78.9	83.1	81.0	78.7	69.1	61.1	54.9	(28)
	2%	WB	46.3	43.7	45.4	51.6	59.7	66.6	71.8	71.4	70.3	63.4	57.5	50.7	(29)
		MCDB	47.0	44.7	47.6	54.6	66.1	73.2	79.4	77.1	74.8	65.6	58.5	51.6	(30)
	5%	WB	41.7	39.5	42.4	48.8	56.3	64.1	69.9	69.8	68.1	60.6	55.2	47.1	(31)
		MCDB	42.5	40.9	45.0	51.9	62.1	69.8	76.1	75.2	71.7	62.7	56.2	48.1	(32)
	10%	WB	37.2	35.5	39.2	46.0	53.5	61.9	68.2	68.0	66.1	57.9	51.6	43.1	(33)
		MCDB	38.3	37.0	42.3	49.6	57.9	67.9	73.5	73.0	69.3	60.2	53.2	44.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.2	18.7	18.4	18.3	20.5	20.4	19.6	20.4	21.9	19.9	16.5	15.9	(35)
		MCDBR	20.1	20.2	23.1	26.1	30.3	28.8	25.5	25.8	25.2	23.5	19.2	18.7	(36)
		MCWBR	20.2	18.2	17.6	17.5	18.1	16.8	14.1	14.7	15.8	16.5	17.7	18.9	(37)
	5% WB	MCDBR	20.2	19.5	20.5	19.5	23.6	22.6	19.7	18.9	18.9	17.9	17.6	18.9	(38)
		MCWBR	20.4	18.9	17.8	15.6	16.2	14.6	12.0	11.9	13.2	15.1	17.3	19.2	(39)
(40) Clear-Sky Solar Irradiance	taub		0.301	0.301	0.326	0.350	0.372	0.393	0.413	0.394	0.351	0.337	0.321	0.295	(40)
	taud		2.468	2.495	2.461	2.440	2.422	2.389	2.358	2.409	2.501	2.529	2.525	2.529	(41)
	Ebn at Noon		260	283	289	289	285	278	270	272	277	266	250	252	(42)
	Edh at Noon		22	26	30	34	36	37	38	35	29	25	21	19	(43)
(44) All-Sky Solar Radiation	RadAvg		428	698	1092	1342	1556	1683	1672	1551	1253	804	456	333	(44)
	RadStd		35	58	73	116	182	161	119	114	91	84	50	24	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.83	N/A	N/A	N/A	N/A

Nomenclature: See separate page