

MALAY FALLS, NS, Canada

WMO: 730290

Lat: 44.980N

Lon: 62.480W

Elev: 40

StdP: 100.85

Time Zone: -4.00 (NAA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.3	-17.2	-22.9	0.5	-17.6	-20.3	0.6	-15.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.3	28.2	20.6	26.5	19.6	24.8	18.8	22.1	25.8	21.1	24.3	20.2	23.0	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.7	23.4	20.1	14.8	22.6	19.2	14.0	21.7	64.9	25.8	61.4	24.5	58.2	23.0	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-24.0	31.8	2.7	1.9	-26.0	33.1	-27.6	34.2	-29.1	35.2	-31.1	36.6		
(5)			-23.7	23.7	2.6	1.6	-25.6	24.8	-27.1	25.7	-28.6	26.6	-30.5	27.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-5.2	-4.8	-1.1	4.0	9.2	14.0	18.5	18.5	14.8	8.8	3.9	-1.4
	DBStd	9.29	5.85	5.35	4.60	3.43	3.23	3.44	2.63	2.65	3.91	4.05	4.64	5.35
	HDD10.0	2096	472	415	345	183	54	6	0	0	5	72	190	354
	HDD18.3	4354	731	648	603	431	284	136	31	30	119	296	433	612
	CDD10.0	874	0	0	1	2	29	124	263	264	148	36	7	1
	CDD18.3	90	0	0	0	0	1	5	36	36	12	1	0	0
	CDH23.3	719	0	0	1	1	20	88	267	258	82	2	0	0
	CDH26.7	141	0	0	0	0	6	18	53	44	19	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	1545	138	109	118	112	110	122	118	118	117	151	159	174
	PrecMax	1906	213	166	219	221	185	235	205	211	345	337	255	321
	PrecMin	1225	70	41	48	41	52	49	55	58	38	53	104	126
	PrecStd	164	32	35	39	39	35	44	40	37	64	64	44	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	9.9	14.5	18.2	26.4	29.1	31.1	30.0	29.1	22.6	16.9	13.0
		MCWB	10.4	8.3	8.7	10.4	15.9	19.9	22.1	21.7	20.9	16.9	15.0	12.5
	2%	DB	8.0	7.3	9.7	14.8	21.2	25.6	28.0	27.8	25.4	19.7	15.1	11.0
		MCWB	7.4	6.1	6.5	9.2	13.3	17.7	20.7	20.6	20.2	16.7	14.0	10.3
	5%	DB	5.5	5.0	7.8	12.3	18.4	23.5	26.2	26.1	23.3	17.8	13.7	8.9
		MCWB	4.8	4.0	5.3	8.1	12.1	16.8	19.7	19.6	18.9	15.4	12.7	8.3
	10%	DB	3.2	2.8	5.9	10.3	16.0	21.3	24.5	24.5	21.6	16.2	12.0	6.7
		MCWB	2.4	1.7	3.8	7.5	10.8	16.0	18.8	18.9	18.3	14.1	10.9	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	9.1	9.8	13.2	18.1	21.4	23.7	23.1	22.9	19.4	15.6	12.3
		MCDB	11.0	9.7	11.4	15.9	24.4	26.0	28.4	27.2	26.0	20.6	16.2	12.7
	2%	WB	8.0	6.5	7.4	10.9	15.4	19.2	22.1	21.9	21.3	17.5	14.2	10.4
		MCDB	8.3	7.0	8.7	12.6	18.9	22.9	26.3	25.1	23.8	18.6	14.7	10.9
	5%	WB	5.4	4.2	5.8	9.3	13.5	17.8	21.1	21.0	20.1	15.9	12.9	8.4
		MCDB	5.9	4.9	7.2	11.1	16.7	21.0	24.5	24.0	22.1	17.1	13.4	8.9
	10%	WB	2.9	2.0	4.0	7.8	11.9	16.6	20.1	20.0	19.0	14.4	10.9	6.2
		MCDB	3.5	2.8	5.7	9.8	14.4	20.0	23.1	22.8	20.7	15.7	11.8	6.7
Mean Daily Temperature Range	5% DB	MDBR	10.1	10.4	10.2	10.2	11.4	11.3	10.9	11.3	12.1	11.1	9.2	8.8
		MCDBR	11.2	11.2	12.8	14.5	16.8	16.0	14.2	14.3	14.0	13.0	10.7	10.4
		MCWBR	11.2	10.1	9.8	9.7	10.1	9.3	7.9	8.2	8.8	9.1	9.8	10.5
	5% WB	MCDBR	11.2	10.8	11.4	10.8	13.1	12.5	10.9	10.5	10.5	10.0	9.8	10.5
		MCWBR	11.3	10.5	9.9	8.7	9.0	8.1	6.7	6.6	7.3	8.4	9.6	10.7
Clear-Sky Solar Irradiance	taub	0.301	0.301	0.326	0.350	0.372	0.393	0.413	0.394	0.351	0.337	0.321	0.295	
	taud	2.468	2.495	2.461	2.440	2.422	2.389	2.358	2.409	2.501	2.529	2.525	2.529	
	Ebn at Noon	819	893	911	912	897	876	852	857	872	837	789	793	
	Edh at Noon	70	81	96	107	112	117	119	109	92	78	66	60	
All-Sky Solar Radiation	RadAvg	1.35	2.20	3.44	4.23	4.90	5.31	5.27	4.89	3.95	2.54	1.44	1.05	
	RadStd	0.11	0.18	0.23	0.37	0.57	0.51	0.37	0.36	0.29	0.27	0.16	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.46	N/A	N/A	N/A

Nomenclature: See separate page