

DARRINGTON 21 NNE, WA, USAWMO: **742020**Lat: **48.5405N**Lon: **121.4460W**Elev: **407**StdP: **14.48**Time Zone: **-8.00 (NAP)**Period: **03-19**WBAN: **04223****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.3	24.9	5.5	7.4	30.6	10.3	9.4	29.5	10.0	32.9	8.7	31.7	3.5	N/A	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.2	87.7	67.3	84.0	65.6	80.3	64.7	69.1	83.3	67.5	81.1	65.9	78.7	2.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.9	90.4	74.7	62.2	85.0	72.6	60.7	80.5	70.5	33.3	83.2	32.0	80.5	30.7	78.6	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.9	4.8	3.8	14.7	94.6	3.2	3.7	12.4	97.2	10.6	99.4	8.8	101.5	6.5	104.1
			14.6	72.6	2.9	1.2	12.5	73.4	10.8	74.1	9.2	74.8	7.1	75.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	37.0	38.7	42.5	48.0	55.3	59.5	65.0	65.3	59.0	49.6	41.1	36.2	(6)
	DBStd	11.58	5.32	5.29	5.15	5.45	5.59	5.42	4.78	4.52	5.07	4.79	5.47	5.20	(7)
	HDD50	1836	402	317	238	100	14	1	0	0	2	64	270	428	(8)
	HDD65	5684	867	737	697	509	303	183	58	52	191	476	718	893	(9)
	CDD50	1777	0	0	7	41	179	285	465	474	272	52	2	0	(10)
	CDD65	150	0	0	0	0	3	17	58	61	11	0	0	0	(11)
	CDH74	2619	0	0	2	26	154	344	968	898	226	1	0	0	(12)
	CDH80	839	0	0	0	4	35	111	329	298	62	0	0	0	(13)
(14) Wind	WSAvg	1.2	1.3	1.6	1.3	1.3	1.2	1.1	1.1	1.1	0.9	0.9	1.1	1.2	(14)
(15) Precipitation	PrecAvg	70.8	11.3	6.4	6.8	3.9	2.9	2.6	1.3	1.8	2.8	7.9	12.6	11.0	(15)
	PrecMax	96.7	19.5	12.8	14.2	7.8	5.0	5.2	3.6	5.0	7.2	20.5	27.3	19.2	(16)
	PrecMin	52.1	5.7	0.1	0.7	1.1	0.9	0.7	0.2	0.1	0.5	0.7	3.9	5.0	(17)
	PrecStd	11.5	3.6	3.7	3.4	1.8	1.2	1.1	0.9	1.4	2.0	4.5	6.6	3.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.4	57.9	67.4	77.7	84.4	89.2	94.1	91.5	87.1	71.5	56.9	50.3	(19)
		MCWB	46.2	47.3	50.8	57.2	62.2	69.6	67.1	67.2	64.4	56.0	51.1	45.3	(20)
	2%	DB	49.3	52.6	60.1	69.4	78.5	83.0	87.7	87.1	80.4	65.6	53.3	47.2	(21)
		MCWB	43.8	45.8	48.6	53.8	61.3	66.3	67.1	67.2	63.1	54.8	50.6	44.7	(22)
	5%	DB	46.3	49.2	55.0	63.2	73.2	77.3	83.4	83.2	75.3	61.2	50.8	45.0	(23)
		MCWB	43.5	45.4	46.6	51.5	59.5	63.6	66.8	65.8	61.2	53.5	48.6	43.4	(24)
	10%	DB	44.1	46.2	50.8	58.4	68.1	72.5	79.4	79.1	70.5	57.5	48.7	43.1	(25)
		MCWB	42.2	43.8	45.7	49.4	57.3	61.1	65.2	65.0	59.7	52.5	47.0	41.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.4	50.4	54.9	60.2	65.9	71.2	70.6	70.9	67.5	60.9	53.7	47.3	(27)
		MCDB	51.3	53.0	64.2	75.5	80.7	86.4	84.6	84.8	80.8	65.1	55.1	48.1	(28)
	2%	WB	45.5	48.1	50.9	55.7	63.0	67.6	69.2	68.6	65.4	57.4	51.6	45.0	(29)
		MCDB	47.2	50.3	59.3	67.6	76.2	82.2	83.4	82.8	77.3	61.3	52.7	45.8	(30)
	5%	WB	43.7	45.9	48.6	52.7	60.7	64.5	67.6	67.0	63.2	55.2	49.4	43.2	(31)
		MCDB	45.3	47.6	54.0	60.9	72.2	76.5	81.3	80.3	72.9	58.3	50.1	44.0	(32)
	10%	WB	42.2	43.9	46.5	50.5	58.7	62.1	65.8	65.5	60.9	53.4	47.5	41.7	(33)
		MCDB	43.7	45.9	50.8	56.9	68.8	72.1	78.7	77.9	68.5	56.9	48.6	42.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	12.4	15.5	18.6	21.4	20.4	25.2	25.1	21.2	15.3	10.3	7.9	(35)
		MCDBR	14.3	18.7	25.1	30.3	33.2	33.1	34.3	34.5	32.5	23.9	13.8	10.5	(36)
	5% WB	MCWBR	10.6	10.3	14.7	15.8	17.2	16.8	15.9	15.4	15.6	13.9	10.0	7.8	(37)
		MCWBR	12.2	12.3	22.1	26.1	29.5	30.3	30.6	29.8	27.1	17.2	9.3	8.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.294	0.294	0.313	0.346	0.379	0.363	0.350	0.351	0.334	0.336	0.301	0.296	(40)
		taud	2.374	2.386	2.358	2.283	2.309	2.424	2.476	2.494	2.536	2.510	2.503	2.356	(41)
	Ebn at Noon		245	275	287	286	280	285	287	282	278	257	244	226	(42)
		Edh at Noon	22	27	32	38	39	35	33	31	27	24	19	19	(43)
(44) All-Sky Solar Radiation	RadAvg		325	597	892	1339	1649	1811	2116	1798	1277	723	357	257	(44)
	RadStd		51	68	104	126	143	179	174	126	105	96	51	37	(45)

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (64 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page