

TRURO, NS, Canada

WMO: 743985

Lat: 45.370N

Lon: 63.270W

Elev: 131

StdP: 14.63

Time Zone: -4.00 (NAA)

Period: 90-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.6	(c) -0.9	(d) -17.7	(e) 2.1	(f) -0.7	(g) -12.8	(h) 2.8	(i) 1.2	(j) 23.1	(k) 29.1	(l) 20.7	(m) 28.1	(n) 4.6	(o) 270	(p) 0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 18.6	(c) 80.4	(d) 68.5	(e) 77.9	(f) 67.0	(g) 75.5	(h) 65.8	(i) 71.2	(j) 77.7	(k) 69.4	(l) 75.1	(m) 67.7	(n) 72.6	(o) 6.8	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 69.1	(b) 107.5	(c) 74.3	(d) 67.4	(e) 101.2	(f) 72.4	(g) 65.7	(h) 95.3	(i) 70.8	(j) 35.1	(k) 77.7	(l) 33.6	(m) 75.0	(n) 32.2	(o) 72.7	(p) 78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 19.6	(b) 16.9	(c) 14.7	(e) -13.3	(f) 85.7	(g) 6.9	(h) 2.3	(i) -18.3	(j) 87.4	(k) -22.3	(l) 88.8	(m) -26.2	(n) 90.1	(o) -31.2	(p) 91.8		
(a) 19.6	(b) 16.9	(c) 14.7	(e) -14.0	(f) 74.7	(g) 6.7	(h) 2.0	(i) -18.8	(j) 76.1	(k) -22.7	(l) 77.2	(m) -26.5	(n) 78.3	(o) -31.3	(p) 79.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.3	20.3	21.5	29.4	39.0	49.3	58.5	65.2	65.1	57.1	47.6	37.7	27.1		
	DBStd	17.51	11.40	10.61	8.89	6.24	6.51	6.27	4.95	5.07	6.37	7.18	8.03	9.91		
	HDD50	4026	922	798	638	334	92	6	0	0	13	135	379	709		
	HDD65	8086	1387	1218	1103	780	487	209	59	62	247	541	819	1174		
	CDD50	1571	0	0	0	4	71	262	470	469	225	60	9	1		
	CDD65	156	0	0	0	0	1	15	65	66	9	0	0	0		
	CDH74	844	0	0	0	0	19	103	364	332	26	0	0	0		
	CDH80	92	0	0	0	0	1	9	44	38	0	0	0	0		
	WSAvg	5.5	5.9	6.4	6.7	6.7	5.7	4.9	4.4	4.0	4.1	5.0	5.7	6.2		
	PrecAvg	48.7	4.6	3.8	3.8	3.6	3.7	3.2	3.6	4.1	3.5	4.5	4.8	5.2		
	PrecMax	57.1	10.4	6.6	6.5	5.8	7.1	9.5	7.2	10.7	6.0	10.0	7.3	9.6		
(15) Precipitation	PrecMin	32.6	1.5	1.2	1.2	1.3	0.9	1.1	1.2	0.4	0.7	1.0	1.5	2.5		
	PrecStd	5.2	1.8	1.4	1.3	1.2	1.8	1.7	1.9	1.9	1.4	2.0	1.5	1.8		
	0.4% DB	54.5	50.6	55.5	62.9	76.8	80.7	84.5	83.8	77.4	71.1	62.7	55.5			
	0.4% MCWB	52.1	49.0	50.9	52.7	61.3	67.4	70.7	70.2	67.2	63.9	59.6	54.7			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	48.5	45.1	50.7	57.2	70.5	77.1	80.6	80.2	73.2	66.2	59.1	50.7			
	2% MCWB	46.9	44.0	47.8	49.1	58.4	66.0	68.9	69.0	64.7	62.1	57.4	49.6			
	5% DB	40.5	40.5	46.3	53.8	66.1	73.5	78.0	77.8	70.3	62.9	54.4	45.3			
	5% MCWB	38.7	38.5	42.7	47.5	55.4	63.5	67.0	67.7	63.3	59.3	52.2	43.7			
	10% DB	35.6	36.5	42.1	50.4	62.0	70.5	75.4	75.0	67.8	59.7	49.9	40.0			
	10% MCWB	34.0	34.5	38.9	44.9	52.9	60.9	65.7	66.2	62.6	56.0	47.3	37.8			
	0.4% WB	52.4	49.1	52.2	56.7	63.4	70.5	73.7	73.7	70.2	66.6	60.3	54.9			
	0.4% MCDB	53.9	50.6	53.5	61.0	72.9	78.8	80.7	79.5	74.9	68.0	61.3	55.5			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	47.4	44.2	48.6	52.4	60.2	67.5	71.2	71.6	67.4	63.4	57.6	50.2			
	2% MCDB	48.6	45.2	51.0	54.7	67.6	74.7	78.0	77.8	70.6	65.6	59.1	50.8			
	5% WB	38.9	38.8	43.3	48.8	57.1	65.3	69.2	69.7	65.7	60.1	52.8	44.1			
	5% MCDB	40.1	40.1	45.5	52.8	63.3	71.3	75.3	75.2	68.6	62.3	54.1	45.3			
	10% WB	34.2	34.6	39.3	45.3	54.2	62.9	67.3	68.0	63.7	56.8	48.0	38.1			
	10% MCDB	35.3	36.2	41.9	49.6	60.3	68.4	72.7	72.4	66.9	59.0	49.4	39.5			
(35) Mean Daily Temperature Range	MDBR	17.4	17.4	15.6	15.7	20.0	19.8	18.4	18.6	18.4	16.2	12.6	14.8			
	5% DB MCDBR	23.1	17.5	20.1	23.6	28.2	24.6	22.6	22.0	21.1	19.7	16.9	19.6			
	5% DB MCWBR	23.3	17.0	17.4	16.5	17.6	15.4	12.8	12.4	13.8	15.1	16.4	21.1			
	5% WB MCDBR	23.0	17.0	19.0	18.6	24.1	20.3	18.3	17.2	16.1	16.9	16.7	19.9			
	5% WB MCWBR	23.6	17.2	17.8	15.6	16.3	13.8	11.3	10.6	12.2	14.5	16.6	21.0			
(40) Clear-Sky Solar Irradiance	taub	0.300	0.291	0.320	0.353	0.369	0.394	0.413	0.396	0.352	0.328	0.311	0.289			
	taud	2.429	2.477	2.444	2.404	2.408	2.358	2.326	2.368	2.476	2.535	2.535	2.522			
	Ebn at Noon	258	286	290	288	285	277	270	271	276	268	253	252			
	Edh at Noon	23	26	31	35	36	38	39	36	30	24	21	19			
	RadAvg	434	691	1071	1317	1541	1674	1705	1562	1229	784	439	323			
(45) All-Sky Solar Radiation	RadStd	38	58	70	119	179	150	121	116	99	84	49	23			

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.72	N/A	N/A	N/A	+29

Nomenclature: See separate page