

TRURO, NS, Canada

WMO: 743985

Lat: 45.370N

Lon: 63.270W

Elev: 40

StdP: 100.85

Time Zone: -4.00 (NAA)

Period: 90-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.9	-18.3	-27.6	0.3	-18.2	-24.9	0.4	-17.1	10.3	-1.6	9.3	-2.2	2.1	270	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.3	26.9	20.3	25.5	19.5	24.2	18.8	21.8	25.4	20.8	23.9	19.8	22.6	3.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.4	23.5	19.7	14.5	22.5	18.7	13.6	21.6	63.8	25.4	60.2	23.9	57.0	22.6	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.6	6.6	-25.2	29.9	3.8	1.3	-27.9	30.8	-30.2	31.6	-32.3	32.3	-35.1	33.2		
(5)			-25.5	23.7	3.7	1.1	-28.2	24.5	-30.4	25.1	-32.5	25.7	-35.2	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.3	-6.5	-5.8	-1.4	3.9	9.6	14.7	18.4	18.4	13.9	8.6	3.2	-2.7
	DBStd	9.73	6.34	5.90	4.94	3.47	3.61	3.48	2.75	2.81	3.54	3.99	4.46	5.51
	HDD10.0	2237	512	443	354	186	51	3	0	0	7	75	211	394
	HDD18.3	4492	771	677	613	433	271	116	33	34	137	301	455	652
	CDD10.0	873	0	0	0	2	39	146	261	261	125	33	5	1
	CDD18.3	87	0	0	0	0	1	8	36	37	5	0	0	0
	CDH23.3	469	0	0	0	0	11	57	202	184	14	0	0	0
	CDH26.7	51	0	0	0	0	1	5	24	21	0	0	0	0
Wind	WSAvg	2.4	2.6	2.9	3.0	3.0	2.5	2.2	2.0	1.8	1.8	2.3	2.5	2.8
Precipitation	PrecAvg	1236	116	96	97	91	95	81	91	103	88	115	123	132
	PrecMax	1451	263	168	164	148	180	242	182	272	153	253	185	243
	PrecMin	827	38	31	31	34	23	27	30	10	18	26	38	64
	PrecStd	132	45	35	34	30	46	43	47	49	36	50	38	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	10.3	13.1	17.2	24.9	27.1	29.2	28.8	25.2	21.7	17.0	13.1
		MCWB	11.2	9.4	10.5	11.5	16.3	19.7	21.5	21.2	19.6	17.7	15.3	12.6
	2%	DB	9.2	7.3	10.4	14.0	21.4	25.1	27.0	26.8	22.9	19.0	15.0	10.4
		MCWB	8.3	6.6	8.8	9.5	14.6	18.9	20.5	20.5	18.2	16.7	14.1	9.8
	5%	DB	4.7	4.7	8.0	12.1	19.0	23.1	25.5	25.4	21.3	17.1	12.5	7.4
		MCWB	3.7	3.6	6.0	8.6	13.0	17.5	19.5	19.8	17.4	15.2	11.2	6.5
	10%	DB	2.0	2.5	5.6	10.2	16.7	21.4	24.1	23.9	19.9	15.4	9.9	4.5
		MCWB	1.1	1.4	3.8	7.2	11.6	16.0	18.7	19.0	17.0	13.3	8.5	3.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	9.5	11.2	13.7	17.5	21.4	23.2	23.2	21.2	19.2	15.7	12.7
		MCDB	12.2	10.3	11.9	16.1	22.7	26.0	27.1	26.4	23.8	20.0	16.3	13.1
	2%	WB	8.5	6.8	9.2	11.4	15.7	19.7	21.8	22.0	19.7	17.4	14.2	10.1
		MCDB	9.2	7.3	10.6	12.6	19.8	23.7	25.6	25.4	21.5	18.7	15.0	10.5
	5%	WB	3.8	3.8	6.3	9.3	14.0	18.5	20.7	21.0	18.7	15.6	11.5	6.7
		MCDB	4.5	4.5	7.5	11.5	17.4	21.8	24.0	24.0	20.3	16.8	12.3	7.4
	10%	WB	1.2	1.5	4.1	7.4	12.3	17.2	19.6	20.0	17.6	13.8	8.9	3.4
		MCDB	1.8	2.3	5.5	9.8	15.7	20.2	22.6	22.5	19.4	15.0	9.7	4.2
Mean Daily Temperature Range	5% DB	MDBR	9.7	9.7	8.7	8.7	11.1	11.0	10.2	10.3	10.2	9.0	7.0	8.2
		MCDBR	12.9	9.7	11.2	13.1	15.7	13.7	12.5	12.2	11.7	11.0	9.4	10.9
		MCWBR	12.9	9.4	9.7	9.2	9.8	8.6	7.1	6.9	7.7	8.4	9.1	11.7
	5% WB	MCDBR	12.8	9.5	10.6	10.3	13.4	11.3	10.2	9.6	9.0	9.4	9.3	11.1
		MCWBR	13.1	9.6	9.9	8.6	9.1	7.7	6.3	5.9	6.8	8.0	9.2	11.7
Clear-Sky Solar Irradiance	taub	0.300	0.291	0.320	0.353	0.369	0.394	0.413	0.396	0.352	0.328	0.311	0.289	
	taud	2.429	2.477	2.444	2.404	2.408	2.358	2.326	2.368	2.476	2.535	2.535	2.522	
	Ebn at Noon	812	902	915	907	900	874	851	853	869	846	799	796	
	Edh at Noon	71	81	97	110	114	120	123	114	94	77	65	59	
All-Sky Solar Radiation	RadAvg	1.37	2.18	3.38	4.15	4.86	5.28	5.38	4.92	3.88	2.47	1.38	1.02	
	RadStd	0.12	0.18	0.22	0.38	0.56	0.47	0.38	0.37	0.31	0.27	0.15	0.07	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.40	N/A	N/A	+16

Nomenclature: See separate page