

HARRISBURG-RALEIGH, IL, USA

WMO: 744652

Lat: 37.811N

Lon: 88.549W

Elev: 396

StdP: 14.49

Time Zone: -6.00 (NAC)

Period: 02-19

WBAN: 53897

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 9.7	(c) 14.5	(d) 0.2	(e) 5.6	(f) 12.8	(g) 4.9	(h) 7.2	(i) 17.3	(j) 25.9	(k) 46.7	(l) 23.5	(m) 44.4	(n) 5.0	(o) 350	(p) 0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.5	(c) 93.4	(d) 75.8	(e) 91.0	(f) 75.2	(g) 89.8	(h) 74.8	(i) 80.0	(j) 88.2	(k) 78.4	(l) 86.5	(m) 77.2	(n) 85.2	(o) 7.2	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.5	145.0	84.3	76.5	140.3	83.1	74.8	132.2	81.1	43.8	87.9	42.1	86.7	40.7	85.1	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.9	(b) 18.5	(c) 16.3	(e) 1.4	(f) 97.0	(g) 5.6	(h) 3.5	(i) -2.6	(j) 99.5	(k) -5.9	(l) 101.6	(m) -9.0	(n) 103.5	(o) -13.1	(p) 106.0		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			1.4	97.0	5.6	3.5	-2.6	99.5	-5.9	101.6	-9.0	103.5	-13.1	106.0		
			0.5	81.5	5.2	2.1	-3.3	83.0	-6.3	84.2	-9.3	85.4	-13.1	86.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.0	33.6	36.3	47.2	57.7	66.9	75.0	77.2	76.1	69.9	58.0	46.2	38.2
	DBStd	17.75	11.13	11.06	10.75	8.99	7.91	5.35	4.96	4.99	6.73	9.16	9.48	9.24
	HDD50	1727	520	401	186	32	1	0	0	0	0	26	180	381
	HDD65	4350	973	803	559	247	78	3	0	2	30	258	566	831
	CDD50	4273	11	19	98	263	525	751	843	809	597	275	67	15
	CDD65	1420	0	0	6	29	137	304	379	345	176	42	2	0
	CDH74	13795	0	0	45	267	1186	2994	3769	3309	1780	427	18	0
	CDH80	5364	0	0	4	30	328	1186	1611	1393	698	113	1	0
(14) Wind	WSAvg	6.0	7.7	7.6	8.0	8.0	6.1	4.9	3.8	3.6	4.1	5.4	6.4	6.9
(15) Precipitation	PrecAvg	47.5	3.2	3.0	4.7	4.6	5.1	4.4	4.1	3.3	3.1	3.1	4.3	4.1
	PrecMax	66.0	11.7	6.7	14.8	13.1	14.3	12.7	9.2	9.6	7.5	10.4	9.2	13.1
	PrecMin	31.8	0.0	0.7	1.5	1.7	1.1	0.5	0.3	0.4	0.1	0.0	0.4	0.6
	PrecStd	7.8	2.1	1.5	2.6	2.4	2.9	2.5	2.2	2.2	1.9	2.1	2.2	2.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.7	70.0	79.3	82.5	89.8	95.3	98.8	97.2	94.1	88.1	76.9	67.8
		MCWB	60.4	62.4	64.6	65.7	72.1	75.0	76.1	73.5	72.6	70.8	61.8	62.4
	2%	DB	61.5	64.7	73.1	80.7	86.2	91.1	92.9	93.3	90.9	82.5	71.6	62.3
		MCWB	56.5	58.0	61.7	64.3	71.4	75.0	78.6	74.7	72.3	68.4	61.9	57.5
	5%	DB	56.9	59.5	69.9	77.2	83.8	89.8	90.5	90.5	88.1	79.0	66.1	57.4
		MCWB	52.4	52.8	60.0	62.6	70.1	74.4	77.1	74.8	72.1	65.8	58.5	53.3
	10%	DB	51.6	54.4	64.3	73.2	81.3	87.3	88.4	87.9	83.9	73.9	62.6	53.8
		MCWB	47.0	48.8	56.7	61.3	68.5	73.9	75.9	74.4	70.0	63.6	55.4	49.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.4	64.0	66.6	70.0	76.5	80.2	82.2	81.1	77.5	74.8	67.4	63.9
		MCDB	63.8	68.6	75.4	78.7	83.3	89.0	91.1	89.0	86.9	82.8	72.5	67.3
	2%	WB	58.8	60.1	64.0	67.7	74.3	78.2	80.6	79.1	75.9	72.1	63.6	59.0
		MCDB	61.9	63.7	71.0	76.0	81.9	87.0	88.8	87.3	85.7	78.8	67.5	61.3
	5%	WB	53.7	54.8	61.3	65.8	72.3	76.9	79.1	77.5	74.3	69.0	60.0	54.2
		MCDB	55.7	59.0	68.4	73.7	80.2	85.3	87.0	85.7	83.2	75.7	64.9	56.9
	10%	WB	46.7	48.8	58.2	63.5	70.7	75.3	77.7	76.1	72.6	66.0	55.9	49.5
		MCDB	50.0	54.0	63.8	69.7	78.1	83.3	85.3	83.9	80.1	72.0	62.1	52.5
(35) Mean Daily Temperature Range	MDBR		15.6	16.2	18.6	20.8	19.4	19.7	19.5	20.8	22.9	22.1	19.0	15.2
	5% DB	MCDBR	21.6	23.8	23.7	24.4	22.5	22.3	21.7	24.4	27.1	26.4	24.6	20.5
		MCWBR	18.2	18.3	14.5	12.4	9.8	8.7	8.7	9.3	10.6	12.9	16.0	17.1
	5% WB	MCDBR	18.9	21.6	21.6	19.7	18.6	18.8	19.1	19.9	22.3	21.5	20.2	18.5
		MCWBR	18.0	18.9	14.2	11.9	9.5	8.8	9.1	9.1	10.0	11.7	16.5	17.4
(40) Clear-Sky Solar Irradiance	taub		0.315	0.326	0.367	0.399	0.432	0.441	0.473	0.474	0.411	0.360	0.325	0.309
	taud		2.462	2.410	2.359	2.273	2.234	2.222	2.150	2.136	2.308	2.442	2.485	2.482
	Ebn at Noon		276	286	284	279	271	267	258	254	265	271	270	269
	Edh at Noon		26	31	36	42	44	45	48	47	38	30	25	24
(44) All-Sky Solar Radiation	RadAvg		646	869	1194	1578	1778	2029	1956	1790	1493	1110	750	552
	RadStd		63	100	109	96	154	126	127	93	94	116	83	48

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+139

Nomenclature: See separate page