

OLNEY-NOBLE, IL, USA

WMO: 744659

Lat: 38.722N

Lon: 88.176W

Elev: 147

StdP: 99.57

Time Zone: -6.00 (NAC)

Period: 02-19

WBAN: 53822

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.8	-12.1	-22.0	0.5	-11.2	-18.5	0.7	-9.1	11.7	-0.1	10.6	-1.5	2.3	300	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	34.8	24.6	32.9	24.1	32.2	23.9	27.1	31.5	26.0	30.5	25.3	29.9	2.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.8	29.4	24.9	20.3	28.3	23.9	19.1	27.8	86.2	31.6	81.6	30.8	78.1	29.4	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.0	7.1	-18.8	36.8	3.4	4.4	-21.2	39.9	-23.2	42.4	-25.1	44.9	-27.5	48.0		
(5)			-19.3	28.4	3.3	1.6	-21.6	29.6	-23.5	30.5	-25.4	31.4	-27.7	32.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	-0.8	1.1	7.5	13.3	18.9	23.7	24.9	24.2	20.9	14.1	7.2	2.0	(6)
(7)		DBStd	10.38	6.40	6.33	6.16	5.34	4.62	3.19	3.08	2.98	3.87	5.10	5.40	5.55	(7)
(8)		HDD10.0	1133	338	256	123	28	1	0	0	0	17	117	254		(8)
(9)		HDD18.3	2646	592	482	338	164	52	2	1	1	18	153	336	507	(9)
(10)		CDD10.0	2282	4	7	46	127	278	411	462	441	328	142	32	6	(10)
(11)		CDD18.3	754	0	0	3	13	70	163	204	184	96	21	1	0	(11)
(12)		CDH23.3	7302	0	0	18	123	615	1565	2048	1746	964	216	7	0	(12)
(13)		CDH26.7	2917	0	0	2	19	182	627	893	744	385	64	1	0	(13)
(14)	Wind	WSAvg	2.7	3.5	3.3	3.5	3.4	2.6	2.1	1.6	1.5	1.8	2.5	3.0	3.2	(14)
(15)	Precipitation	PrecAvg	1113	72	65	108	109	123	104	101	89	72	86	106	89	(15)
(16)		PrecMax	1472	221	150	232	244	312	213	243	284	170	248	310	254	(16)
(17)		PrecMin	709	2	12	16	39	22	12	16	12	1	14	6	17	(17)
(18)		PrecStd	212	53	35	53	52	73	58	55	56	45	53	57	47	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.5	20.0	26.9	28.8	32.7	36.1	38.9	37.4	34.1	31.4	23.9	17.9	(19)
(20)			MCWB	15.2	16.1	17.9	19.2	21.9	25.1	24.2	25.5	23.2	22.2	16.0	14.4	(20)
(21)		2%	DB	14.8	17.1	22.6	27.0	30.3	33.0	34.5	34.0	32.6	28.0	21.1	15.2	(21)
(22)			MCWB	12.3	13.4	16.3	18.1	21.5	24.2	25.2	24.3	22.6	20.1	16.4	13.1	(22)
(23)		5%	DB	12.2	13.8	19.9	24.1	28.7	32.2	32.7	32.5	31.1	26.0	17.9	12.6	(23)
(24)			MCWB	10.1	10.1	14.9	17.3	20.9	23.6	25.0	24.2	22.1	18.5	13.8	10.3	(24)
(25)		10%	DB	8.0	11.0	17.4	22.5	27.3	30.8	31.3	31.1	28.8	22.7	16.1	10.2	(25)
(26)			MCWB	6.1	8.1	13.7	16.1	20.2	23.2	24.7	23.8	21.0	17.2	12.0	8.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.8	17.1	18.9	21.7	24.7	27.4	28.4	28.3	25.7	23.8	19.0	16.2	(27)
(28)			MCD B	17.2	18.7	24.0	26.8	28.4	31.5	32.5	33.5	31.2	28.9	22.2	17.2	(28)
(29)		2%	WB	13.0	14.3	17.4	19.7	23.4	25.9	27.3	26.7	24.6	21.9	17.1	13.3	(29)
(30)			MCD B	14.2	16.5	21.4	24.4	27.7	30.9	31.3	31.5	29.5	26.1	19.0	14.5	(30)
(31)		5%	WB	10.3	11.1	15.8	18.4	22.3	25.1	26.3	25.7	23.4	20.3	14.8	11.0	(31)
(32)			MCD B	11.6	13.4	19.1	22.1	26.6	29.9	30.5	30.2	28.1	24.2	17.7	12.7	(32)
(33)		10%	WB	6.4	7.7	14.2	17.1	21.3	24.1	25.5	24.8	22.4	18.2	12.3	8.0	(33)
(34)			MCD B	8.2	10.3	17.3	21.0	25.3	28.5	29.8	29.1	26.9	21.8	15.4	9.5	(34)
(35)	Mean Daily Temperature Range			MDBR	8.3	9.0	10.1	11.4	10.8	11.0	12.0	13.0	11.9	9.9	7.8	(35)
(36)		5% DB	MCD BR	11.5	12.9	13.0	13.6	12.6	12.9	12.6	14.5	15.0	14.8	13.1	10.7	(36)
(37)			MCWBR	10.1	10.3	8.0	7.4	5.5	5.5	5.2	6.7	6.5	8.2	9.0	8.9	(37)
(38)		5% WB	MCD BR	10.7	11.9	11.7	11.8	10.8	10.7	10.6	12.0	13.0	12.7	11.5	9.5	(38)
(39)			MCWBR	10.2	10.6	8.1	7.8	6.1	6.2	6.2	6.9	7.1	8.4	9.1	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.310	0.322	0.356	0.404	0.439	0.441	0.464	0.467	0.414	0.360	0.319	0.307	(40)
(41)		taud		2.450	2.400	2.374	2.241	2.196	2.216	2.154	2.134	2.275	2.421	2.485	2.468	(41)
(42)		Ebn at Noon		867	902	901	873	846	842	818	805	829	847	849	843	(42)
(43)		Edh at Noon		82	98	111	135	144	142	150	149	122	95	78	75	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.92	2.71	3.71	4.89	5.50	6.37	6.18	5.61	4.67	3.36	2.26	1.64	(44)
(45)		RadStd		0.20	0.29	0.34	0.28	0.48	0.41	0.39	0.32	0.33	0.35	0.25	0.16	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+106	+78

Nomenclature: See separate page