

NEW YORK KENNEDY, NY, USA

WMO: 744860

Lat: 40.639N

Lon: 73.764W

Elev: 3

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94789

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.3	-8.0	-21.1	0.6	-8.7	-18.8	0.7	-6.2	14.6	-1.6	13.2	-1.0	7.4	300	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	32.1	22.8	30.4	22.3	29.0	21.8	25.2	28.7	24.4	27.7	23.7	26.9	5.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.1	19.0	26.8	23.4	18.2	26.1	22.6	17.4	25.5	76.6	28.5	73.4	27.8	70.7	27.0	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.2	10.0	DB	-13.2	35.4	2.8	1.9	-15.2	36.8	-16.8	37.9	-18.4	39.0	-20.4	40.4	(4)
(5)			WB	-14.6	26.4	2.5	1.2	-16.3	27.3	-17.8	27.9	-19.2	28.6	-21.0	29.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.7	0.5	1.6	5.3	10.8	15.9	21.4	24.7	24.1	20.6	14.4	8.5	3.8	(6)	
	DBStd	9.25	5.20	4.57	4.32	3.71	3.46	3.32	2.58	2.49	3.10	3.87	4.16	4.51	(7)	
	HDD10.0	1001	294	237	156	32	1	0	0	0	0	7	76	198	(8)	
	HDD18.3	2645	552	469	404	227	92	11	0	1	14	132	294	450	(9)	
	CDD10.0	1985	1	2	9	57	185	341	454	437	318	144	32	6	(10)	
	CDD18.3	587	0	0	0	2	18	102	196	178	81	11	0	0	(11)	
	CDH23.3	3777	0	0	2	18	99	600	1483	1198	346	31	0	0	(12)	
	CDH26.7	1018	0	0	0	4	19	168	459	306	57	6	0	0	(13)	
(14) Wind	WSAvg	5.0	5.7	5.7	5.8	5.4	4.7	4.5	4.4	4.2	4.4	4.9	5.2	5.5	(14)	
(15) Precipitation	PrecAvg	1162	89	72	103	95	97	101	101	121	94	102	82	105	(15)	
	PrecMax	1618	197	135	254	245	196	241	192	442	230	382	145	172	(16)	
	PrecMin	911	35	17	23	36	39	13	20	16	30	11	22	26	(17)	
	PrecStd	163	35	32	52	48	35	54	47	79	48	73	36	35	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	15.7	19.9	25.9	29.1	33.2	35.4	33.6	30.6	26.9	19.7	16.6	(19)	
		MCWB	10.7	10.1	12.3	15.9	19.8	23.0	24.4	23.8	21.6	19.5	14.8	12.7	(20)	
	2%	DB	11.3	11.9	15.9	21.3	26.1	30.6	32.7	31.3	28.3	23.4	17.6	13.9	(21)	
		MCWB	9.6	7.8	9.7	13.2	18.4	21.9	23.0	22.8	21.0	18.4	14.3	11.6	(22)	
	5%	DB	9.6	9.6	13.2	18.6	23.7	28.5	30.7	29.6	26.6	21.7	16.2	12.0	(23)	
		MCWB	7.6	6.7	8.7	11.5	17.4	20.7	22.4	22.4	20.5	18.2	13.6	10.3	(24)	
	10%	DB	7.7	7.9	11.1	16.4	21.6	26.7	29.1	28.3	25.2	20.2	14.8	10.5	(25)	
		MCWB	5.7	5.3	7.3	10.7	16.1	20.0	22.1	21.9	20.3	16.7	12.3	8.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	11.8	14.1	17.8	21.9	24.6	26.6	26.3	24.7	22.0	17.4	14.4	(27)	
		MCDB	12.8	13.7	18.2	23.2	27.1	30.2	31.9	30.5	27.0	23.4	18.2	15.9	(28)	
	2%	WB	10.2	9.1	11.4	15.3	20.2	23.4	25.2	25.2	23.6	20.5	15.7	12.2	(29)	
		MCDB	11.0	10.6	13.8	18.8	24.0	28.0	29.2	28.4	25.8	22.5	16.7	13.1	(30)	
	5%	WB	8.0	7.3	9.7	13.6	18.8	22.5	24.5	24.4	22.7	19.1	14.3	10.7	(31)	
		MCDB	9.2	8.9	12.3	16.4	22.1	26.2	28.1	27.3	24.7	21.1	15.6	12.0	(32)	
	10%	WB	6.1	5.6	8.1	12.1	17.4	21.5	23.8	23.7	21.7	17.6	12.8	8.7	(33)	
		MCDB	7.5	7.7	10.4	14.9	20.5	24.9	27.2	26.5	24.0	19.5	14.4	10.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.1	7.5	8.1	7.9	7.8	7.4	7.2	7.3	7.4	6.9	6.2	(35)	
		MCDBR	8.3	9.1	10.3	11.5	10.8	10.4	9.2	8.5	8.2	8.4	8.0	7.9	(36)	
	5% WB	MCWBR	7.6	7.0	6.5	6.0	5.7	4.7	3.8	4.1	4.4	5.5	6.3	7.6	(37)	
		MCWBR	8.0	8.7	9.3	9.6	9.5	8.9	7.5	7.0	6.5	7.4	7.0	7.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.321	0.331	0.362	0.386	0.434	0.488	0.494	0.478	0.404	0.365	0.335	0.321	(40)	
		taud	2.468	2.443	2.407	2.373	2.270	2.156	2.150	2.187	2.368	2.484	2.522	2.523	(41)	
	Edn at Noon		837	882	889	887	848	800	790	791	834	833	816	810	(42)	
			78	92	106	118	133	150	149	140	110	88	74	69	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.87	2.77	3.78	4.85	5.39	5.93	6.01	5.31	4.37	3.04	2.12	1.60	(44)	
(45)	RadStd		0.16	0.28	0.32	0.47	0.55	0.55	0.29	0.34	0.39	0.30	0.18	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+102	+68	(46)	
(47)	Regional (63 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+67	(47)	

Nomenclature: See separate page