

DUNKIRK AP, NY, USA

WMO: 744989

Lat: 42.493N

Lon: 79.272W

Elev: 203

StdP: 98.91

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 14747

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.1	-13.1	-20.4	0.6	-15.1	-17.9	0.8	-12.2	13.3	2.7	12.0	0.7	3.6	210	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	30.0	22.4	28.8	21.8	27.6	21.1	23.8	28.0	22.9	27.0	22.2	26.2	5.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.4	17.5	26.5	21.5	16.6	25.7	20.9	16.0	25.1	71.9	28.2	68.7	27.0	66.1	26.3	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	10.0	8.9	DB	-20.3	32.6	5.1	1.1	-24.0	33.4	-27.0	34.0	-29.8	34.6	-33.5	35.4	(4)
(5)			WB	-20.5	25.0	4.9	0.8	-24.0	25.6	-26.9	26.1	-29.6	26.5	-33.1	27.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-2.7	-2.6	1.3	7.7	14.2	19.3	21.8	21.1	17.6	11.6	5.8	0.6	(6)	
	DBStd	10.04	6.37	6.33	6.05	5.18	4.77	3.77	2.97	2.84	3.87	4.60	4.97	4.94	(7)	
	HDD10.0	1623	397	356	277	106	13	0	0	0	1	36	144	294	(8)	
	HDD18.3	3479	653	587	527	321	146	33	5	8	59	216	374	551	(9)	
	CDD10.0	1512	2	2	8	36	144	278	364	343	228	84	20	2	(10)	
	CDD18.3	327	0	0	0	2	18	61	111	92	37	6	0	0	(11)	
	CDH23.3	2286	0	0	1	21	135	448	828	586	240	27	0	0	(12)	
	CDH26.7	464	0	0	0	2	22	99	184	109	46	2	0	0	(13)	
(14) Wind	WSAvg	4.2	5.2	4.8	4.4	4.4	3.8	3.6	3.4	3.3	3.5	4.3	4.9	5.1	(14)	
(15) Precipitation	PrecAvg	1070	66	52	67	86	86	95	96	98	124	104	112	85	(15)	
	PrecMax	1476	143	132	138	163	173	249	234	229	301	188	308	179	(16)	
	PrecMin	798	24	11	14	23	24	28	28	22	54	24	37	33	(17)	
	PrecStd	160	29	28	28	34	39	46	49	42	56	35	50	29	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.2	16.4	20.7	26.2	29.0	31.1	31.8	31.2	30.3	26.3	20.4	17.1	(19)	
		MCWB	12.7	11.3	14.6	16.8	21.1	21.7	23.5	23.3	22.4	19.6	14.1	13.1	(20)	
	2%	DB	12.5	12.5	17.0	22.7	26.8	29.1	30.0	29.1	27.9	23.4	18.2	12.6	(21)	
		MCWB	9.7	9.3	11.8	14.7	19.1	21.6	22.7	22.2	21.4	17.8	13.1	9.4	(22)	
	5%	DB	8.9	9.1	14.0	19.9	24.6	27.7	28.7	27.7	26.2	21.2	16.3	10.3	(23)	
		MCWB	6.1	6.2	9.8	13.1	18.0	20.7	21.9	21.7	20.4	16.9	12.0	8.0	(24)	
	10%	DB	6.1	5.8	10.9	16.9	22.5	26.1	27.4	26.5	24.2	18.9	13.9	7.7	(25)	
		MCWB	3.9	3.1	7.4	11.5	16.7	20.0	21.2	20.8	19.4	14.9	10.0	5.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	13.1	15.0	18.3	21.9	23.5	25.1	24.6	23.8	20.8	15.7	13.2	(27)	
		MCDB	16.1	16.0	19.7	24.1	27.9	28.6	30.0	29.2	28.1	24.5	18.5	16.6	(28)	
	2%	WB	10.1	9.6	12.5	15.7	20.4	22.5	24.0	23.5	22.6	19.3	14.2	10.4	(29)	
		MCDB	12.1	12.4	16.0	21.3	25.4	27.4	28.4	27.3	26.5	22.4	17.3	12.4	(30)	
	5%	WB	6.6	6.6	10.2	14.0	19.1	21.7	23.0	22.7	21.3	17.2	12.3	7.9	(31)	
		MCDB	8.6	8.9	13.7	18.7	23.6	26.4	27.0	26.4	24.9	20.1	15.7	9.9	(32)	
	10%	WB	3.7	3.0	7.5	12.0	17.7	20.7	22.3	21.9	20.2	15.5	10.5	5.6	(33)	
		MCDB	6.0	5.5	10.6	15.9	21.4	25.1	26.2	25.4	23.5	18.6	13.6	7.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	7.9	8.6	10.3	10.4	9.4	9.1	9.0	9.4	8.3	7.5	6.2	(35)	
		MCDBR	10.0	12.1	12.9	14.7	12.2	11.0	9.9	10.1	10.9	11.1	10.9	10.0	(36)	
	5% WB	MCWBR	8.5	9.8	9.0	8.8	6.6	5.8	5.2	5.8	6.2	6.8	7.8	8.3	(37)	
		MCWBR	10.1	12.0	12.2	13.3	10.9	9.3	8.3	9.2	9.9	10.1	9.3	8.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.305	0.340	0.337	0.373	0.404	0.435	0.438	0.428	0.378	0.361	0.315	0.303	(40)	
		taud	2.388	2.258	2.368	2.328	2.288	2.235	2.249	2.267	2.379	2.408	2.506	2.455	(41)	
	Ebn at Noon		832	849	907	894	871	841	834	831	851	821	822	805	(42)	
		Edh at Noon	80	107	108	121	130	137	134	128	106	91	71	69	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.28	2.11	3.18	4.40	5.41	5.88	5.93	5.27	4.16	2.53	1.55	0.98	(44)	
	RadStd		0.12	0.21	0.41	0.47	0.55	0.44	0.46	0.30	0.39	0.26	0.24	0.14	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page