

FALLBROOK 5 NE, CA, USA

WMO: 745020

Lat: 33.4392N

Lon: 117.1904W

Elev: 1140

StdP: 14.10

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 53151

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	39.2	41.6	1.6	6.2	64.5	6.6	8.1	63.2	15.0	54.4	14.0	54.9	6.5	N/A	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	25.7	97.0	66.3	93.5	65.2	90.5	64.7	70.7	89.7	69.5	87.3	68.3	85.1	6.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	97.1	74.5	63.7	92.2	74.0	62.4	87.8	73.3	35.1	89.7	34.2	87.2	33.1	85.0	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.6	11.0	9.8	DB	34.6	105.8	1.9	3.3	33.2	108.2	32.1	110.1	31.0	112.0	29.7	114.4	
			WB	29.4	73.1	1.7	0.8	28.2	73.6	27.2	74.1	26.2	74.6	24.9	75.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.4	58.7	57.2	59.7	62.1	63.6	68.8	73.6	75.4	75.1	70.1	63.8	56.7
	DBStd	9.19	6.93	7.59	6.48	6.21	5.98	5.13	4.46	5.03	6.42	7.18	7.52	6.48
	HDD50	38	8	14	2	1	0	0	0	0	0	0	1	12
	HDD65	1288	217	239	191	128	94	12	0	0	1	28	110	268
	CDD50	5670	277	215	303	363	422	563	731	786	752	622	415	221
	CDD65	1445	21	20	28	40	50	125	266	321	303	185	74	12
	CDH74	13095	151	184	292	486	569	1192	2287	2892	2752	1578	625	87
	CDH80	5585	21	41	74	173	235	450	952	1339	1345	718	227	10
Wind	WSAvg	4.8	5.7	5.2	4.9	4.9	4.5	4.1	4.1	4.0	4.3	4.9	5.5	5.5
Precipitation	PrecAvg	12.9	2.6	2.9	1.9	0.9	0.3	0.1	0.2	0.1	0.2	0.6	1.0	2.1
	PrecMax	25.9	13.7	11.3	9.0	2.3	1.8	0.8	2.2	0.9	1.4	6.2	3.0	10.2
	PrecMin	4.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.9	3.3	2.5	2.1	0.7	0.4	0.2	0.4	0.2	0.3	1.3	0.8	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.9	84.7	87.3	91.5	94.8	97.8	97.1	99.7	102.8	98.6	91.7	81.2
		MCWB	54.4	55.7	58.0	58.6	59.0	66.3	68.2	69.0	68.2	61.4	58.3	52.7
	2%	DB	78.2	80.0	81.1	85.3	86.3	90.0	92.1	94.7	96.7	93.3	86.7	76.3
		MCWB	52.7	54.6	57.2	55.8	58.4	65.6	67.8	68.2	67.5	59.0	56.3	52.3
	5%	DB	74.5	74.9	76.8	79.6	79.8	84.9	88.6	91.2	92.1	88.0	81.4	71.4
		MCWB	51.6	54.3	55.9	56.2	60.0	64.3	67.1	67.7	66.6	59.2	55.0	51.0
	10%	DB	70.3	69.6	71.8	74.6	74.8	80.5	85.5	87.6	88.0	83.1	76.3	66.9
		MCWB	50.7	51.9	55.1	56.4	59.5	63.4	66.9	67.2	65.5	59.2	53.5	50.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.7	60.8	62.7	62.9	65.3	69.2	71.4	72.4	71.6	68.9	62.2	61.4
		MCDB	74.6	71.9	79.7	78.4	83.6	89.1	89.7	91.0	92.9	81.3	77.2	64.4
	2%	WB	56.4	57.9	60.1	60.8	63.2	67.4	69.9	70.8	70.5	66.1	59.7	58.2
		MCDB	67.7	70.5	75.1	75.1	78.5	85.4	87.2	89.1	91.2	77.9	75.9	65.4
	5%	WB	54.7	56.0	58.4	59.3	61.7	65.6	68.7	69.4	68.9	64.1	58.0	56.1
		MCDB	65.1	70.0	72.3	73.5	75.2	81.5	85.3	86.8	87.6	77.8	72.9	62.7
	10%	WB	53.1	54.4	56.8	57.7	59.9	64.1	67.6	68.2	67.2	62.3	56.5	54.1
		MCDB	63.9	68.0	69.0	70.1	71.8	78.7	83.5	84.8	82.7	75.4	69.3	61.2
Mean Daily Temperature Range	5% DB	MDBR	19.4	19.6	20.5	21.3	19.9	23.7	24.7	25.7	24.3	22.4	21.3	18.3
		MCDBR	24.4	26.1	26.9	29.0	28.3	29.8	28.0	28.0	27.5	28.3	27.3	24.4
	5% WB	MCWBR	12.0	12.5	13.0	12.1	11.7	10.9	9.9	10.2	9.7	11.2	11.9	12.4
		MCWBR	19.8	23.1	23.5	23.7	24.0	27.4	25.5	25.5	24.7	23.4	22.3	17.6
Clear-Sky Solar Irradiance	taub		0.296	0.304	0.322	0.335	0.350	0.350	0.378	0.371	0.346	0.339	0.303	0.305
	taud		2.579	2.569	2.501	2.474	2.457	2.466	2.456	2.458	2.514	2.502	2.593	2.585
	Ebn at Noon		295	303	304	302	296	295	286	287	292	285	290	285
	Edh at Noon		25	28	32	35	36	35	36	35	32	30	24	24
All-Sky Solar Radiation	RadAvg		1035	1312	1757	2126	2302	2461	2389	2264	1929	1478	1143	936
	RadStd		68	127	89	100	138	135	115	62	71	96	62	66

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (48 neighbors)	+1.10	N/A	-3.01	+1.19	N/A	N/A	N/A	-185	+391	+202

Nomenclature: See separate page