

FALLBROOK 5 NE, CA, USA

WMO: 745020

Lat: 33.4392N

Lon: 117.1904W

Elev: 348

StdP: 97.22

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 53151

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.0	5.3	-16.9	0.9	18.1	-14.1	1.2	17.3	6.7	12.5	6.3	12.7	2.9	N/A	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.3	36.1	19.0	34.2	18.4	32.5	18.1	21.5	32.0	20.8	30.7	20.2	29.5	2.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.9	23.6	17.6	13.2	23.3	16.9	12.5	22.9	63.8	32.1	61.6	30.7	59.2	29.5	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.7	4.9	4.4	1.4	41.0	1.0	1.8	0.7	42.3	0.1	43.4	-0.5	44.4	-1.3	45.8		
			-1.4	22.8	1.0	0.4	-2.1	23.1	-2.7	23.4	-3.2	23.6	-3.9	24.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	14.8	14.0	15.4	16.7	17.6	20.4	23.1	24.1	23.9	21.1	17.7	13.7	
	DBStd	5.10	3.85	4.22	3.60	3.45	3.32	2.85	2.48	2.80	3.57	3.99	4.18	3.60	
	HDD10.0	21	4	8	1	1	0	0	0	0	0	0	1	7	
	HDD18.3	716	121	133	106	71	52	7	0	0	1	16	61	149	
	CDD10.0	3150	154	119	168	202	234	313	406	437	418	346	231	123	
	CDD18.3	803	12	11	16	22	28	69	148	178	168	103	41	7	
	CDH23.3	7275	84	102	162	270	316	662	1271	1607	1529	877	347	48	
CDH26.7	3103	12	23	41	96	131	250	529	744	747	399	126	6		
Wind	WSAvg	2.1	2.5	2.3	2.2	2.2	2.0	1.8	1.8	1.8	1.9	2.2	2.4	2.4	
Precipitation	PrecAvg	328	67	73	47	24	8	3	4	3	5	15	25	53	
	PrecMax	658	349	288	228	58	45	21	57	23	36	157	76	258	
	PrecMin	108	1	0	0	0	0	0	0	0	0	0	0	0	
	PrecStd	150	83	64	53	18	10	5	11	5	8	32	21	53	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.3	29.3	30.7	33.1	34.9	36.5	36.2	37.6	39.4	37.0	33.2	27.4	
		MCWB	12.5	13.2	14.4	14.8	15.0	19.1	20.1	20.6	20.1	16.3	14.6	11.5	
	2%	DB	25.6	26.7	27.3	29.6	30.2	32.2	33.4	34.8	35.9	34.1	30.4	24.6	
		MCWB	11.5	12.5	14.0	13.2	14.7	18.7	19.9	20.1	19.7	15.0	13.5	11.3	
	5%	DB	23.6	23.8	24.9	26.4	26.6	29.4	31.4	32.9	33.4	31.1	27.5	21.9	
		MCWB	10.9	12.4	13.3	13.4	15.5	17.9	19.5	19.8	19.2	15.1	12.8	10.6	
	10%	DB	21.3	20.9	22.1	23.6	23.8	26.9	29.7	30.9	31.1	28.4	24.6	19.4	
		MCWB	10.4	11.1	12.8	13.6	15.3	17.4	19.4	19.5	18.6	15.1	12.0	10.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.8	16.0	17.1	17.2	18.5	20.7	21.9	22.4	22.0	20.5	16.8	16.3
			MCDB	23.7	22.2	26.5	25.8	28.6	31.7	32.1	32.8	33.8	27.4	25.1	18.0
2%		WB	13.6	14.4	15.6	16.0	17.3	19.7	21.1	21.5	21.4	19.0	15.4	14.6	
		MCDB	19.8	21.4	23.9	24.0	25.8	29.6	30.7	31.7	32.9	25.5	24.4	18.6	
5%		WB	12.6	13.3	14.7	15.1	16.5	18.7	20.4	20.8	20.5	17.8	14.4	13.4	
		MCDB	18.4	21.1	22.4	23.1	24.0	27.5	29.6	30.4	30.9	25.4	22.7	17.1	
10%		WB	11.7	12.5	13.8	14.3	15.5	17.9	19.8	20.1	19.5	16.8	13.6	12.3	
		MCDB	17.7	20.0	20.6	21.2	22.1	25.9	28.6	29.3	28.2	24.1	20.7	16.2	
Mean Daily Temperature Range		5% DB	MDBR	10.8	10.9	11.4	11.8	11.1	13.2	13.7	14.3	13.5	12.5	11.8	10.1
			MCDBR	13.5	14.5	15.0	16.1	15.7	16.6	15.6	15.6	15.3	15.7	15.2	13.6
	MCWBR		6.7	6.9	7.2	6.7	6.5	6.0	5.5	5.7	5.4	6.2	6.6	6.9	
	5% WB	MCDBR	11.0	12.9	13.1	13.2	13.4	15.2	14.2	14.2	13.7	13.0	12.4	9.8	
		MCWBR	6.0	6.6	6.7	6.2	5.9	5.9	5.3	5.4	5.0	5.4	6.2	5.5	
Clear-Sky Solar Irradiance	taub	0.296	0.304	0.322	0.335	0.350	0.350	0.378	0.371	0.346	0.339	0.303	0.305		
	taud	2.579	2.569	2.501	2.474	2.457	2.466	2.456	2.458	2.514	2.502	2.593	2.585		
	Ebn at Noon	930	955	957	953	934	929	901	906	919	900	913	898		
	Edh at Noon	79	88	102	110	113	111	112	110	100	93	77	75		
All-Sky Solar Radiation	RadAvg	3.26	4.13	5.54	6.70	7.26	7.76	7.53	7.14	6.08	4.66	3.60	2.95		
	RadStd	0.21	0.40	0.28	0.32	0.43	0.43	0.36	0.20	0.22	0.30	0.20	0.21		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (48 neighbors)	+0.61	N/A	-1.67	+0.66	N/A	N/A	N/A	-103	+217	+112

Nomenclature: See separate page