

YOSEMITE VILLAGE 12 W, CA, USA

WMO: 745030

Lat: 37.7592N

Lon: 119.8208W

Elev: 2018

StdP: 79.32

Time Zone: -8.00 (NAP)

Period: 07-19

WBAN: 53150

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.3	-6.9	-27.4	0.4	7.0	-22.4	0.6	7.0	7.9	1.1	6.8	1.1	1.0	N/A	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	26.6	13.7	25.4	12.7	24.4	12.3	15.4	23.8	14.5	23.1	13.6	22.5	2.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.9	11.1	20.6	10.6	10.2	19.9	9.4	9.4	18.3	50.8	23.7	47.5	22.8	44.9	22.7	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.9	3.9	3.3	-10.6	28.8	1.1	1.2	-11.3	29.7	-12.0	30.4	-12.6	31.1	-13.3	32.0		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	4.1	2.5	3.8	6.2	9.8	15.8	19.9	19.6	17.0	11.3	6.9	2.9		
	DBStd	7.93	5.23	5.67	4.88	5.31	5.24	4.73	2.81	2.82	4.46	4.72	5.58	5.26		
	HDD10.0	1217	188	215	197	137	71	10	0	1	8	42	122	227		
	HDD18.3	3211	440	443	450	363	268	99	17	18	72	219	342	480		
	CDD10.0	1230	7	6	6	24	63	184	306	298	218	83	31	5		
	CDD18.3	183	0	0	0	0	2	24	65	58	32	3	0	0		
	CDH23.3	482	0	0	0	0	2	61	174	171	72	3	0	0		
	CDH26.7	29	0	0	0	0	0	2	11	13	3	0	0	0		
(14) Wind	WSAvg	1.6	1.6	1.7	1.8	1.8	1.7	1.6	1.4	1.5	1.6	1.5	1.5	1.6		
(15) Precipitation	PrecAvg	1029	206	167	139	88	56	16	6	3	7	60	91	188		
	PrecMax	1644	517	411	466	263	149	60	75	31	50	248	238	437		
	PrecMin	535	14	11	10	6	0	0	0	0	0	0	2	22		
	PrecStd	309	144	102	124	69	42	18	16	7	12	63	71	117		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.5	15.2	16.1	19.6	23.1	26.8	28.0	28.3	26.9	23.3	19.0	15.5		
		MCWB	4.9	5.7	7.4	11.0	11.4	15.3	14.4	13.7	12.2	10.2	7.9	4.1		
	2%	DB	13.6	13.6	13.7	17.4	20.7	25.2	26.5	26.5	25.2	20.6	17.2	13.5		
		MCWB	4.0	5.0	6.0	9.0	10.8	13.5	13.9	12.8	11.6	8.7	7.0	2.8		
	5%	DB	12.2	11.9	11.9	15.5	18.8	23.6	25.2	25.2	24.1	19.0	15.7	11.7		
		MCWB	2.9	3.9	5.1	8.0	10.0	12.3	13.0	12.2	11.4	8.2	6.4	2.4		
	10%	DB	10.7	10.3	10.4	13.8	16.9	22.2	24.1	24.0	22.7	17.5	14.0	10.1		
		MCWB	2.3	3.3	4.0	6.9	8.7	11.6	12.6	11.8	11.0	7.7	5.3	2.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	7.7	8.5	13.4	13.1	17.2	16.7	15.5	14.5	11.7	8.9	5.9		
		MCDB	11.1	13.5	14.0	16.8	19.8	25.5	25.2	24.7	22.1	19.5	16.6	9.7		
	2%	WB	5.3	6.3	7.4	10.5	11.8	15.7	15.2	14.4	13.4	10.7	7.6	5.1		
		MCDB	10.0	11.7	13.1	15.7	18.7	24.3	23.8	24.3	22.0	18.7	15.2	8.6		
	5%	WB	4.5	5.4	6.6	9.0	10.7	14.4	14.4	13.4	12.5	9.9	6.5	4.1		
		MCDB	9.3	10.8	11.6	14.8	17.9	22.7	23.2	23.2	21.6	17.7	13.8	8.3		
	10%	WB	3.8	4.4	5.5	7.8	9.8	13.0	13.7	12.7	11.7	8.9	5.6	3.2		
		MCDB	8.9	9.9	10.1	13.6	16.4	21.7	22.6	22.5	20.9	16.3	12.4	8.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.4	5.7	7.0	6.9	7.3	7.0	7.8	7.9	6.9	5.9	5.5		
		MCDBR	5.7	6.0	6.7	7.7	7.7	7.3	7.0	8.0	8.0	7.1	6.2	6.0		
	5% WB	MCWBR	4.2	4.9	5.7	6.5	5.8	5.6	4.6	4.4	4.3	4.5	4.4	4.5		
		MCWBR	5.6	6.3	6.8	7.5	7.7	7.1	7.1	7.5	7.7	6.9	6.3	5.4		
(40) Clear-Sky Solar Irradiance	taub	taub	0.268	0.275	0.300	0.291	0.303	0.297	0.309	0.290	0.291	0.273	0.271	0.265		
		taud	2.471	2.465	2.400	2.490	2.493	2.525	2.508	2.553	2.559	2.610	2.551	2.510		
	Ebn at Noon	Ebn at Noon	930	966	966	990	976	977	962	978	966	961	924	912		
		Edh at Noon	80	92	109	105	107	104	105	98	92	78	73	72		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.46	3.35	4.68	6.04	7.21	8.32	8.10	7.42	6.11	4.41	2.95	2.18		
	RadStd	RadStd	0.32	0.43	0.45	0.51	0.53	0.44	0.38	0.29	0.23	0.31	0.18	0.30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	-121	+148	+53

Nomenclature: See separate page