

MOUNTAIN VIEW MOFFETT, CA, USAWMO: **745090**Lat: **37.417N**Lon: **122.050W**Elev: **12**StdP: **101.18**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **23244****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	2.5	3.8	-6.0	2.3	11.3	-3.7	2.8	10.6	9.1	13.6	8.1	13.0	0.6	140	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	31.1	18.7	28.8	18.2	26.9	17.8	20.2	28.1	19.4	26.6	18.8	25.3	4.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	12.4	23.4	16.4	11.7	22.2	16.0	11.4	21.7	57.7	27.7	55.1	26.6	52.9	25.3	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.6	6.9	-0.4	35.7	1.3	2.4	-1.3	37.3	-2.1	38.7	-2.8	40.0	-3.8	41.8		
(5)			-1.8	21.3	1.3	1.1	-2.8	22.2	-3.6	22.8	-4.3	23.4	-5.3	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.7	10.8	11.8	13.4	14.9	16.7	18.9	19.9	20.1	20.0	17.6	13.6	10.6
	DBStd	4.28	2.41	2.49	2.54	2.74	2.55	2.51	2.03	2.06	2.62	2.54	2.59	2.69
	HDD10.0	60	19	9	3	1	0	0	0	0	0	0	3	24
	HDD18.3	1214	234	182	154	109	66	19	6	4	9	46	143	241
	CDD10.0	2140	44	61	108	147	207	267	307	312	299	234	112	42
	CDD18.3	251	0	0	1	6	14	37	54	58	58	22	2	0
	CDH23.3	1618	0	2	14	69	134	267	261	279	400	179	13	0
	CDH26.7	473	0	0	1	16	46	86	64	74	141	46	1	0
Wind	WSAvg	2.5	1.7	2.2	2.4	2.8	3.1	3.2	3.3	3.0	2.4	2.0	1.7	1.9
Precipitation	PrecAvg	354	70	56	58	25	5	2	1	1	5	21	52	52
	PrecMax	798	173	184	162	101	42	12	12	16	31	89	142	112
	PrecMin	158	5	4	2	1	0	0	0	0	0	0	2	0
	PrecStd	132	49	52	40	27	9	3	3	4	8	22	44	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.7	22.9	25.2	29.1	31.5	33.0	32.0	32.4	33.7	30.9	25.4	19.5
		MCWB	11.7	13.6	15.3	17.2	17.9	18.6	20.8	20.0	18.6	17.1	15.0	13.1
	2%	DB	18.3	20.1	22.3	25.1	27.1	29.0	28.3	28.5	30.7	27.5	22.0	17.7
		MCWB	11.9	12.9	14.0	15.5	17.3	18.4	19.5	19.3	18.2	16.1	14.8	12.7
	5%	DB	16.7	18.0	20.1	22.4	23.6	26.2	26.1	26.2	27.6	25.1	19.9	16.6
		MCWB	11.8	12.2	13.5	14.9	16.0	17.9	18.6	18.7	17.8	15.5	13.6	12.3
	10%	DB	15.2	16.4	18.3	20.1	21.5	24.0	24.2	24.3	25.1	22.8	18.2	15.4
		MCWB	11.3	11.6	13.0	13.7	15.0	16.9	18.0	18.0	17.5	15.3	13.1	11.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	15.5	16.6	18.3	19.7	20.7	21.4	21.2	20.8	19.3	17.2	15.8
		MCDB	17.7	19.4	23.4	26.6	29.4	30.3	29.8	29.3	29.0	26.1	22.3	17.5
	2%	WB	13.7	14.3	15.4	16.8	17.7	19.3	19.9	20.0	19.5	18.1	16.1	14.8
		MCDB	15.8	18.3	20.3	23.9	24.4	27.2	27.3	27.2	26.8	24.0	20.1	16.6
	5%	WB	12.7	13.3	14.5	15.5	16.5	18.3	19.0	19.1	18.7	17.2	15.2	13.7
		MCDB	15.2	16.9	18.6	21.1	22.8	25.1	25.4	25.3	25.9	22.5	18.3	15.5
	10%	WB	11.8	12.5	13.6	14.4	15.5	17.4	18.3	18.4	17.9	16.3	14.2	12.5
		MCDB	14.2	15.6	17.4	19.2	21.0	23.4	24.0	23.9	24.4	21.1	17.3	14.6
Mean Daily Temperature Range	5% DB	MDBR	8.5	8.6	9.2	9.8	9.5	10.1	9.2	9.2	10.5	10.4	9.3	8.5
		MCDBR	10.8	11.6	12.3	13.7	13.3	13.6	12.0	12.1	14.9	14.5	11.8	9.6
		MCWBR	6.1	6.5	6.6	7.0	6.5	6.2	5.5	5.3	6.1	6.5	6.1	5.5
	5% WB	MCDBR	8.0	9.5	10.5	12.1	11.9	12.2	11.0	11.1	12.3	11.3	9.3	6.4
MCWBR		5.1	5.7	6.1	6.6	6.1	5.8	5.2	5.1	5.6	5.6	5.6	4.4	
Clear-Sky Solar Irradiance	taub	0.324	0.333	0.338	0.359	0.370	0.362	0.366	0.348	0.353	0.335	0.322	0.324	
	taud	2.541	2.516	2.492	2.407	2.396	2.426	2.423	2.470	2.442	2.533	2.550	2.550	
	Ebn at Noon	866	902	928	921	911	915	908	921	898	887	861	840	
	Edh at Noon	77	89	100	115	119	115	115	107	104	86	76	72	
All-Sky Solar Radiation	RadAvg	2.43	3.37	4.77	6.18	7.12	7.78	7.33	6.56	5.57	4.13	2.87	2.15	
	RadStd	0.32	0.39	0.41	0.50	0.45	0.32	0.24	0.28	0.21	0.25	0.17	0.30	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-157	N/A	N/A
(47)	Regional (43 neighbors)	N/A	N/A	-1.17	N/A	N/A	N/A	N/A	-108	+133	N/A

Nomenclature: See separate page