

BODEGA 6 WSW, CA, USA

WMO: 745180

Lat: 38.3208N

Lon: 123.0747W

Elev: 19

StdP: 101.09

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 93245

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.6	4.7	-4.2	2.7	9.4	-1.4	3.4	8.2	7.3	12.3	6.6	11.9	1.2	N/A	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	5.7	20.1	15.5	18.8	15.1	17.7	14.7	16.8	19.0	16.0	18.0	15.4	17.2	2.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.8	11.2	17.5	15.1	10.7	16.9	14.5	10.3	16.3	47.1	19.0	44.9	18.2	43.1	17.3	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.6	5.7	5.1	DB	0.8	26.6	1.2	3.5	0.0	29.1	-0.7	31.2	-1.4	33.1	-2.3	35.7
			WB	-0.4	18.4	0.7	1.2	-1.0	19.3	-1.4	20.0	-1.8	20.6	-2.4	21.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	10.4	10.3	10.6	10.9	11.5	12.7	13.5	14.1	14.0	13.4	11.8	10.0	(6)
	DBStd	2.34	2.05	2.28	1.70	1.54	1.08	1.26	1.46	1.61	1.79	2.10	2.11	2.28	(7)
	HDD10.0	98	19	22	13	7	1	0	0	0	0	1	6	29	(8)
	HDD18.3	2334	246	225	240	223	212	168	149	130	130	155	196	259	(9)
	CDD10.0	807	31	30	32	33	47	82	109	128	121	105	60	28	(10)
	CDD18.3	2	0	0	0	0	0	0	0	0	1	1	0	0	(11)
	CDH23.3	12	0	0	0	2	0	0	0	0	3	6	2	0	(12)
	CDH26.7	3	0	0	0	1	0	0	0	0	1	2	0	0	(13)
(14) Wind	WSAvg	2.1	2.2	2.5	2.4	2.5	2.5	2.3	1.8	1.7	1.8	1.8	1.9	2.2	(14)
(15) Precipitation	PrecAvg	1232	236	223	142	78	50	12	1	3	2	53	125	277	(15)
	PrecMax	1911	719	685	436	266	178	64	4	33	13	145	321	625	(16)
	PrecMin	686	3	12	4	12	0	0	0	0	0	0	1	63	(17)
	PrecStd	367	170	164	126	67	56	17	1	7	3	41	92	195	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	19.1	16.7	18.1	17.5	18.9	20.1	20.3	22.0	21.7	20.3	16.8	(19)
		MCWB	11.5	13.1	12.0	13.8	12.8	15.4	16.5	16.7	16.3	12.3	13.7	11.5	(20)
	2%	DB	15.5	15.8	14.9	15.1	15.3	17.2	18.4	18.8	19.6	19.0	17.2	15.2	(21)
		MCWB	11.1	12.4	12.6	13.1	12.9	14.5	15.4	15.9	16.3	14.4	13.1	13.2	(22)
	5%	DB	14.0	14.5	14.1	14.1	14.6	16.0	16.9	17.6	18.0	17.6	15.7	14.2	(23)
		MCWB	11.3	12.4	12.3	12.3	12.4	13.7	14.6	15.2	15.4	14.4	12.8	12.2	(24)
	10%	DB	13.2	13.5	13.3	13.5	13.8	15.2	15.9	16.7	17.0	16.5	14.7	13.4	(25)
		MCWB	11.3	11.8	11.9	11.8	11.9	13.0	14.0	14.7	14.8	14.0	12.4	11.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	14.5	14.1	14.8	14.1	15.9	16.9	17.2	18.2	16.8	15.6	15.1	(27)
		MCDB	14.1	16.7	14.9	17.2	16.8	18.0	19.7	19.5	20.2	18.7	17.5	15.4	(28)
	2%	WB	13.0	13.6	13.5	13.7	13.4	15.0	15.8	16.3	17.1	16.0	14.7	14.3	(29)
		MCDB	13.6	15.2	14.3	14.8	15.3	17.1	18.1	18.4	18.9	17.7	15.9	14.9	(30)
	5%	WB	12.5	12.9	12.9	12.9	12.8	14.1	15.1	15.5	16.0	15.4	14.0	13.5	(31)
		MCDB	13.3	14.3	13.7	13.9	14.5	15.8	17.0	17.4	18.0	16.9	14.9	14.0	(32)
	10%	WB	11.9	12.2	12.3	12.2	12.3	13.4	14.4	15.0	15.2	14.8	13.4	12.6	(33)
		MCDB	13.0	13.4	13.2	13.3	13.8	14.9	16.0	16.6	17.0	16.2	14.4	13.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	5.5	5.2	5.2	5.1	5.5	5.3	5.2	5.7	5.9	6.0	5.7	(35)
		MCDBR	7.1	6.9	5.8	5.9	5.9	6.2	6.0	5.9	6.9	7.7	7.5	6.2	(36)
	5% WB	MCWBR	4.6	4.6	4.4	4.3	4.0	4.0	3.5	3.4	4.1	4.5	4.7	4.5	(37)
		MCWBR	4.8	5.6	5.0	5.4	5.6	5.8	5.7	5.6	6.2	6.0	5.3	3.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.320	0.327	0.333	0.355	0.358	0.351	0.357	0.337	0.337	0.329	0.316	0.320	(40)
		taud	2.568	2.548	2.534	2.436	2.460	2.483	2.469	2.530	2.512	2.580	2.588	2.567	(41)
	Ebn at Noon		866	906	931	924	922	924	915	930	913	891	863	838	(42)
		Edh at Noon	74	86	95	111	111	109	109	100	96	82	72	70	(43)
(44) All-Sky Solar Radiation	RadAvg		2.27	3.21	4.54	5.99	6.97	7.61	6.99	6.15	5.31	3.91	2.69	1.96	(44)
	RadStd		0.34	0.42	0.42	0.45	0.48	0.38	0.35	0.33	0.29	0.28	0.20	0.31	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(47)	Regional (37 neighbors)	N/A	N/A	-1.19	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page