

DINOSAUR 2 E, CO, USA

WMO: 745190

Lat: 40.2446N

Lon: 108.9677W

Elev: 6062

StdP: 11.75

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 94082

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.3	2.9	-8.5	4.4	7.1	-4.3	5.5	8.6	12.4	21.6	10.0	22.9	2.4	N/A	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.5	93.0	55.8	90.7	55.5	88.4	55.2	60.4	78.6	59.4	78.5	58.4	77.9	6.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.9	83.7	63.8	53.7	76.9	64.0	51.3	70.3	64.5	29.7	78.1	28.8	78.5	28.0	78.0	64.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.5	10.7	9.0	DB	-7.0	97.7	4.9	1.5	-10.5	98.8	-13.4	99.7	-16.1	100.5	-19.7	101.6	
			WB	-8.4	62.8	5.5	1.2	-12.4	63.6	-15.6	64.3	-18.7	64.9	-22.7	65.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	21.7	28.7	39.8	46.9	56.4	69.3	76.1	72.5	63.8	49.2	37.1	23.3
	DBStd	20.13	10.00	9.64	8.60	8.39	8.47	7.91	4.42	4.77	7.80	8.74	8.91	10.07
	HDD50	3343	877	597	334	155	36	2	0	0	7	119	389	827
	HDD65	6759	1342	1017	783	543	285	50	0	8	111	492	836	1292
	CDD50	2922	0	0	16	63	236	581	810	698	421	93	4	0
	CDD65	862	0	0	0	1	19	180	346	240	75	1	0	0
	CDH74	9292	0	0	0	14	256	2160	3750	2344	753	15	0	0
	CDH80	3849	0	0	0	2	45	909	1770	924	198	1	0	0
	WSAvg	4.6	3.2	4.0	4.8	5.6	5.5	5.7	5.2	5.1	5.0	4.4	3.9	3.3
	PrecAvg	11.3	0.7	0.7	0.8	1.1	1.1	0.8	0.7	1.0	1.4	1.5	0.8	0.6
Precipitation	PrecMax	15.3	1.5	1.1	2.6	3.0	2.9	3.5	2.0	2.6	3.9	3.9	1.8	2.9
	PrecMin	7.1	0.1	0.0	0.1	0.3	0.0	0.1	0.0	0.2	0.2	0.1	0.2	0.1
	PrecStd	2.2	0.4	0.3	0.6	0.7	0.8	0.9	0.6	0.6	0.9	0.9	0.5	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.0	55.2	68.3	75.8	85.3	95.1	96.9	93.1	89.2	75.9	61.6	49.2
		MCWB	34.7	39.9	45.6	48.7	52.0	55.6	58.0	56.0	54.7	50.1	44.0	37.5
	2%	DB	40.3	49.6	62.8	70.6	80.4	91.8	94.0	90.4	85.1	70.6	57.2	44.2
		MCWB	32.1	37.9	43.0	46.0	50.0	54.8	56.5	55.5	54.0	48.0	42.4	35.2
	5%	DB	37.2	45.3	58.4	66.8	76.7	89.0	91.6	88.2	82.0	66.5	53.8	40.6
		MCWB	31.1	35.8	41.0	44.9	49.1	53.8	56.0	55.4	53.0	47.2	40.3	33.2
	10%	DB	34.5	41.6	53.9	62.3	72.4	85.7	89.4	85.8	78.6	62.7	50.3	37.0
		MCWB	29.5	34.1	38.8	43.2	48.1	52.7	56.2	55.3	51.8	45.7	38.6	31.0
	0.4%	WB	36.7	41.8	46.5	49.4	53.6	58.6	62.4	61.4	59.7	54.2	45.4	39.4
		MCDB	42.0	53.3	67.5	71.6	75.5	84.1	80.1	81.3	77.0	66.3	58.9	47.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.0	39.2	44.1	47.6	51.5	57.1	61.1	60.0	57.4	51.2	43.2	36.6
		MCDB	39.0	48.6	62.5	67.2	73.6	84.4	77.9	78.6	73.3	64.9	55.4	43.0
	5%	WB	32.1	37.1	41.9	46.0	50.2	55.7	60.0	59.0	56.2	49.4	41.1	34.5
		MCDB	36.6	45.7	57.3	63.6	71.2	82.8	78.7	77.2	71.9	62.9	51.8	40.4
	10%	WB	30.0	35.0	40.0	44.1	48.9	54.4	59.0	57.8	54.8	47.5	39.0	31.8
		MCDB	34.2	42.7	53.8	60.3	68.6	81.3	78.8	76.1	70.8	61.0	49.0	37.1
Mean Daily Temperature Range	5% DB	MDBR	13.8	15.6	19.3	22.4	23.6	27.0	26.5	25.7	24.1	20.1	16.8	13.7
		MCDBR	15.8	18.5	24.3	27.5	28.2	29.5	28.7	28.0	27.2	24.0	20.3	16.4
		MCWBR	11.8	10.7	11.9	12.7	11.0	10.4	9.3	9.4	10.1	11.0	10.5	10.4
	5% WB	MCDBR	14.9	17.5	23.0	25.6	25.8	26.4	24.8	24.5	22.2	20.4	19.6	15.3
		MCWBR	10.7	10.3	11.6	12.0	10.5	9.6	7.9	8.4	8.6	9.5	10.2	9.8
Clear-Sky Solar Irradiance	taub		0.242	0.250	0.269	0.287	0.300	0.302	0.334	0.337	0.293	0.270	0.252	0.242
	taud		2.584	2.586	2.548	2.508	2.523	2.527	2.471	2.455	2.574	2.615	2.600	2.586
	Ebn at Noon		303	314	316	314	310	308	297	293	303	302	296	295
	Edh at Noon		21	25	29	32	33	33	34	34	28	24	21	20
All-Sky Solar Radiation	RadAvg		731	1016	1450	1837	2145	2475	2266	2016	1719	1229	838	627
	RadStd		56	75	105	105	131	143	102	81	100	87	65	53

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page