

LA JUNTA 17 WSW, CO, USA

WMO: 745290

Lat: 37.8639N

Lon: 103.8224W

Elev: 4386

StdP: 12.51

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 03063

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.0	3.9	-10.1	3.7	12.7	-4.7	5.0	20.8	21.3	45.2	17.9	47.2	3.1	N/A	0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.8	99.8	61.2	97.3	60.9	94.9	61.0	67.3	84.4	66.0	84.0	64.8	83.3	7.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	100.9	71.2	61.3	95.5	70.3	59.7	90.1	70.3	34.4	84.5	33.2	83.5	32.2	83.2	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.8	15.7	13.3		DB	-13.6	103.9	6.0	2.1	-17.9	105.4	-21.4	106.6	-24.7	107.8	-29.1	109.3
				WB	-13.1	69.6	6.4	1.9	-17.8	71.0	-21.5	72.1	-25.1	73.1	-29.8	74.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.7	30.3	33.4	43.2	50.8	59.9	72.6	77.1	74.2	67.1	52.3	40.6	29.9	(6)
	DBStd	18.94	11.53	11.04	9.86	8.63	8.34	6.61	4.44	4.99	7.45	9.55	9.78	11.23	(7)
	HDD50	2461	613	473	249	92	18	0	0	0	2	83	306	625	(8)
	HDD65	5565	1076	886	675	427	198	14	0	3	63	403	732	1088	(9)
	CDD50	3453	1	7	39	117	325	677	841	751	515	155	23	2	(10)
	CDD65	1086	0	0	0	3	40	242	377	289	126	9	0	0	(11)
	CDH74	17526	1	11	92	312	1197	3910	5203	3940	2341	475	43	1	(12)
	CDH80	9251	0	1	10	65	488	2177	3062	2141	1161	143	3	0	(13)
(14) Wind	WSAvg	5.4	4.5	5.1	5.9	6.9	6.5	6.5	5.6	4.9	4.8	4.6	4.5	4.5	(14)
(15) Precipitation	PrecAvg	15.2	0.5	0.4	0.9	1.6	1.9	1.8	2.4	2.3	1.1	0.9	0.7	0.5	(15)
	PrecMax	18.3	1.1	1.3	2.4	4.7	4.8	3.8	5.2	4.7	2.2	2.9	2.0	3.5	(16)
	PrecMin	8.9	0.0	0.0	0.0	0.3	0.5	0.4	0.7	0.7	0.3	0.0	0.0	0.1	(17)
	PrecStd	2.5	0.3	0.3	0.7	1.2	1.3	0.9	1.4	1.0	0.6	0.9	0.6	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.5	75.3	81.5	86.5	94.4	103.4	102.6	101.2	97.7	88.7	78.8	69.2	(19)
		MCWB	45.8	47.8	49.8	52.4	56.5	59.7	62.5	60.6	60.0	55.1	49.5	45.6	(20)
	2%	DB	63.6	67.8	76.6	81.4	89.9	99.1	99.9	97.7	94.4	84.2	74.1	63.0	(21)
		MCWB	43.0	44.6	48.0	51.2	55.2	59.4	62.2	61.0	59.0	53.1	48.5	42.6	(22)
	5%	DB	57.2	62.8	71.9	77.7	85.9	95.9	97.7	95.0	91.3	80.0	68.3	57.3	(23)
		MCWB	40.4	42.7	46.5	50.3	55.5	59.2	62.1	61.4	59.0	52.9	45.9	40.1	(24)
	10%	DB	51.2	55.7	66.1	73.1	81.4	92.3	95.1	91.8	87.5	74.5	62.2	51.3	(25)
		MCWB	37.8	39.3	44.5	48.9	54.1	59.7	62.9	61.9	57.8	51.1	43.6	37.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.6	48.4	51.6	55.6	61.9	66.9	69.4	69.2	65.0	60.0	50.9	46.3	(27)
		MCDB	66.4	73.0	75.5	74.0	79.8	88.7	86.5	84.0	82.7	74.9	74.1	67.1	(28)
	2%	WB	43.1	45.7	49.4	53.6	59.3	64.7	67.6	67.2	63.0	56.9	48.6	42.9	(29)
		MCDB	61.1	67.5	75.3	73.7	79.1	85.6	85.0	82.8	80.8	74.8	71.0	61.0	(30)
	5%	WB	40.7	43.4	47.5	52.0	57.5	63.6	66.4	65.7	61.7	54.5	46.3	40.6	(31)
		MCDB	56.1	63.0	70.3	72.6	78.3	84.3	84.2	83.2	82.3	73.4	65.9	56.8	(32)
	10%	WB	38.0	40.3	45.6	50.2	55.8	62.3	65.3	64.4	60.4	52.5	43.9	37.7	(33)
		MCDB	50.2	56.5	66.0	71.0	75.6	83.8	83.7	82.4	81.5	72.0	61.6	50.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	32.2	32.6	35.5	33.8	33.3	34.8	32.8	32.3	34.7	35.7	35.7	32.1	(35)
		MCDBR	41.0	43.8	44.5	42.4	41.5	39.4	37.6	37.2	39.7	43.8	44.8	42.0	(36)
	5% WB	MCWBR	23.8	22.8	21.4	18.2	16.1	12.5	10.3	10.3	13.5	19.7	23.2	25.1	(37)
		MCWBR	39.6	42.5	42.4	38.7	35.8	34.4	30.1	30.6	33.0	36.6	42.3	41.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.244	0.252	0.277	0.307	0.326	0.345	0.374	0.354	0.317	0.278	0.256	0.246	(40)
		taud	2.606	2.605	2.523	2.435	2.440	2.406	2.390	2.426	2.494	2.595	2.581	2.592	(41)
	Ebn at Noon		308	318	315	309	302	295	285	290	297	303	300	299	(42)
		Edh at Noon	22	25	30	35	36	37	37	35	31	25	23	21	(43)
(44) All-Sky Solar Radiation	RadAvg		896	1173	1591	1949	2219	2407	2331	2092	1775	1345	989	783	(44)
	RadStd		60	89	113	110	129	98	82	73	86	85	66	52	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+139	+74

Nomenclature: See separate page