

COSHOCTON 8 NNE, OH, USA

WMO: 745710

Lat: 40.3667N

Lon: 81.7829W

Elev: 1120

StdP: 14.11

Time Zone: -5.00 (NAE)

Period: 06-16

WBAN: 54851

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.8	7.7	-5.4	4.3	4.0	-1.1	5.4	9.0	18.4	31.9	16.8	27.8	6.0	N/A	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	87.0	72.2	85.0	71.3	82.9	70.3	75.4	84.2	73.8	81.3	72.5	79.5	5.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.8	126.9	80.0	71.4	120.9	77.9	70.1	115.6	76.7	39.6	84.2	38.2	81.8	36.9	78.9	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.2	13.2	11.6	DB	-3.7	89.6	6.6	3.4	-8.5	92.0	-12.4	94.0	-16.1	96.0	-21.0	98.4	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	26.7	27.4	40.7	51.4	61.7	69.0	71.9	71.0	64.6	53.2	42.4	34.3
	DBStd	18.30	11.49	11.40	11.91	9.53	8.34	5.35	5.11	4.75	6.87	8.49	9.82	10.39
	HDD50	2634	729	636	340	96	9	0	0	0	1	63	265	495
	HDD65	5712	1189	1054	754	417	165	25	7	8	89	376	677	951
	CDD50	3117	5	2	53	137	372	569	680	651	438	162	38	10
	CDD65	719	0	0	2	8	64	143	221	194	77	10	0	0
	CDH74	4971	0	0	13	84	463	959	1597	1278	508	69	0	0
	CDH80	1175	0	0	0	8	72	212	451	300	121	11	0	0
Wind	WSAvg	5.3	6.8	6.6	6.6	6.6	4.5	4.1	3.8	3.6	3.9	4.9	5.6	6.2
Precipitation	PrecAvg	41.0	3.1	2.2	3.1	3.7	4.3	4.4	4.3	3.7	3.2	3.0	2.8	3.1
	PrecMax	54.7	7.5	4.8	7.4	5.5	7.9	8.3	10.7	6.7	6.9	5.6	5.1	7.6
	PrecMin	27.6	1.6	1.1	1.0	1.9	1.8	1.1	1.9	1.0	1.3	1.0	1.1	1.1
	PrecStd	6.3	1.4	0.9	1.4	1.1	1.8	1.9	2.1	1.7	1.5	1.3	1.0	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	60.3	75.5	81.3	85.3	87.9	91.8	89.0	87.5	81.8	69.1	63.5
		MCWB	57.1	48.9	59.8	60.7	71.4	71.0	74.1	71.6	71.0	62.2	57.4	58.7
	2%	DB	56.3	54.9	69.2	76.3	82.1	85.0	87.2	86.2	83.8	75.0	65.5	58.8
		MCWB	51.2	47.0	57.2	59.6	68.0	70.3	73.6	71.3	71.3	62.7	54.1	54.7
	5%	DB	49.2	50.0	64.3	72.1	79.3	82.6	84.8	83.6	79.8	71.2	61.4	55.1
		MCWB	45.3	42.8	53.5	57.2	66.8	69.4	72.0	70.8	69.4	60.5	51.6	51.0
	10%	DB	43.2	43.7	59.6	67.8	76.3	79.8	82.3	80.7	76.3	67.4	57.9	50.9
		MCWB	39.6	37.9	51.2	55.2	65.4	68.2	70.8	70.0	66.6	58.7	49.4	47.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.0	53.2	62.4	64.2	73.2	75.2	78.2	76.2	75.3	68.0	61.3	59.9
		MCDB	61.1	57.1	74.6	75.1	83.5	84.4	87.3	84.0	84.7	72.6	68.2	62.5
	2%	WB	51.6	47.9	58.8	61.7	70.3	73.1	76.3	74.4	72.4	64.2	56.2	56.3
		MCDB	54.0	55.3	66.1	71.1	79.2	81.2	85.3	81.4	79.2	70.0	60.7	58.9
	5%	WB	44.7	42.7	56.2	59.6	68.7	71.5	74.6	73.0	70.6	61.3	53.4	52.5
		MCDB	47.5	49.3	62.8	67.9	77.5	79.8	82.9	79.4	77.1	68.2	59.8	55.2
	10%	WB	38.1	37.9	51.9	57.4	66.9	70.2	72.9	71.5	68.6	58.9	50.6	48.0
		MCDB	42.6	42.6	58.1	63.8	75.2	77.2	79.8	77.5	74.2	65.6	56.8	51.5
Mean Daily Temperature Range	5% DB	MDBR	13.5	14.1	16.9	18.8	18.4	17.5	17.0	17.3	17.4	16.5	14.9	12.6
		MCDBR	18.8	20.4	22.4	23.8	21.2	20.6	19.5	20.2	20.2	21.5	19.6	17.8
		MCWBR	18.4	16.3	13.6	13.8	10.3	10.5	8.6	8.4	8.4	11.8	13.4	14.1
	5% WB	MCDBR	18.2	20.8	19.6	20.3	18.6	17.7	17.5	16.3	16.4	19.4	17.4	14.7
		MCWBR	17.8	17.1	12.3	13.7	9.7	10.0	8.9	7.9	8.1	12.4	13.9	13.9
Clear-Sky Solar Irradiance	taub		0.303	0.324	0.350	0.389	0.428	0.454	0.458	0.448	0.389	0.359	0.320	0.303
	taud		2.446	2.367	2.366	2.279	2.192	2.161	2.166	2.183	2.323	2.404	2.488	2.477
	Ebn at Noon		273	282	286	280	271	263	260	259	269	266	265	264
	Edh at Noon		25	31	35	41	46	47	47	45	36	30	24	23
All-Sky Solar Radiation	RadAvg		489	757	1070	1451	1714	1866	1844	1695	1376	928	619	418
	RadStd		44	102	105	141	142	141	123	89	125	84	86	49

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (44 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+234	+122	

Nomenclature: See separate page