

OCEAN CITY, MD, USA

WMO: 745946

Lat: 38.308N

Lon: 75.124W

Elev: 12

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 00-19

WBAN: 93786

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.8	19.5	-0.4	5.4	19.1	4.0	6.8	23.1	25.9	33.9	23.3	33.1	8.2	330	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	90.2	76.6	87.6	76.2	85.1	75.3	79.7	86.6	78.3	84.5	77.3	83.0	8.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.6	143.7	83.3	76.6	138.5	82.1	75.4	133.0	80.8	43.1	86.3	41.7	84.7	40.6	83.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.9	19.0	17.0	8.7	96.8	7.1	3.1	3.6	99.0	-0.6	100.9	-4.6	102.6	-9.7	104.9		
			7.1	81.7	6.0	1.3	2.7	82.6	-0.8	83.3	-4.1	84.1	-8.5	85.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	36.2	38.2	44.5	53.8	63.0	72.2	77.1	75.5	70.3	59.6	48.9	41.8
	DBStd	16.16	9.93	8.83	8.52	8.00	7.44	6.12	4.97	4.89	5.82	8.03	8.03	8.56
	HDD50	1454	439	342	215	46	2	0	0	0	0	11	116	283
	HDD65	4198	894	749	636	347	131	10	0	0	19	207	485	720
	CDD50	3962	11	13	45	161	404	666	841	792	609	309	83	28
	CDD65	1229	0	0	1	12	68	226	377	327	178	39	1	0
	CDH74	9227	0	0	10	75	316	1591	3412	2709	980	133	1	0
	CDH80	2415	0	0	2	18	58	441	1019	698	164	15	0	0
(14) Wind	WSAvg	7.9	8.6	8.6	9.1	9.0	7.8	7.1	6.6	6.4	7.5	8.0	7.9	7.9
(15) Precipitation	PrecAvg	43.9	3.2	2.9	4.3	3.3	3.3	3.6	4.0	4.4	4.2	3.5	3.3	3.8
	PrecMax	60.0	7.4	6.7	9.0	5.6	6.4	8.0	7.2	12.0	8.6	6.5	7.4	7.8
	PrecMin	33.5	1.4	0.6	0.3	1.1	0.8	1.4	1.0	0.7	0.5	0.0	0.1	1.7
	PrecStd	7.1	1.3	1.5	1.9	1.1	1.6	1.6	1.7	2.5	2.3	2.0	2.0	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.5	66.4	72.1	82.6	86.0	92.6	95.0	94.1	88.2	81.4	71.6	66.2
		MCWB	57.5	55.4	58.7	66.0	73.0	76.1	79.0	78.4	75.6	70.5	64.8	59.5
	2%	DB	58.2	59.5	64.9	74.6	80.8	88.1	90.3	88.9	83.9	77.4	66.8	61.8
		MCWB	53.9	52.3	55.9	63.4	70.4	74.5	77.7	77.1	74.4	70.4	61.7	58.1
	5%	DB	54.4	54.9	60.7	69.9	77.3	84.8	87.8	86.1	81.4	74.6	64.1	58.6
		MCWB	50.7	49.1	53.9	61.8	68.9	73.7	76.9	76.3	73.5	68.8	59.7	55.4
	10%	DB	51.1	51.7	56.7	65.5	74.1	81.9	85.2	83.7	79.1	72.1	62.1	55.4
		MCWB	47.6	47.5	51.3	57.9	67.5	72.8	76.1	75.4	72.2	67.0	58.2	52.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.0	58.9	61.8	68.5	75.1	79.3	81.9	80.5	78.4	75.2	66.5	62.2
		MCDB	62.4	63.7	70.3	76.8	82.3	86.6	89.8	87.9	84.4	78.5	69.3	64.3
	2%	WB	55.0	54.2	58.1	65.6	72.6	77.3	80.1	79.4	77.0	73.1	63.5	58.9
		MCDB	57.9	57.5	63.2	72.8	78.4	84.7	87.1	86.0	81.6	76.4	65.3	61.1
	5%	WB	51.8	50.8	55.1	62.8	70.7	75.9	78.6	78.2	75.7	70.3	61.0	56.0
		MCDB	53.7	54.1	59.1	68.8	76.0	82.4	85.0	84.0	79.6	73.2	63.3	58.2
	10%	WB	48.0	47.6	52.3	60.0	68.7	74.6	77.5	77.1	74.2	68.0	58.8	53.2
		MCDB	50.2	51.1	55.9	64.4	73.3	80.3	83.4	82.4	77.7	71.1	61.5	55.0
(35) Mean Daily Temperature Range	5% DB	MDBR	15.6	16.3	15.6	15.8	14.5	14.1	13.8	14.0	14.1	16.3	17.0	16.1
		MCDBR	18.6	19.8	19.8	21.2	18.6	17.5	16.1	15.8	15.1	16.9	17.3	17.2
		MCWBR	15.6	15.5	13.8	11.5	10.3	8.2	7.3	7.4	8.9	11.0	13.7	15.4
	5% WB	MCDBR	17.2	18.7	18.1	18.2	16.2	15.1	14.0	13.3	12.0	13.2	15.3	15.8
		MCWBR	16.1	16.2	14.5	11.7	10.0	7.8	7.1	7.0	7.5	10.0	13.9	15.5
(40) Clear-Sky Solar Irradiance	taub		0.320	0.324	0.356	0.394	0.442	0.482	0.503	0.500	0.409	0.363	0.331	0.319
	taud		2.501	2.489	2.434	2.342	2.242	2.176	2.133	2.129	2.368	2.493	2.529	2.536
	Ebn at Noon		273	287	287	281	268	256	249	247	266	269	267	265
	Edh at Noon		25	29	33	39	44	47	49	48	36	29	24	23
(44) All-Sky Solar Radiation	RadAvg		679	944	1287	1645	1864	2034	1973	1769	1444	1087	774	598
	RadStd		60	95	107	117	196	156	98	117	137	106	69	56

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (62 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+257	+160

Nomenclature: See separate page